

NYISO Major Emergency Report

At 0004 on 11/07/2019 a Major Emergency was declared by the NYISO Shift Supervisor

when the power flow on Central East VC
exceeded its Voltage Transfer Limit
by more than 105%

This was caused by: Energy flows into ISO-NE exceeded scheduled amounts.

To correct this the
NYISO Shift
Supervisor:

Requested ISO-NE reduce flows to scheduled amounts, moved Phase
Angle Regulators (PARs) to reduce flows and placed a capacitor in
service to increase the limit.

Load relief was not required.

The Major Emergency was terminated at 0006 on 11/07/2019