

February 10, 2021

By Electronic Delivery

Honorable Kimberly D. Bose, Secretary
Federal Energy Regulatory Commission
888 First Street, NE
Washington, DC 20426

Re: New York Independent System Operator, Inc., Notification of Major Emergency
in the New York Control Area; Docket No. EY21-__-000

Dear Secretary Bose:

Pursuant to Section 2.13 of its Open Access Transmission Tariff (“OATT”), the New York Independent System Operator, Inc. (“NYISO”) hereby notifies the Commission that an “Emergency State” existed in the New York Control Area on February 10, 2021 at 0119. As a result, the NYISO was required to take special action to ensure that the reliability of the New York State Transmission System was not adversely affected. The NYISO has enclosed documentation describing the Emergency State and its actions. As required by Section 2.13 of the OATT, the NYISO has also notified the New York State Public Service Commission of the Emergency State and its actions.

Please feel free to contact me at (518) 356-6159 if you have any questions or comments.

Sincerely,

/s/ Gregory Campoli

Gregory Campoli
Manager, Reliability, Compliance & Industry Affairs
New York Independent System Operator

Enclosure

Cc: Wes Yeomans
Ray Stalter
Chris Sharp

NYISO Major Emergency Report

At 0119 on 02/10/2021

a Major Emergency was declared by the NYISO Shift Supervisor

when the power flow on Central East VC exceeded its Voltage Transfer Limit by 5% or more

This was caused by:

Trip of the New Scotland 345KV 77K Bus at 0118

To correct this the NYISO Shift Supervisor:

Started and redispatched generation, placed capacitors in service, and moved PARs

Load relief was not required.

The Major Emergency was terminated at 0129 on 02/10/2021