

Attachment II

4.4 Real-Time Markets and Schedules

4.4.1 Real-Time Commitment (“RTC”)

4.4.1.1 Overview

RTC will make binding unit commitment and de-commitment decisions for the periods beginning fifteen minutes (in the case of Resources that can respond in ten minutes) and thirty minutes (in the case of Resources that can respond in thirty minutes) after the scheduled posting time of each RTC run, will provide advisory commitment information for the remainder of the two and a half hour optimization period, and will produce binding schedules for External Transactions to begin at the start of each quarter hour. RTC will treat Behind-the-Meter Net Generation Resources, Energy Storage Resources, and Aggregations as already being committed and available to be scheduled. RTC will co-optimize to solve simultaneously for all Load, Operating Reserves and Regulation Service and to minimize the total as-bid production costs over its optimization timeframe. RTC will consider SCUC’s Resource commitment for the day, load forecasts that RTC itself will produce each quarter hour, binding transmission constraints, and all Real-Time Bids and Bid parameters submitted pursuant to Section 4.4.1.2 below.

4.4.1.2 Bids and Other Requests

After the Day-Ahead schedule is published and before the close of the Real-Time Scheduling Window for each hour, Customers may submit Real-Time Bids into the Real-Time Market for real-time evaluation by providing all information required to permit real-time evaluation pursuant to ISO Procedures. If the Supplier elects to participate in the Real-Time Market, and is within a defined electrical boundary, electrically interconnected with, and routinely serves a Host Load (which Host Load does not exclusively consist of Station Power) at a single PTID, it can only participate in the Real-Time Market as a Behind-the-Meter Net

Generation Resource. If a Behind-the-Meter Net Generation Resource submits Bids into the Real-Time Market for real-time evaluation, such Bids shall provide the forecasted Host Load for each hour for which Bids are submitted.

An Energy Storage Resource shall indicate in its Real-Time Bids whether its Energy Level will be ISO- or Self-Managed. An Energy Storage Resource that elects to Self-Manage its Energy Level shall be responsible for managing its Energy Level through its Bids. An Energy Storage Resource, including an Energy Storage Resource that received a Day-Ahead Schedule, may change its Energy Level Management election for each operating hour in the Real-Time Market day.

A Supplier's Real-Time Market Self-Committed Flexible Bid for a DER Aggregation may include Energy withdrawals if the DER Aggregation includes at least one Withdrawal-Eligible Generator. A Supplier's Real-Time Market Bids for a DER Aggregation to withdraw Energy and to supply Energy shall be submitted in a single, continuous bid curve representing the Capacity, in MW, that is being made available. When the Energy Bid for the DER Aggregation includes both Energy supply and Energy withdrawal by a Withdrawal-Eligible Generator that is a component of the Aggregation, each point of the DER Aggregation's Bid curve shall reflect the net offer, such that any Energy withdrawals reduce the Energy the DER Aggregation is capable of supplying.

A Supplier may submit a Real-Time Market Self-Committed Fixed Bid for a DER Aggregation to withdraw Energy if the DER Aggregation includes at least one Withdrawal-Eligible Generator. When a Self-Committed Fixed Bid for a DER Aggregation reflects both Energy supply and Energy withdrawals by a Withdrawal-Eligible Generator that is a component of the Aggregation, the DER Aggregation's Bid shall reflect the net offer, such that any Energy

withdrawals reduce the Energy the DER Aggregation is capable of supplying. However, if the Monthly Net Benefit Threshold price is less than the LBMP, Demand Side Resources shall not be permitted to net Energy withdrawals of Withdrawal-Eligible Generators in the DER Aggregation.

Co-located Storage Resources can each offer all of their available capability into the Real-Time Market. RTC will account for the CSR Scheduling Limits in the schedules it determines for CSR Generators.

4.4.1.2.1 Real-Time Bids to Supply or Withdraw Energy and Supply Ancillary Services, other than External Transactions

Intermittent Power Resources and Aggregations that depend solely on wind or solar energy as their fuel submitting new or revised offers to supply Energy shall bid as ISO-Committed Flexible and shall submit a Minimum Generation Bid of zero MW and zero cost and a Start-Up Bid at zero cost.

Eligible Customers may submit new or revised Bids to supply or withdraw Energy, and to supply Operating Reserves and/or Regulation Service. Customers that submit such Bids may specify different Bid parameters in real-time than they did Day-Ahead.

Self-Managed Energy Storage Resources, Self-Managed Aggregations that are made up entirely of Energy Storage Resources and DER Aggregations may submit a Self-Committed Fixed or Flexible Bid to inject Energy that includes a Lower Operating Limit that is equal to or greater than zero MW. Self-Managed Energy Storage Resources, Self-Managed Aggregations that are made up entirely of Energy Storage Resources and withdrawal-eligible DER Aggregations may submit a Self-Committed Fixed or Flexible Bid to withdraw Energy that includes a Normal Upper Operating Limit that is equal to or less than zero MW. Otherwise,

Energy Storage Resources and Aggregations may not submit Bids that include a Lower Operating Limit that exceeds zero MW, or an Upper Operating Limit that is less than zero MW.

Incremental Energy Bids, for portions of the Capacity of Resources that were scheduled in the Day-Ahead Market, and/or Start-Up Bids may be submitted by Suppliers bidding Resources using ISO-Committed Fixed, ISO-Committed Flexible, and Self-Committed Flexible bid modes that exceed the Incremental Energy Bids or Start-Up Bids submitted in the Day-Ahead Market or the mitigated Day-Ahead Incremental Energy Bids or Start-Up Bids where appropriate, if not otherwise prohibited pursuant to other provisions of the tariff.

The ISO will use a Fast-Start Resource's single point Start-Up Bid if one is submitted (or the mitigated Bid, where appropriate). If a Fast-Start Resource does not submit a single point Start-Up Bid in real-time, the ISO will use the point on the Fast-Start Resource's multi-point Start-Up Bid curve (or its mitigated multi-point Start-Up Bid curve, where appropriate) that corresponds to the shortest specified down time.

Minimum Generation Bids or Regulation Service Bids for any hour in which Resources received a Day-Ahead Energy schedule or a Regulation Service schedule, as appropriate, may not exceed the Minimum Generation Bids or Regulation Service Bids, as appropriate, submitted for those Resources in the Day-Ahead Market. Provided however, a Fast-Start Resource that receives a Day-Ahead schedule may submit Minimum Generation Bids using ISO-Committed Fixed, ISO-Committed Flexible, and Self-Committed Flexible bid modes that exceed the dollar component of the Bids submitted in the Day-Ahead Market, or the dollar component of the mitigated Day-Ahead Bids where appropriate, if not otherwise prohibited pursuant to other provisions of the tariff.

Additionally, Real-Time Minimum Run Qualified Gas Turbine Customers shall not increase their previously submitted Real-Time Incremental Energy Bids, Minimum Generation Bids, or Start-Up Bids within 135 minutes of the dispatch hour. Bids to supply Energy or Ancillary Services shall be subject to the rules set forth in Section 4.2.1 of this ISO Services Tariff. For Behind-the-Meter Net Generation Resources, the ISO will consider only those segments of the Resource's Incremental Energy Bids above the forecasted Host Load and subject to the Injection Limit.

Suppliers bidding on behalf of Generators or Aggregations (except Aggregations comprised of only Intermittent Power Resources) that did not receive a Day-Ahead schedule for a given hour may offer their Generators or Aggregations, for those hours, using the ISO-Committed Flexible, Self-Committed Flexible, Self-Committed Fixed bid mode or, with ISO approval, the ISO-Committed Fixed bid modes in real-time. For Behind-the-Meter Net Generation Resources, the ISO will consider only those segments of the Resource's Incremental Energy Bids above the forecasted Host Load and subject to the Injection Limit. A Supplier bidding on behalf of a Generator or Aggregation that received a Day-Ahead schedule for a given hour may not change the bidding mode for that Generator or Aggregation for the Real-Time Market for that hour provided, however, that Generators or Aggregations that were scheduled Day-Ahead in Self-Committed Fixed mode may switch, with ISO approval, to ISO-Committed Fixed bidding mode in real-time. Generators or Aggregations that were scheduled Day-Ahead in ISO-Committed Fixed mode will be scheduled as Self-Committed Fixed in the Real-Time Market unless, with ISO approval, they change their bidding mode to ISO-Committed Fixed.

Co-located Storage Resources must each submit a CSR injection Scheduling Limit and a CSR withdrawal Scheduling Limit for each hour of the Real-Time Market to indicate the

expected capability of the relevant facilities. Resources that participate as CSR shall not submit Real-Time Market Bids that would self-commit either of the Generators, or both of the Generators together, to inject or to withdraw a quantity of Energy that exceeds an applicable CSR Scheduling Limit.

An Energy Storage Resource that, together with a Generator that submits a Minimum Generation Bid or is a Fixed Block Unit, participates as Co-located Storage Resources shall not submit Day-Ahead or Real-Time Market Bids that would self-commit the Energy Storage Resource to inject Energy such that the Generator's Minimum Generation (or full output for a Fixed Block Unit), plus the Energy Storage Resource's self schedule, exceeds the CSR injection Scheduling Limit.

When a Generator that submits a Minimum Generation Bid or that is a Fixed Block Unit participates as a Co-located Storage Resource, the ISO will treat the Generator as operating at its Minimum Generation Level (or full output for a Fixed Block Unit) for the purpose of scheduling the Energy Storage Resource whenever the Generator is scheduled, including during start-up and shut-down periods. Generators and Aggregations with a real time physical operating problem that makes it impossible for them: (a) to operate in the bidding mode in which the Generator or Aggregation was scheduled Day-Ahead; or (b) to provide all of the Energy or Ancillary Services offered in their Bids, or (c) to achieve or comply with applicable operating parameters or other requirements, shall notify the ISO. Additionally, if the Host Load of a Behind-the-Meter Net Generation Resource is greater in real-time than was forecasted Day-Ahead such that it cannot meet its Day-Ahead schedule, it must notify the ISO.

Generators and Aggregations may not submit separate Operating Reserves Availability Bids in real-time and will instead automatically be assigned a real-time Operating Reserves

Availability Bid of zero for the amount of Operating Reserves they are capable of providing in light of their response rate (as determined under Rate Schedule 4).

4.4.1.2.2 Real-Time Bids Associated with Internal and External Bilateral Transactions

Customers may use Real-Time Bids to seek to modify Bilateral Transactions that were previously scheduled Day-Ahead or propose new Bilateral Transactions, including External Transactions, for economic evaluation by RTC, provided however, that Bilateral Transactions with Trading Hubs as their POWs that were previously scheduled Day-Ahead may not be modified. Bids associated with Internal Bilateral Transactions shall be subject to the rules set forth above in Section 4.2.1.7.

Except as provided in this section, External Transaction Bids may not vary over the course of an hour. Each such Bid must offer to import, export or wheel the same amount of Energy at the same price at each point in time within that hour. At Variably Scheduled Proxy Generator Buses the ISO shall permit the submission of Bids to import or export Energy that vary the amount of Energy, and vary the price, for each quarter hour evaluation period.

The ISO may vary External Transaction Schedules at Proxy Generator Buses that are authorized to schedule transactions on an intra-hour basis if the party submitting the Bid for such a Transaction elects to permit variable scheduling. The ISO may also vary External Transaction Schedules at CTS Enabled Proxy Generator Buses. External Transaction Bids submitted to import Energy from, or export Energy to Proxy Generator Buses that are authorized to schedule transactions on either an intra-hour or hourly basis shall indicate whether the ISO may vary schedules associated with those Bids within each hour. Transmission Customers scheduling External Bilateral Transactions shall also be subject to the provisions of Section 16, Attachment J of the ISO OATT.

4.4.1.2.3 Self-Commitment Requests

Self-Committed Flexible Resources must provide the ISO with schedules of their expected minimum operating points in quarter hour increments. Self-Committed Fixed Resources must provide their expected actual operating points in quarter hour increments or, with ISO approval, bid as an ISO-Committed Fixed Generator.

4.4.1.2.4 ISO-Committed Fixed

The ability to use the ISO-Committed Fixed bidding mode in the Real-Time Market shall be subject to ISO approval pursuant to procedures, which shall be published by the ISO. Generators that have exclusively used the Self-Committed Fixed or ISO-Committed Fixed bid modes in the Day-Ahead Market or that do not have the communications systems, operational control mechanisms or hardware to be able to respond to five-minute dispatch basepoints are eligible to bid using the ISO-Committed Fixed bid mode in the Real-Time Market. Real-Time Bids by Generators using the ISO-Committed Fixed bid mode in the Real-Time Market shall provide variable Energy price Bids, consisting of up to eleven monotonically increasing, constant cost incremental Energy steps, Minimum Generation Bids, hourly Start-Up Bids and other information pursuant to ISO Procedures.

RTC shall schedule ISO-Committed Fixed Generators.

4.4.1.3 External Transaction Scheduling

RTC15 will schedule External Transactions on an hourly basis as part of its development of a co-optimized least-bid cost Real-Time Commitment. For External Transactions that are scheduled on a 15 minute basis, the amount of Energy scheduled to be imported, exported or wheeled in association with that External Transaction may change on the quarter hour. All RTC runs will schedule intra-hour External Transactions on a 15 minute basis at Variably Scheduled

Proxy Generator Buses. RTC will alert the ISO when it appears that scheduled External Transactions need to be reduced for reliability reasons but will not automatically Curtail them. Curtailment decisions will be made by the ISO, guided by the information that RTC provides, pursuant to the rules established by Attachment B of this ISO Services Tariff and the ISO Procedures. External Bilateral Transaction schedules are also governed by the provisions of Section 16, Attachment J of the OATT.

4.4.1.4 Posting Commitment/De-Commitment and External Transaction Scheduling Decisions

Except as specifically noted in Section 4.4.2, 4.4.3 and 4.4.4 of this ISO Services Tariff, RTC will make all Resource commitment and de-commitment decisions. RTC will make all economic commitment/de-commitment decisions based upon available offers assuming Suppliers internal to the NYCA have a minimum run time of at least 15 minutes, but not longer than one hour; provided however, Real-Time Minimum Run Qualified Gas Turbines shall be assumed to have a two-hour minimum run time. For Behind-the-Meter Net Generation Resources, RTC will consider only those segments of the Resource's Incremental Energy Bids above the forecasted Host Load and subject to the Injection Limit.

RTC will produce advisory commitment information and advisory real-time prices. RTC will make decisions and post information in a series of fifteen-minute "runs" which are described below.

RTC₁₅ will begin at the start of the first hour of the RTC co-optimization period and will post its commitment, de-commitment, and External Transaction scheduling decisions no later than fifteen minutes after the start of that hour. During the RTC₁₅ run, RTC will:

- (i) Commit Resources with 10-minute start-up times that should be synchronized by the time that the results of the next RTC run are posted so that they will be synchronized and running at their scheduled dispatch levels by that time;
- (ii) Commit Resources with 30-minute start-up times that should be synchronized by the time that the results of the RTC run following the next RTC run are posted so that they will be synchronized and running at their scheduled dispatch levels by that time;
- (iii) De-commit Resources that should be disconnected from the network by the time that the results of the next RTC run are posted so that they will be disconnected by that time;
- (iv) Issue advisory commitment and de-commitment guidance for periods more than thirty minutes in the future and advisory dispatch information;
- (v) Schedule economic hourly External Transactions for the next hour;
- (vi) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at Variably Scheduled Proxy Generator Buses other than a CTS Enabled Proxy Generator Bus;
- (vii) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at a CTS Enabled Proxy Generator Bus; and
- (viii) Schedule ISO-Committed Fixed Resources.

All subsequent RTC runs in the hour, *i.e.*, RTC₃₀, RTC₄₅, and RTC₀₀ will begin executing at fifteen minutes before their designated posting times (for example, RTC₃₀ will begin in the fifteenth minute of the hour), and will take the following steps:

- (i) Commit Resources with 10-minute start-up times that should be synchronized by the time that the results of the next RTC run are posted so that they will be synchronized and running at that time;
- (ii) Commit Resources with 30-minute start-up times that should be synchronized by the time that the results of the RTC run following the next RTC run are posted so that they will be synchronized and running at that time;
- (iii) De-commit Resources that should be disconnected from the network by the time that the results of the next RTC run are posted so that they will be disconnected at that time;
- (iv) Issue advisory commitment, de-commitment, and dispatching guidance for the period from thirty minutes in the future until the end of the RTC co-optimization period;
- (v) Either reaffirm that the External Transactions scheduled by previous RTC runs should continue to flow in the next hour, or inform the ISO that External Transactions may need to be reduced;
- (vi) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at Variably Scheduled Proxy Generator Buses other than a CTS Enabled Proxy Generator Bus;
- (vii) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at a CTS Enabled Proxy Generator Bus; and
- (viii) Schedule ISO-Committed Fixed Resources.

4.4.1.5 External Transaction Settlements

Settlements for External Transactions in the LBMP Market are described in Sections 4.2.6 and 4.5 of this ISO Services Tariff. Settlements for External Bilateral Transactions are also described in Section 16, Attachment J and Rate Schedules 7 and 8 of the OATT.

The calculation of Real-Time LBMPs at Proxy Generator Buses and CTS Enabled Interfaces is described in Section 17, Attachment B to this ISO Services Tariff.

4.4.2 Real-Time Dispatch

4.4.2.1 Overview

The Real-Time Dispatch will make dispatching decisions, send Base Point Signals to Internal Generators and Aggregations, produce schedules for intra-hour External Transactions at Dynamically Scheduled Proxy Generator Buses, calculate Real-Time Market clearing prices for Energy, Operating Reserves, and Real-Time Market Prices for Regulation Service, and establish real-time schedules for those products on a five-minute basis, starting at the beginning of each hour. The Real-Time Dispatch will not make commitment decisions and will not consider start-up costs in any of its dispatching or pricing decisions, except as specifically provided in Section 4.4.2.4 below. In each interval, Real-Time Dispatch will review the Beginning Energy Level of each Energy Storage Resource and of each Aggregation comprised only of Energy Storage Resources.

Real-Time Dispatch will attempt to prevent dispatching a Self-Managed Energy Storage Resource or Aggregation composed only of Energy Storage Resources in a manner that would be infeasible based on its Beginning Energy Level. Instead, Real-Time dispatch will consider an Energy Storage Resource's or Aggregation Composed of only Energy Storage Resources' Beginning Energy Level in developing a schedule for the binding interval. The Beginning

Energy Level of an Energy Storage Resource or of an Aggregation comprised only of Energy Storage Resources will be used to ensure that Operating Reserves scheduled from the Resource can be sustained for one hour if the Operating Reserves are converted to Energy. The Real-Time Dispatch will account for the CSR Scheduling Limits in the schedules and dispatch instructions it issues to CSR Generators.

Each Real-Time Dispatch run will co-optimize to solve simultaneously for Load, Operating Reserves, and Regulation Service and to minimize the total cost of production over its bid optimization horizon (which may be fifty, fifty-five, or sixty minutes long depending on where the run falls in the hour.) In addition to producing a binding schedule for the next five minutes, each Real-Time Dispatch run will produce advisory schedules for the remaining four time steps of its bid-optimization horizon (which may be five, ten, or fifteen minutes long depending on where the run falls in the hour). An advisory schedule may become binding in the absence of a subsequent Real-Time Dispatch run. RTD will use the most recent system information and the same set of Bids and constraints that are considered by RTC.

4.4.2.2 External Transaction Scheduling

All RTD runs will schedule External Transactions on a 5 minute basis at Dynamically Scheduled Proxy Generator Buses. For External Transactions that are scheduled on a 5 minute basis, the amount of Energy scheduled to be imported, exported or wheeled in association with that External Transaction may change every 5 minutes. External Bilateral Transaction Schedules are also governed by the provisions of Attachment J of the OATT.

4.4.2.3 Calculating Real-Time Market LBMPs and Advisory Prices

RTD shall calculate *ex ante* Real-Time LBMPs at each Generator bus, Transmission Node, and for each Load Zone in each RTD cycle, in accordance with the procedures set forth in

Attachment B to this ISO Services Tariff. RTD will also calculate and post advisory Real-Time LBMPs for the next four quarter hours in accordance with the procedures set forth in Attachment B.

4.4.2.4 Real-Time Pricing Rules for Scheduling Ten Minute Resources

RTD may commit and dispatch, for pricing purposes, Resources capable of starting and meeting Minimum Generation Levels within ten minutes (“eligible Resources”) when necessary to meet load. Eligible Resources committed and dispatched by RTD for pricing purposes may be physically started through normal ISO operating processes. In the RTD cycle in which RTD commits and dispatches an eligible Resource, RTD will consider the Resource’s start-up and incremental energy costs and will assume the Resource has a zero downward response rate for purposes of calculating *ex ante* Real-Time LBMPs pursuant to Section 17, Attachment B to this ISO Services Tariff.

4.4.2.5 Post the Real-Time Schedule

Subsequent to the close of the Real-Time Scheduling Window, the ISO shall post the real-time schedule for each entity that submits a Bid or Bilateral Transaction schedule. All schedules shall be considered proprietary, with the posting only visible to the appropriate scheduling Customer, Transmission Customer and Transmission Owners subject to the applicable Code of Conduct (See Attachment F to the ISO OATT). The ISO will post on the OASIS the real-time Load for each Load Zone, and the Real-Time LBMP prices (including the Congestion Component and the Marginal Losses Component) for each Load Zone for each hour of the Dispatch Day. The ISO shall conduct the real-time settlement based upon the real-time schedule determined in accordance with this Section.

4.4.3 Real-Time Dispatch - Corrective Action Mode

When the ISO needs to respond to system conditions that were not anticipated by RTC or the regular Real-Time Dispatch, *e.g.*, the unexpected loss of a major Generator or Transmission line, it will activate the specialized RTD-CAM program. RTD-CAM runs will be nominally either five or ten minutes long, as is described below. Unlike the Real-Time Dispatch, RTD-CAM will have the ability to commit certain Resources, and schedule intra-hour External Transactions at Dynamically Scheduled Proxy Generator Buses. When RTD-CAM is activated, the ISO will have discretion to implement various measures to restore normal operating conditions. These RTD-CAM measures are described below.

The ISO shall have discretion to determine which specific RTD-CAM mode should be activated in particular situations. In addition, RTD-CAM may require Resources to run above their UOL_{NS}, up to the level of their UOL_{ES} as is described in the ISO Procedures. Self-Committed Fixed Resources will not be expected to move in response to RTD-CAM Base Point Signals except when a maximum generation pickup is activated. Combined Cycle Gas Turbine Generators with Duct-Firing Capability that have opted for the Limiting Participation Flag will not be dispatched beyond the specified Participation Limit, unless such a Resource is already ~~at~~ ~~or~~ above its Participation Limit, in which case it will not be dispatched to or below ~~any higher or lower~~ than its Participation Limit, ~~physical basepoint in effect~~ at the time that RTD-CAM is activated.

Except as expressly noted in this section, RTD-CAM will dispatch the system in the same manner as the normal Real-Time Dispatch.

4.4.3.1 RTD-CAM Modes

4.4.3.1.1 Reserve Pickup

The ISO will enter this RTD-CAM mode when necessary to re-establish schedules when large area control errors occur. When in this mode, RTD-CAM will send 10-minute Base Point Signals and produce schedules for the next ten minutes. RTD-CAM may also commit, or if necessary de-commit, Resources capable of starting or stopping within 10-minutes. The ISO will continue to optimize for Energy and Operating Reserves, will recognize locational Operating Reserve requirements and Scarcity Reserve Requirements, but will set all Regulation Service schedules to zero. If Resources are committed or de-committed in this RTD-CAM mode the schedules for them will be passed to RTC and the Real-Time Dispatch for their next execution.

Resources that are eligible to provide Operating Reserves and that are available to the ISO for dispatch in real-time are required to be able to meet the energy sustainability requirements set forth in applicable NERC, NPCC and/or NYSRC reliability requirements. When the ISO enters a reserve pickup RTD-CAM mode it will determine sustainable Energy schedules for Energy Storage Resources that are eligible to provide Operating Reserves and that are available to the ISO for dispatch based on their telemetered state of charge.

The ISO will have discretion to classify a reserve pickup as a “large event” or a “small event.” In a small event the ISO will have discretion to reduce Base Point Signals in order to reduce transmission line loadings. The ISO will not ordinarily have this discretion in large events, except that it may determine Energy schedules that satisfy Operating Reserve energy sustainability requirements for Energy Storage Resources. The distinction also has significance with respect to a Supplier’s eligibility to receive Bid Production Cost guarantee payment in accordance with Section 4.6.6 and Attachment C of this ISO Services Tariff.

4.4.3.1.2 Maximum Generation Pickup

The ISO will enter this RTD-CAM mode when an Emergency makes it necessary to maximize Energy production in one or more location(s), i.e., Long Island, New York City, Southeastern New York, East of Central East and/or NYCA-wide. RTD-CAM will produce schedules directing all Generators and Aggregations located in a targeted location to increase production at their emergency response rate up to their UOL_E level and to stay at that level until instructed otherwise. RTD-CAM will produce schedules directing each Combined Cycle Gas Turbine Generator with Duct-Firing Capability that has not opted for the Limiting Participation Flag, located in a targeted location, to increase production at the normal response rate corresponding to the Generator's output level ~~its physical base point~~ at the time when RTD-CAM was activated, until reaching its UOL_E , and to continue to operate at that level until instructed otherwise. RTD-CAM will produce schedules directing each Combined Cycle Gas Turbine Generator with Duct-Firing Capability, that has opted for the Limiting Participation Flag, located in a targeted location, ~~to increase production at the normal response rate corresponding to the Generator's output level its physical base point~~ to increase production at the normal response rate corresponding to the Generator's output level ~~its physical base point~~ at the time when RTD-CAM was activated, until: (i) reaching its Participation Limit, and to continue to operate at that level until instructed otherwise, if the Generator's output level was below or equal to the Participation Limit ~~at the time when RTD-CAM was activated is below the Participation Limit~~ or (ii) reaching its UOL_E , and to continue to operate at that level until instructed otherwise, if the Generator's output level was above its Participation Limit at the time RTD-CAM was activated, to continue to operate at the level that the Generator was at prior to the RTD-CAM activation, if the Generator's output level at the time when RTD-CAM was activated is equal to or above the Participation Limit.

Security constraints will be obeyed to the extent possible. The ISO will continue to optimize for Energy and Operating Reserves, will recognize locational Operating Reserve requirements and Scarcity Reserve Requirements, but will set all Regulation Service schedules to zero.

4.4.3.1.3 Base Points ASAP -- No Commitments

The ISO will enter this RTD-CAM mode when changed circumstances make it necessary to issue an updated set of Base Point Signals. Examples of changed circumstances that could necessitate taking this step include correcting line, contingency, or transfer overloads and/or voltage problems caused by unexpected system events. When operating in this mode, RTD-CAM will produce schedules and Base Point Signals for the next five minutes but will only redispatch Generators and Aggregations that are capable of responding within five minutes. RTD-CAM will not commit or de-commit Resources in this mode.

4.4.3.1.4 Base Points ASAP -- Commit As Needed

This operating mode is identical to Base Points ASAP – No Commitments, except that it also allows the ISO to commit Generators that are capable of starting within 10 minutes when doing so is necessary to respond to changed system conditions.

4.4.3.1.5 Re-Sequencing Mode

When the ISO is ready to de-activate RTD-CAM, it will often need to transition back to normal Real-Time Dispatch operation. In this mode, RTD-CAM will calculate normal five-minute Base Point Signals and establish five minute schedules. Unlike the normal RTD-Dispatch, however, RTD-CAM will only look ahead 10-minutes. RTD-CAM re-sequencing will

terminate as soon as the normal Real-Time Dispatch software is reactivated and is ready to produce Base Point signals for its entire optimization period.

4.4.3.2 Calculating Real-Time LBMPs

When RTD-CAM is activated, RTD shall calculate *ex ante* Real-Time LBMPs at each Generator bus, Transmission Node, and for each Load Zone in accordance with the procedures set forth in Section 17, Attachment B of this ISO Services Tariff.

4.4.4 Identifying the Pricing and Scheduling Rules That Apply to External Transactions

LBMPs will be determined and External Transactions will be scheduled at external Proxy Generator Buses consistent with the table below.

| Proxy Generator Bus | PTID | Scheduled Line | Designated Scheduled Line | Non-Competitive | CTS Enabled Proxy Generator Bus | | Scheduling Frequencies | | |
|------------------------|--------|------------------------------------|---------------------------|-----------------|---------------------------------|------------------|------------------------|--------------------|---|
| | | | | | Requires CTS Bids | Permits CTS Bids | Hourly Scheduled | Variably Scheduled | Dynamically Scheduled (Not Presently Available) |
| Hydro Quebec | | | | | | | | | |
| HQ_GEN_IMPORT | 323601 | | | ✓ | | | ✓ | ✓ | |
| HQ_LOAD_EXPORT | 355639 | | | ✓ | | | ✓ | ✓ | |
| HQ_GEN_CEDARS_PROXY | 323590 | Dennison Scheduled Line | | ✓ | | | ✓ | | |
| HQ_LOAD_CEDARS_PROXY | 355586 | Dennison Scheduled Line | | ✓ | | | ✓ | | |
| HQ_GEN_WHEEL | 23651 | | | ✓ | | | ✓ | | |
| HQ_LOAD_WHEEL | 55856 | | | ✓ | | | ✓ | | |
| HQ_CHPE_GEN | 323851 | Champlain Hudson Power Express MTF | | ✓ | | | ✓*+ (See Notes) | ✓ | |
| HQ_CHPE_LOAD | 356515 | Champlain Hudson Power Express MTF | | ✓ | | | ✓*+ (See Notes) | ✓ | |
| PJM | | | | | | | | | |
| PJM_GEN_KEYSTONE | 24065 | | | | | ✓ | ✓* (See Notes) | ✓ | |
| PJM_LOAD_KEYSTONE | 55857 | | | | | ✓ | ✓* (See Notes) | ✓ | |
| PJM_GEN_NEPTUNE_PROXY | 323594 | Neptune Scheduled Line | ✓ | | | ✓ | ✓* (See Notes) | ✓ | |
| PJM_LOAD_NEPTUNE_PROXY | 355615 | Neptune Scheduled Line | ✓ | | | ✓ | ✓* (See Notes) | ✓ | |

| Proxy Generator Bus | PTID | Scheduled Line | Designated Scheduled Line | Non-Competitive | CTS Enabled Proxy Generator Bus | | Scheduling Frequencies | | |
|-------------------------|--------|----------------------------------|---------------------------|-----------------|---------------------------------|------------------|------------------------|--------------------|---|
| | | | | | Requires CTS Bids | Permits CTS Bids | Hourly Scheduled | Variably Scheduled | Dynamically Scheduled (Not Presently Available) |
| PJM_GEN_VFT_PROXY | 323633 | Linden VFT Scheduled Line | ✓ | | | ✓ | ✓* (See Notes) | ✓ | |
| PJM_LOAD_VFT_PROXY | 355723 | Linden VFT Scheduled Line | ✓ | | | ✓ | ✓* (See Notes) | ✓ | |
| PJM_HTP_GEN | 323702 | HTP Scheduled Line | ✓ | | | ✓ | ✓* (See Notes) | ✓ | |
| HUDSONTP_345KV_HTP_LOAD | 355839 | HTP Scheduled Line | ✓ | | | ✓ | ✓* (See Notes) | ✓ | |
| ISO New England | | | | | | | | | |
| N.E._GEN_SANDY_POND | 24062 | | | | ✓ | | ✓** (See Notes) | ✓ | |
| NE_LOAD_SANDY_PD | 55858 | | | | ✓ | | ✓** (See Notes) | ✓ | |
| NPX_GEN_CSC | 323557 | Cross Sound Scheduled Line | ✓ | | | | ✓ | | |
| NPX_LOAD_CSC | 355535 | Cross Sound Scheduled Line | ✓ | | | | ✓ | | |
| NPX_GEN_1385_PROXY | 323591 | Northport Norwalk Scheduled Line | | | | | ✓ | | |

| Proxy Generator Bus | PTID | Scheduled Line | Designated Scheduled Line | Non-Competitive | CTS Enabled Proxy Generator Bus | | Scheduling Frequencies | | |
|---------------------|--------|----------------------------------|---------------------------|-----------------|---------------------------------|------------------|------------------------|--------------------|---|
| | | | | | Requires CTS Bids | Permits CTS Bids | Hourly Scheduled | Variably Scheduled | Dynamically Scheduled (Not Presently Available) |
| NPX_LOAD_1385_PROXY | 355589 | Northport Norwalk Scheduled Line | | | | | ✓ | | |
| Ontario | | | | | | | | | |
| OH_GEN_PROXY | 24063 | | | | | | ✓ | | |
| OH_LOAD_PROXY | 55859 | | | | | | ✓ | | |

Notes:

* At specifically identified Proxy Generator Buses (“* See Notes”), only Wheels Through (the NYCA) are scheduled on an hourly basis.

** At specifically identified Proxy Generator Buses (“** See Notes”), only wheels through the NYCA or a neighboring Control Area are scheduled on an hourly basis.

+ The Champlain Hudson Power Express MTF, Neptune Scheduled Line and HTP Scheduled Line are all unidirectional transmission facilities. Only Imports of Energy to the NYCA can be scheduled over these facilities.

Pricing rules for Proxy Generator Buses are set forth in Section 17 of the Services Tariff.

The ISO may offer a more frequent scheduling option at a Proxy Generator Bus identified on the table. The ISO shall inform its Market Participants of the availability of such an option by providing notice at least two weeks in advance of the implementation of any such change. At the same time, the ISO shall update the above table to reflect the change in scheduling options by submitting a compliance filing in FERC Docket No. ER11-2547. Unless FERC acts on the ISO's compliance filing, the ISO shall effectuate the change in scheduling capability on the date it proposed in its compliance filing. The addition of new Proxy Generator Buses to the table, or changing the pricing rules that apply at a Proxy Generator Bus, may not be accomplished by submitting a compliance filing in Docket No. ER11-2547. The ISO may revert to establishing hourly Import and Export schedules using all available External Transaction Bids at a Proxy Generator Bus that is identified as a Dynamically or Variably Scheduled Proxy Generator Bus when the ISO or a neighboring Balancing Authority is not able to implement schedules as expected, or when necessary to ensure or preserve system reliability. When it reverts to hourly Import and Export schedules at a Dynamically or Variably Scheduled Proxy Generator Bus, the ISO shall apply the pricing rules for a corresponding Proxy Generator Bus that is not Dynamically Scheduled or Variably Scheduled. The ISO may cease evaluating CTS Interface Bids at CTS Enabled Proxy Generator Buses when the ISO or a neighboring Balancing Authority is not able to implement schedules as expected, or when necessary to ensure or preserve system reliability.

17.1 LBMP Calculation

The Locational Based Marginal Prices (“LBMPs” or “prices”) for Suppliers and Loads in the Real-Time Market will be based on the system marginal costs produced by the Real-Time Dispatch (“RTD”) program and during intervals when certain conditions exist at Proxy Generator Buses, the Real-Time Commitment (“RTC”) program. LBMPs for Suppliers and Loads in the Day-Ahead Market will be based on the system marginal costs produced by the Security Constrained Unit Commitment (“SCUC”). LBMPs calculated by SCUC and RTD will incorporate the incremental dispatch costs of Dispatchable Resources that would be scheduled to meet an increment of Load. For pricing purposes, the incremental dispatch costs of Fast-Start Resources that Bid ISO-Committed Flexible shall be adjusted to include start-up costs and minimum generation costs based on the Start-Up Bids and Minimum Generation Bids or mitigated Start-Up Bids and Minimum Generation Bids of each such Resource, as described in Section 17.1.1.2 below.

To the extent that tradeoffs exist between scheduling providers to produce Energy or reduce demand, and scheduling them to provide Regulation Service or Operating Reserves, LBMPs shall reflect the effect of meeting an increment of Load, given those tradeoffs, at each location on the Bid Production Cost associated with those services. As such, those LBMPs may incorporate: (i) Bids for Regulation Service or Operating Reserves; or (ii) shortage costs associated with the inability to meet a Regulation Service or Operating Reserves requirement under the Regulation Service Demand Curve set forth in Rate Schedule 3 of this ISO Services Tariff and Operating Reserve Demand Curves and Scarcity Reserve Demand Curve set forth in Rate Schedule 4 of this ISO Services Tariff. For the purposes of calculating LBMPs under this

Services Tariff Section 17, Energy withdrawals by Withdrawal-Eligible Generators are treated as negative generation, and can set price.

Additionally, for the purpose of calculating Real-Time LBMPs when RTD is committing and dispatching Resources meeting Minimum Generation Levels and capable of starting in ten minutes pursuant to Section 4.4.2.4 of this ISO Services Tariff, RTD shall include in the incremental dispatch cost of each such Resource a start-up cost based on the Start-Up Bid of each such Resource and shall assume for each such Resource a zero downward response rate.

17.1.1 LBMP Bus Calculation Method

System marginal costs will be utilized in an *ex ante* computation to produce Day-Ahead and Real-Time LBMP bus prices using the following equations.

The LBMP at bus i can be written as:

$$\gamma_i = \lambda^R + \gamma_i^L + \gamma_i^C$$

Where:

| | | |
|--------------|---|--|
| γ_i | = | LBMP at bus i in \$/MWh |
| λ^R | = | the system marginal price at the Reference Bus |
| γ_i^L | = | Marginal Losses Component of the LBMP at bus i which is the marginal cost of losses at bus i relative to the Reference Bus |
| γ_i^C | = | Congestion Component of the LBMP at bus i which is the marginal cost of Congestion at bus i relative to the Reference Bus |

The Marginal Losses Component of the LBMP at any bus i is calculated using the equation:

$$\gamma_i^L = (DF_i - 1)\lambda^R$$

Where:

DF_i = delivery factor for bus i to the system Reference Bus and:

$$DF_i = \left(1 - \frac{\partial L}{\partial P_i}\right)$$

Where:

L = NYCA losses; and

P_i = injection at bus i

The Congestion Component of the LBMP at bus i is calculated using the equation:

$$\gamma_i^c = - \left(\sum_{k \in K}^n GF_{ik} \mu_k \right)$$

Where:

K = the set of Constraints;

GF_{ik} = Shift Factor for bus i on Constraint k in the pre- or post-Contingency case which limits flows across that Constraint (the Shift Factor measures the incremental change in flow on Constraint k , expressed in per unit, for an increment of injection at bus i and a corresponding withdrawal at the Reference Bus); and

μ_k = the Shadow Price of Constraint k expressed in \$/MWh, provided however, this Shadow Price shall not exceed the Transmission Shortage Cost.

Substituting the equations for γ_i^L and γ_i^c into the first equation yields:

$$\gamma_i = \lambda^R + (DF_i - 1)\lambda^R - \sum_{k \in K} GF_{ik} \mu_k$$

LBMPs will be calculated for the Day-Ahead and the Real-Time Markets. In the Day-Ahead Market, the three components of the LBMP at each location will be calculated from the SCUC results and posted for each of the twenty four (24) hours of the next day. The Real-Time LBMPs will be calculated and posted for each execution of RTD.

17.1.1.1 Determining Shift Factors and Incremental System Losses

For the purposes of pricing and scheduling, Shift Factors, GF_{ik} , and loss delivery factors, DF_i , will reflect expected power flows, including expected unscheduled power flows. When determining prices and schedules, SCUC, RTC and RTD shall include both the expected power flows resulting from NYISO interchange schedules (*see* Section 17.1.1.1.2), and expected unscheduled power flows (*see* Section 17.1.1.1.1). All NYCA Resource, NYCA Load and Proxy Generator Bus Shift Factors and loss delivery factors will incorporate internal and coordinated external transmission facility outages, power flows due to schedules, and expected unscheduled power flows.

17.1.1.1.1 Determining Expected Unscheduled Power Flows

In the Day-Ahead Market, expected unscheduled power flows will ordinarily be determined based on historical, rolling 30-day on-peak and off-peak averages. To ensure expected unscheduled power flows accurately reflect anticipated conditions, the frequency and/or period used to determine the historical average may be modified by the NYISO to address market rule, system topology, operational, or other changes that would be expected to significantly impact unscheduled power flows. The NYISO will publicly post the Day-Ahead on-peak and off-peak unscheduled power flows on its web site.

In the Real-Time Market, expected unscheduled power flows will ordinarily be determined based on current power flows, modified to reflect expected changes over the real-time scheduling horizon.

17.1.1.1.2 Determining Expected Power Flows Resulting from NYISO Interchange Schedules

In the Day-Ahead Market, for purposes of scheduling and pricing, SCUC will establish expected power flows for the ABC interface, JK interface and Hopatcong-Ramapo interconnection based on the following:

- a. The percentage of PJM-NYISO scheduled interchange that is expected to flow over the Hopatcong-Ramapo interconnection;
 - 1) The expected flow over the Hopatcong-Ramapo interconnection may also be adjusted by a MW offset to reflect expected operational conditions;
- b. The percentage of PJM-NYISO scheduled interchange that is expected to flow over the ABC interface;
 - 1) The expected flow over the ABC interface will include an additional Operational Base Flow as described in Attachment CC to the OATT;
- c. The percentage of PJM-NYISO scheduled interchange (if any) that is expected to flow over the JK interface;
 - 1) The expected flow over the JK interface will include an additional Operational Base Flow as described in Attachment CC to the OATT.

The terms “ABC interface” and “JK interface” have the meaning ascribed to them in Attachment CC to the OATT.

The NYISO shall post the interchange percentage and Operational Base Flow values it is currently using to establish Day-Ahead and real-time expected Hopatcong-Ramapo interconnection, ABC interface and JK interface flows for purposes of scheduling and pricing on its web site. If the NYISO determines it is necessary to change the posted Hopatcong-Ramapo,

ABC or JK interchange percentage or Operational Base Flow values, it will provide notice to its Market Participants as far in advance of the change as is practicable under the circumstances.

In the Day-Ahead Market, scheduled interchange that is not expected to flow over the ABC interface, JK interface or Hopatcong-Ramapo interconnection (or on Scheduled Lines) will be expected to flow over the NYISO's other interconnections. Expected flows over the NYISO's other interconnections will be determined consistent with the expected impacts of scheduled interchange and consistent with shift factors and delivery factors calculated in accordance with Section 17.1.1.1, above.

For pricing purposes, flows in the Real-Time Market will be established for the ABC interface, JK interface, and Hopatcong-Ramapo interconnection based on the current flow, modified to reflect the expected incremental impacts of changes to interchange schedules over the forward scheduling horizon in a manner that is consistent with the method used to establish Day-Ahead power flows over these facilities. Expected flows over the NYISO's other interconnections will be determined based on the current flow, modified to reflect the expected incremental impacts of changes to interchange schedules over the forward scheduling horizon, and shall be consistent with shift factors and delivery factors calculated in accordance with Section 17.1.1.1, above.

17.1.1.1.3 Scheduled Lines and Chateauguay Interconnection with Hydro Quebec

For purposes of scheduling and pricing, the NYISO expects that power flows will ordinarily match the interchange schedule at Scheduled Lines, and at the NYCA's Chateauguay interconnection with Hydro Quebec, in both the Day-Ahead and Real-Time Markets.

17.1.1.2 Incremental Dispatch Costs for Pricing Fast-Start Resources

For the purpose of calculating LBMPs for the Day-Ahead and Real-Time Markets, the incremental dispatch costs of Fast-Start Resources that Bid ISO-Committed Flexible shall be adjusted to include start-up costs and minimum generation costs based on the Start-Up Bids and Minimum Generation Bids or mitigated Start-Up Bids and Minimum Generation Bids of each such Resource (“Adjusted Dispatch Costs”). For start-up costs, the ISO will use a Fast-Start Resource’s single point Start-Up Bid if one is submitted (or the mitigated Bid, where appropriate). If a Fast-Start Resource does not submit a single point Start-Up Bid in the Real-Time Market, the ISO will use the point on the Fast-Start Resource’s multi-point Start-Up Bid curve (or its mitigated multi-point Start-Up Bid curve, where appropriate) that corresponds to the shortest specified down time.

The ISO will use the following procedure to determine a Fast-Start Resource’s Adjusted Dispatch Costs for each pricing interval in the Day-Ahead and Real-Time Markets. The ISO will determine the “cost-minimizing output level” that minimizes the average as-Bid operating cost (“minimum average cost”) for that Fast-Start Resource in each hour of the Day-Ahead Market and in each RTD interval of the Real-Time Market. The average as-Bid operating cost for a Fast-Start Resource at a given operating level shall include the Fast-Start Resource’s minimum generation costs and incremental energy costs to provide Energy at that operating level, based on the Resource’s Bids, or mitigated Bids as appropriate. The average as-Bid operating cost may also include some or all of the Fast-Start Resource’s start-up costs based on the Resource’s Bids, or mitigated Bids as appropriate, in a given hour, to be determined as follows: (1) for the Day-Ahead Market, a Fast-Start Resource’s average as-Bid operating cost to operate in a given hour will include start-up costs for the hour the Resource is scheduled to start; or (2) for the Real-Time Market, a Fast-Start Resource’s average as-Bid operating cost to operate in a given RTD

interval will include the start-up costs for approximately the first fifteen minutes, among consecutive operating intervals, after the Resource is scheduled to start, *i.e.*, for each RTD interval that starts within the first fifteen minutes after the Resource is scheduled to start, the average as-Bid operating cost to operate in that interval will include start-up costs.

For all output levels less than or equal to the cost-minimizing output level, the ISO will set the Adjusted Dispatch Cost equal to the minimum average cost. For all output levels greater than the cost-minimizing output level, the ISO will set the Adjusted Dispatch Cost equal to the price on the Resource's Bid curve. The ISO will calculate Adjusted Dispatch Costs for each output level between the Fast-Start Resource's minimum operating level and its UOL_N or UOL_E (whichever is applicable).

For the purpose of calculating LBMPs for the Day-Ahead and Real-Time Markets, all Fast-Start Resources that Bid ISO-Committed Flexible are treated as flexible and able to be dispatched anywhere between zero (0) MW and their UOL_N or UOL_E (whichever is applicable). The dispatch for Fast-Start Resources, including Fixed Block Units, that participate as Co-located Storage Resources will consider CSR Scheduling Limits.

Additional rules for Fixed Block Units are set forth below in Section 17.1.2.1.2.

17.1.2 Real-Time LBMP Calculation Procedures

For each RTD interval, the ISO shall use the procedures described below in Sections 17.1.2.1-17.1.2.1.4 to calculate Real-Time LBMPs at each Load Zone, Generator bus and Transmission Node. The LBMP bus and zonal calculation procedures are described in Sections 17.1.1 and 17.1.5 of this Attachment B, respectively. Procedures governing the calculation of LBMPs at Proxy Generator Buses are set forth below in Section 17.1.6 of this Attachment B.

17.1.2.1 General Procedures

17.1.2.1.1 Overview

The ISO shall calculate Real-Time Market LBMPs using the three passes of each RTD run, except as noted below in Section 17.1.2.1.3. A new RTD run will initialize every five minutes and each run will produce prices and schedules for five points in time (the optimization period). Only the prices and schedules determined for the first time point of the optimization period will be binding. Prices and schedules for the other four time points of the optimization period are advisory.

Each RTD run shall, depending on when it occurs during the hour, have a bid optimization horizon of fifty, fifty-five, or sixty minutes beyond the first, or binding, point in time that it addresses. The posting time and the first time point in each RTD run, which establishes binding prices and schedules, will be five minutes apart. The remaining points in time in each optimization period can be either five, ten, or fifteen minutes apart depending on when the run begins within the hour. The points in time in each RTD optimization period are arranged so that they parallel as closely as possible RTC's fifteen minute evaluations.

For example, the RTD run that posts its results at the beginning of an hour ("RTD₀") will initialize at the fifty-fifth minute of the previous hour and produce schedules and prices over a fifty-five minute optimization period. RTD₀ will produce binding prices and schedules for the RTD interval beginning when it posts its results (i.e., at the beginning of the hour) and ending at the first time point in its optimization period (i.e., five minutes after the hour). It will produce advisory prices and schedules for its second time point, which is ten minutes after the first time point in its optimization period, and advisory prices and schedules for its third, fourth and fifth time points, each of which would be fifteen minutes apart. The RTD run that posts its results at five minutes after the beginning of the hour ("RTD₅") will initialize at the beginning of the hour

and produce prices over a fifty minute optimization period. RTD₅ will produce binding prices and schedules for the RTD interval beginning when it posts its results (i.e., at five minutes after the hour) and ending at the first time point in its optimization period (i.e., ten minutes after the hour.) It will produce advisory prices and schedules for its second time point (which is five minutes after the first time point), and advisory prices and schedules for its third, fourth and fifth time points, each of which would be fifteen minutes apart. The RTD run that posts its results at ten minutes after the beginning of the hour (“RTD₁₀”) will initialize at five minutes after the beginning of the hour and produce prices over a sixty minute optimization period. RTD₁₀ will produce binding prices and schedules for the interval beginning when it posts its results (i.e., at ten minutes after the hour) and ending at the first time point in its optimization period (i.e., fifteen minutes after the hour.) It will produce advisory prices and schedules for its second, third, fourth and fifth time points, each of which would be fifteen minutes after the preceding time point.

Each RTD run shall dispatch Combined Cycle Gas Turbine Generators with Duct-Firing Capability, that have opted for the Limiting Participation Flag, within the operating range determined by the corresponding RTC run, provided however, after an RTD-CAM interval, Combined Cycle Gas Turbine Generators with Duct-Firing Capability, that have opted for the Limiting Participation Flag, will be dispatched within the operating range determined by RTD-CAM for at least 15 minutes, if the RTD-CAM determines the operating zone to be different than the last RTC run.

17.1.2.1.2 Description of the Real-Time Dispatch Process

17.1.2.1.2.1 The First Pass

The first RTD pass consists of a least bid cost, multi-period co-optimized dispatch for Energy, Regulation Service and Operating Reserves that treats all Fixed Block Units that are committed by RTC, or are otherwise instructed to be online or remain online by the ISO as if they were blocked on at their UOL_N or UOL_E , whichever is applicable. Fixed Block Units that do not participate in a Co-located Storage Resource, are capable of being started and meeting Minimum Generation Levels in ten minutes or less, and that have not been committed by RTC, are treated as flexible (i.e. able to be dispatched anywhere between zero (0) MW and their UOL_N or UOL_E , whichever is applicable). The first pass establishes “physical base points” (i.e., real-time Energy schedules) and real-time schedules for Regulation Service and Operating Reserves for the first time point of the optimization period. Physical base points and schedules established for the first time point shall be binding and shall remain in effect until the results of the next run are posted. Physical base points and schedules established for all subsequent time points shall be advisory. The first pass also produces information that is used to calculate the RTD Base Point Signals that the ISO sends to Suppliers.

RTD will consider CSR Scheduling Limits when setting physical base points for Generators that participate as Co-located Storage Resources.

When establishing physical base points, the ISO shall assume that each Generator and Aggregation will move toward the physical base point established during the first pass of the prior RTD run at its specified response rate.

17.1.2.1.2.1.1 Upper and Lower Dispatch Limits for Dispatchable Resources Other Than Intermittent Power Resources That Depend on Wind or Solar Energy as Their Fuel

When setting physical base points for a Dispatchable Resource at the first time point, the ISO shall ensure that they do not fall outside of the bounds established by the Dispatchable Resource's lower and upper dispatch limits. A Dispatchable Resource's dispatch limits shall be determined based on whether it was feasible for it to reach the physical base point calculated by the last RTD run given its: (A) metered output level and metered Energy Level (if applicable) at the time that the RTD run was initialized; (B) response rate; (C) minimum generation level/LOL; (D) USL and LSL (if applicable); and (E) UOL_N or UOL_E, whichever is applicable. If it was feasible for the Dispatchable Resource to reach that base point, then its upper and lower dispatch limits shall reflect the highest and lowest output levels it could achieve over the next RTD interval starting from its previous base point, subject to factors (A) through (E) specified above. If it was not feasible for the Dispatchable Resource to reach that base point, then its upper and lower dispatch limits shall reflect the highest and lowest output levels it could achieve over the next RTD interval, subject to factors (A) through (E) specified above, but instead starting from the feasible output level closest to its previous base point.

When setting physical base points for a Dispatchable Resource at later time points, the ISO shall ensure that they do not fall outside of the bounds established by the Resource's lower and upper dispatch limits for that time point. A Resource's dispatch limits at later time points shall be based on its: (A) dispatch limits from the first time point; (B) response rate; (C) minimum generation level/LOL; (D) Energy Level, USL and LSL (if applicable); and (E) UOL_N or UOL_E, whichever is applicable.

The upper dispatch limit for a Dispatchable Resource at later time points shall be determined by adjusting the upper dispatch limit from the first time point at the Resource's

response rate, up to its UOL_N or UOL_E , whichever is applicable, considering Energy Level limitations for ISO-Managed ESRs. The lower dispatch limit for a Dispatchable Resource at later time points shall be determined by adjusting the lower dispatch limit from the first time point at the Resource's response rate, down to its minimum generation level/LOL considering applicable Energy Level limitations for ISO-Managed ESRs, or to a Demand Side Resource's Demand Reduction level.

The RTD Base Point Signals sent to Dispatchable Resources shall be the same as the physical base points determined above.

17.1.2.1.2.1.2 Upper and Lower Dispatch Limits for Intermittent Power Resources That Depend on Wind or Solar Energy as Their Fuel

For all time points of the optimization period, the Lower Dispatch Limit shall be the higher of (a) an Intermittent Power Resource's metered output level at the time that the RTD run was initialized reduced by its response rate, or (b) zero. The Upper Dispatch Limit shall be the Wind and Solar Energy Forecast for that Resource. For Intermittent Power Resources depending on wind as their fuel in commercial operation as of January 1, 2002 with a name plate capacity of 12 MWs or fewer, the Upper and Lower Dispatch Limits shall be the output level specified by the Wind and Solar Energy Forecast.

17.1.2.1.2.1.3. Setting Physical Basepoints for Fixed Generators and Aggregations

When setting physical base points for Self-Committed Fixed Generators and Aggregations in any time point, the ISO shall consider the feasibility of the Resource reaching the output levels that it specified in its self-commitment request for each time point in the RTD run given: (A) its metered output at the time that the run was initialized; and (B) its response rate.

When setting physical base points for ISO-Committed Fixed Generators and Aggregations in any time point, the ISO shall consider the feasibility of the Resource reaching the output levels scheduled for it by RTC for each time point in the RTD run given: (A) its metered output at the time that the run was initialized; and (B) its response rate.

The RTD Base Point Signals sent to Self-Committed Fixed Generators and Aggregations shall follow the quarter hour operating schedules that those Generators and Aggregations submitted in their real-time self-commitment requests.

The RTD Base Point Signals sent to ISO-Committed Fixed Generators shall follow the quarter hour operating schedules established for those Generators by RTC, regardless of their actual performance. To the extent possible, the ISO shall honor the response rates specified by such Generators when establishing RTD Base Point Signals. If a Self-Committed Fixed Generator's or Aggregation's operating schedule is not feasible based on its real-time self-commitment requests then its RTD Base Point Signals shall be determined using a response rate consistent with the operating schedule changes.

17.1.2.1.2.2 The Second Pass

The second RTD pass consists of a least bid cost, multi-period, co-optimized dispatch for Energy, Regulation Service, and Operating Reserves that treats: (i) all Fast-Start Resources that are committed by RTC; (ii) Fixed Block Units that do not participate in a Co-located Storage Resource, are capable of starting and meeting Minimum Generation Levels in ten minutes, and have not been committed by RTC; and (iii) all Fixed Block Units otherwise instructed to be online or remain online by the ISO, as flexible (i.e., able to be dispatched anywhere between zero (0) MW and their UOL_N or UOL_E , whichever is applicable), regardless of their minimum run-time status. The dispatch of Generators, including Fast-Start Resources and Fixed Block Units,

that participate as Co-located Storage Resources will consider CSR Scheduling Limits. The second pass calculates real-time Energy prices and real-time Shadow Prices for Regulation Service and Operating Reserves that the ISO shall use for settlement purposes pursuant to Section 4, Rate Schedule 15.3, and Rate Schedule 15.4 of this ISO Services Tariff respectively. The ISO will not use schedules for Energy, Regulation Service and Operating Reserves established in the second pass to dispatch Resources.

The upper and lower dispatch limits used for ISO-Committed Fixed and Self-Committed Fixed Resources shall be the same as the physical base points calculated in the first pass.

17.1.2.1.2.2.1 Upper and Lower Dispatch Limits for Dispatchable Resources Other Than Intermittent Power Resources That Depend on Wind or Solar Energy as Their Fuel

The upper dispatch limit for the first time point of the second pass for a Dispatchable Resource shall be the higher of: (A) its upper dispatch limit from the first pass; or (B) its “pricing base point” from the first time point of the prior RTD interval adjusted up within its Dispatchable range for any possible ramping since that pricing base point was issued less the higher of: (i) the physical base point established during the first pass of the RTD immediately prior to the previous RTD minus the Resource’s metered output level at the time that the current RTD run was initialized, or (ii) zero.

The lower dispatch limit for the first time point of the second pass for a Dispatchable Resource shall be the lower of: (A) its lower dispatch limit from the first pass; or (B) its “pricing base point” from the first time point of the prior RTD interval adjusted down within its Dispatchable range to account for any possible ramping since that pricing base point was issued plus the higher of: (i) the Resource’s metered output level at the time that the current RTD run was initialized minus the physical base point established during the first pass of the RTD

immediately prior to the previous RTD, considering the metered Energy Level if applicable; or
(ii) zero.

The upper dispatch limit for the later time points of the second pass for a Dispatchable Resource shall be determined by adjusting its upper dispatch limit from the first time point at the Resource's response rate, up to its UOL_N or UOL_E , whichever is applicable, considering Energy Level limitations for ISO-Managed ESRs. The lower dispatch limit for the later time points of the second pass for a Dispatchable non-Fast-Start Resource shall be determined by adjusting its lower dispatch limit from the first time point at the Resource's response rate, down to its minimum generation level/LOL, considering Energy Level limitations for ISO-Managed ESRs. The lower dispatch limit for the later time points of the second pass for a Fast Start Resource shall be determined by decreasing its lower dispatch limit from the first time point at the Resource's response rate, down to zero.

17.1.2.1.2.2.2 Upper and Lower Dispatch Limits for Intermittent Power Resources That Depend on Wind or Solar Energy as Their Fuel

For the first time point and later time points for Intermittent Power Resources that depend on wind or solar energy as their fuel, the Lower Dispatch Limit shall be zero and the Upper Dispatch Limit shall be the Wind and Solar Energy Forecast for that Resource. For Intermittent Power Resources depending on wind as their fuel in commercial operation as of January 1, 2002 with a name plate capacity of 12 MWs or fewer, the Upper and Lower Dispatch Limits shall be the output level specified by the Wind and Solar Energy Forecast.

17.1.2.1.2.3 The Third Pass

The third RTD pass is reserved for future use.

17.1.2.1.3 Variations in RTD-CAM

When the ISO activates RTD-CAM, the following variations to the rules specified above in Sections 17.1.2.1.1 and 17.1.2.1.2 shall apply.

First, if the ISO enters reserve pickup mode: (i) the ISO will produce prices and schedules for a single ten minute interval (not for a multi-point co-optimization period); (ii) the ISO shall set Regulation Service schedules to zero as described in Rate Schedule 15.3 of this ISO Services Tariff; (iii) the ISO will have discretion to make additional Generator and Aggregations commitments before executing the three RTD passes; and (iv) the ISO will have discretion to allow the RTD Base Point Signal of each Dispatchable Generator or Aggregation to be set to the higher of the Generator's or Aggregation's physical base point or its actual supply level.

Second, if the ISO enters maximum generation pickup mode: (i) the ISO will produce prices and schedules for a single five minute interval (not for a multi-point co-optimization period); (ii) the ISO shall set Regulation Service schedules to zero as described in Rate Schedule 15.3 of this ISO Services Tariff; (iii) the ISO will have discretion to make additional Generator and Aggregation commitments in the affected area before executing the three RTD passes; and (iv) the ISO will have discretion: (a) either to move the RTD Base Point Signal of each Generator and Aggregation within the affected area towards its UOL_E at its emergency response rate or set it at a level equal to its physical base point; (b) either to move the RTD Base Point Signal of each Combined Cycle Gas Turbine Generator with Duct-Firing Capability within the affected area, that has not opted for the Limiting Participation Flag, towards its UOL_E at the normal response rate corresponding to its output level ~~physical base point~~ at the time when RTD-CAM was activated, or to set it at a level equal to that physical base point; and (c) either to move the RTD Base Point Signal of each Combined Cycle Gas Turbine Generator with Duct-Firing Capability within the affected area, that has opted for the Limiting Participation Flag, (1) towards

its Participation Limit at the normal response rate corresponding to its ~~physical base point~~output level at the time when RTD-CAM was activated, if the Generator's output level at that time is equal to or below the Participation Limit or (2) to its UOLE at the normal response rate corresponding to its output level at the time when RTD-CAM was activated~~set it at a level equal to its physical base point at the time when RTD-CAM was activated~~, if the Generator's output level at that time ~~is equal to or~~was above the Participation Limit.

Third, if the ISO enters basepoints ASAP – no commitments mode it will produce prices and schedules for a single five minute interval (not for a multi-point co-optimization period).

Fourth, if the ISO enters basepoints ASAP – commit as needed mode: (i) the ISO will produce price and schedules for a single five minute interval (not for a multi-point co-optimization period); and (ii) the ISO may make additional commitments of Generators and Aggregations that are capable of starting within ten minutes before executing the three RTD passes.

Fifth, and finally, if the ISO enters re-sequencing mode it will solve for a ten-minute optimization period consisting of two five-minute time points.

17.1.2.1.4 The Real-Time Commitment (“RTC”) Process and Automated Mitigation

Attachment H of this Services Tariff shall establish automated market power mitigation measures that may affect the calculation of Real-Time LBMPs. To the extent that these measures are implemented they shall be incorporated into the RTC software through the establishment of a second, parallel, commitment evaluation that will assess the impact of the mitigation measures. The first evaluation, referred to as the “RTC evaluation,” will determine the schedules and prices that would result using an original set of offers and Bids before any additional mitigation measures, the necessity for which will be considered in the RTC

evaluation, are applied. The second evaluation, referred to as the “RT-AMP” evaluation, will determine the schedules and prices that would result from using the original set of offers and bids as modified by any necessary mitigation measures. Both evaluations will follow the rules governing RTC’s operation that are set forth in Section 4 of and this Attachment B to this ISO Services Tariff.

In situations where Attachment H specifies that real-time automated mitigation measures be utilized, the ISO will perform the two parallel RTC evaluations in a manner that enables it to implement mitigation measures one RTC run (i.e., fifteen minutes) in the future. For example, RTC₁₅ and RT-AMP₁₅ will perform Resource commitment evaluations simultaneously. RT-AMP₁₅ will then apply the mitigation “impact” test, account for reference bid levels as appropriate and determine which Resources are actually to be mitigated. This information will then be conveyed to RTC₃₀ which will make Resource commitments consistent with the application of the mitigation measures (and will thus indirectly be incorporated into future RTD runs).

17.1.3 Day-Ahead LBMP Calculation Procedures

LBMPs in the Day-Ahead Market are calculated using five passes. The first two passes are commitment and dispatch passes; the last three are dispatch only passes.

Pass 1 consists of a least cost commitment and dispatch to meet Bid Load and reliable operation of the NYS Power System that includes Day-Ahead Reliability Units.

It consists of several steps. Step 1A is a complete Security Constrained Unit Commitment (“SCUC”) to meet Bid Load. At the end of this step, committed Fast-Start Resources, Imports, Exports, Virtual Supply, Virtual Load, and non-Fast-Start Resources are dispatched to meet Bid Load. Fast-Start Resources are treated as dispatchable between zero

MW and their UOL_N or UOL_E , whichever is applicable. For mitigation purposes, LBMPs are calculated from this dispatch. Following Step 1A, SCUC tests for automated mitigation procedure (“AMP”) activation.

If AMP is activated, Step 1B tests to determine if the AMP will be triggered by mitigating offer prices subject to mitigation that exceed the conduct threshold to their respective reference prices. These mitigated offer prices together with all originally submitted offer prices not subject to automatic mitigation are then used to commit generation and dispatch energy to meet Bid Load. This step is another iteration of the SCUC process. At the end of Step 1B, committed Fast-Start Resources, Imports, Exports, Virtual Supply, Virtual Load, and non-Fast-Start Resources are again dispatched to meet Bid Load using the same mitigated or unmitigated Bids used to determine the commitment to meet Bid Load. Fast-Start Resources are treated as dispatchable between zero MW and their UOL_N or UOL_E , whichever is applicable. For mitigation purposes, LBMPs are again calculated from this dispatch. The LBMPs determined at the end of Step 1B are compared to the LBMPs determined at the end of Step 1A to determine the hours and zones in which the impact test is met.

In Step 1C, generation offer prices subject to mitigation that exceed the conduct threshold are mitigated for those hours and zones in which the impact test was met in Step 1B. The mitigated offer prices, together with the original unmitigated offer price of units whose offer prices were not subject to mitigation, or did not trigger the conduct or impact thresholds, are used to commit generation and dispatch energy to meet Bid Load. This step is also a complete iteration of the SCUC process. At the end of Step 1C, committed Fast-Start Resources, Imports, Exports, virtual supply, virtual load, and non- Fast-Start Resources are again dispatched to meet Bid Load. Fast-Start Resources are treated as dispatchable between zero MW and their UOL_N or

UOL_E, whichever is applicable. The dispatch for Generators, including Fast-Start Resources and Fixed Block Units, that participate as Co-located Storage Resources will consider CSR Scheduling Limits. For mitigation purposes, LBMPs are again calculated from this dispatch.

All non-Fast-Start Resources committed in the final step of Pass 1 (which could be either step 1A, 1B, or 1C depending on activation of the AMP) are blocked on at least to minimum generation level in Passes 4 through 6. All Energy Storage Resources and Aggregations dispatched in the final step of Pass 1 (which could be either Step 1A, 1B, or 1C depending on activation of the AMP) are blocked on at the dispatch that was determined in Pass 1 in Passes 2 through 4. The resources required to meet local system reliability are determined in Pass 1.

Pass 2 consists of a least cost commitment and dispatch of Fast-Start Resources, Imports, Exports, and non-Fast-Start Resources to meet forecast Load requirements in excess of Bid Load, considering the Wind and Solar Energy Forecast, that minimizes the cost of incremental Minimum Generation and Start Up Bids, given revenues for Minimum Generation Energy based on LBMPs calculated in Pass 1, and assumes all Fast-Start Resources are dispatchable between zero MW and their UOL_N or UOL_E, whichever is applicable. The dispatch for Generators, including Fast-Start Resources, that participate as Co-located Storage Resources will consider CSR Scheduling Limits. Incremental Import Capacity needed to meet forecast Load requirements is determined in Pass 2. Fixed Block Units committed in this pass are not included in the least cost dispatches of Passes 5 or 6. Non-Fast-Start Resources committed in this step are blocked on at least to minimum generation level in Passes 4 through 6. Intermittent Power Resources that depend on wind or solar energy as their fuel committed in this pass as a result of the consideration of the Wind and Solar Energy Forecast are not blocked in Passes 5 or 6.

Pass 3 is reserved for future use.

Pass 4 consists of a least cost dispatch to forecast Load. It is not used to set schedules or prices. It is used for operational purposes and provides a dispatch of Fast-Start Resources, Imports, Exports, and non- Fast-Start Resources committed in Passes 1 or 2. Incremental Import Capacity committed in Pass 2 is re-evaluated and may be reduced if no longer required.

Pass 5 consists of a least cost dispatch of Fast-Start Resources, Imports, Exports, Virtual Supply, Virtual Load, and non- Fast-Start Resources committed to meet Bid Load, based where appropriate on offer prices as mitigated in Pass 1. Fast-Start Resources are treated as dispatchable between zero MW and their UOL_N or UOL_E , whichever is applicable. LBMPs used to settle the Day-Ahead Market are calculated from this dispatch. The Shadow Prices used to compute Day-Ahead Market clearing prices for Regulation Service and for Operating Reserves in Rate Schedules 3 and 4 of this ISO Services Tariff are also calculated from this dispatch. Final schedules for all Imports, Exports, Virtual Supply, Virtual Load, and non-Fast-Start Resources in the Day-Ahead Market are calculated from this dispatch.

Pass 6 consists of a least cost dispatch of all Day-Ahead committed Resources, Imports, Exports, Virtual Supply, Virtual Load, based where appropriate on offer prices as mitigated in Pass 1, with the schedules of all Fixed Block Units committed in the final step of Pass 1 blocked on at maximum Capacity. Final Day-Ahead Market schedules are calculated from this dispatch for Fast-Start Resources and Combined Cycle Gas Turbine Generators with Duct-Firing Capability that have opted for the Limiting Participation Flag~~in the Day-Ahead Market are calculated from this dispatch.~~

17.1.4 Determination of Transmission Shortage Cost

The applicable Transmission Shortage Cost depends on whether a particular transmission Constraint is associated with a transmission facility or Interface that includes a non-zero

constraint reliability margin value. The ISO shall establish constraint reliability margin values for transmission facilities and Interfaces. Non-zero constraint reliability margin values established by the ISO are normally equal to 20 MW. The ISO assigns a non-zero constraint reliability margin value (normally equal to 5 MW) to certain transmission facilities accommodating power flows out of export constrained areas (or “generation pockets”) that, as further described below, are subject to a different Transmission Shortage Cost (for purposes of this Section 17.1.4, the aforementioned facilities are hereinafter referred to as “Identified Facilities”). The ISO shall post to its website a list of transmission facilities and Interfaces assigned a constraint reliability margin value other than 20 MW. The list posted by the ISO shall also include Identified Facilities and the applicable constraint reliability margin value assigned to each such facility.

Except for Identified Facilities, when evaluating transmission Constraints associated with transmission facilities and Interfaces assigned a non-zero constraint reliability margin value, SCUC, RTC, and RTD shall include consideration of a six-step demand curve consisting of the following components: (1) a MW value of additional available resource capacity equal to or less than 20% of the applicable constraint reliability margin value, at a cost of \$200/MWh; (2) a MW value of additional available resource capacity equal to or less than 40% of the applicable constraint reliability margin value, but greater than 20% of such value, at a cost of \$350/MWh; (3) a MW value of additional available resource capacity equal to or less than 60% of the applicable constraint reliability margin value, but greater than 40% of such value, at a cost of \$600/MWh; (4) a MW value of additional available resource capacity equal to or less than 80% of the applicable constraint reliability margin value, but greater than 60% of such value, at a cost of \$1,500/MWh; (5) a MW value of additional available resource capacity equal to or less than

100% of the applicable constraint reliability margin value, but greater than 80% of such value, at a cost of \$2,500/MWh; and (6) any MW value of additional available resource capacity greater than the applicable constraint reliability margin value, at a cost of \$4,000/MWh.

When evaluating transmission Constraints associated with Identified Facilities, SCUC, RTC, and RTD shall include consideration of a two-step demand curve consisting of the following components: (1) a MW value of additional available resource capacity equal to or less than the applicable constraint reliability margin value, at a cost of \$100/MWh; and (2) any MW value of additional available resource capacity greater than the applicable constraint reliability margin value, at a cost of \$250/MWh.

For transmission facilities and Interfaces assigned a non-zero constraint reliability margin value, the applicable demand curve, as described above, shall be applied in a manner such that it is considered in resolving, collectively, all applicable transmission Constraints associated with a particular transmission facility or Interface rather than applying a distinct demand curve individually to each such transmission Constraint. In the event of redundant transmission Constraints on in-series transmission facilities or parallel transmission facilities, the most limiting of such redundant transmission Constraints shall be deemed binding and utilized for the purposes of determining the applicable Shadow Price for the redundant transmission Constraints at issue. The less limiting of such redundant transmission Constraints on in-series transmission facilities or parallel transmission facilities shall be deemed non-binding and assigned a zero value Shadow Price. The MW value of the additional available resource capacity associated with each step of the applicable demand curve, as described above, shall be rounded to the nearest whole number.

For transmission facilities and Interfaces with a constraint reliability margin value of zero, the Shadow Price for transmission Constraints associated with such facilities and Interfaces shall not exceed \$4,000/MWh. SCUC, RTC, and RTD shall not include consideration of additional available resource capacity provided by a demand curve mechanism for such transmission Constraints.

In evaluating transmission Constraints for transmission facilities and Interfaces with a constraint reliability margin value of zero, the ISO will determine whether sufficient available resource capacity exists to solve each transmission Constraint at its applicable limit. If sufficient available resource capacity does not exist to solve the transmission Constraint at its otherwise applicable limit, the ISO shall increase the applicable limit for such transmission Constraint to an amount achievable by the available resource capacity plus 0.2 MW.

Notwithstanding anything to the contrary herein, in circumstances where the ISO is the “Non-Monitoring RTO” with respect to a transmission Constraint associated with a “Flowgate” subject to “M2M” coordination, the ISO’s evaluation of such transmission Constraint in the Real-Time Market shall be consistent with the rules and procedures specified in Section 35.23 of Attachment CC of the ISO OATT. For purposes of this Section 17.1.4, the terms “Non-Monitoring RTO,” “Flowgate,” and “M2M” shall have the meaning specified in Section 35.2.1 of Attachment CC of the ISO OATT.

The ISO may periodically evaluate the Transmission Shortage Cost to determine whether it is necessary to modify the Transmission Shortage Cost to avoid future operational or reliability problems. The ISO will consult with its Market Monitoring Unit after it conducts this evaluation. If the ISO determines that it is necessary to modify the Transmission Shortage Cost in order to avoid future operational or reliability problems the resolution of which would

otherwise require recurring operator intervention outside normal market scheduling procedures, in order to avoid among other reliability issues, a violation of NERC Interconnection Reliability Operating Limits or System Operating Limits, it may temporarily modify it for a period of up to ninety days, provided however the ISO shall file such change with the Commission pursuant to Section 205 of the Federal Power Act within 45 days of such modification. If circumstances reasonably allow, the ISO will consult with its Market Monitoring Unit, the Business Issues Committee, the Commission, and the PSC before implementing any such modification. In all circumstances, the ISO will: (i) consult with those entities as soon as reasonably possible after implementing a temporary modification and shall explain the reasons for the change; and (ii) notify Market Participants of any temporary modification.

The responsibilities of the ISO and the Market Monitoring Unit in evaluating and modifying the Transmission Shortage Cost, as necessary are addressed in Attachment O, Section 30.4.6.8.1 of this Market Services Tariff (“Market Monitoring Plan”).

17.1.5 Zonal LBMP Calculation Method

The computation described in Section 17.1.1 of this Attachment B is at the bus level. An eleven (11) zone model will be used for the LBMP billing related to Loads, except for Energy withdrawals by Eligible Generators for later injection onto the grid. The LBMP for a zone will be a Load weighted average of the Load bus LBMPs in the Load Zone. The Load weights which will sum to unity will be calculated from the load bus MW distribution. Each component of the LBMP for a zone will be calculated as a Load weighted average of the Load bus LBMP components in the zone. The LBMP for a zone j can be written as:

$$\gamma_j^Z = \lambda^R + \gamma_j^{L,Z} + \gamma_j^{C,Z}$$

where:

| | |
|--|--|
| $\gamma_j^Z =$ | LBMP for zone j, |
| $\gamma_j^{L,Z} = \sum_{i=1}^n W_i \gamma_i^L$ | is the Marginal Losses Component of the LBMP for zone j; |
| $\gamma_j^{C,Z} = \sum W_i \gamma_i^L$ | is the Congestion Component of the LBMP for zone j; |
| $n =$ | number of Load buses in zone j for which LBMPs are calculated; and |
| $W_i =$ | Load weighting factor for bus i. |

The NYISO also calculates and posts zonal LBMP for four (4) external zones for informational purposes only. Settlements for External Transactions are determined using the Proxy Generator Bus LBMP. Each external zonal LBMP is equal to the LBMP of the Proxy Generator Bus associated with that external zone. The table below identifies which Proxy Generator Bus LBMP is used to determine each of the posted external zonal LBMPs.

| External Zone | External Zone PTID | Proxy Generator Bus | Proxy Generator Bus PTID |
|---------------|--------------------|---------------------|--------------------------|
| HQ | 61844 | HQ_GEN_WHEEL | 23651 |
| NPX | 61845 | N.E._GEN_SANDY_POND | 24062 |
| OH | 61846 | O.H._GEN_PROXY | 24063 |
| PJM | 61847 | PJM_GEN_KEystone | 24065 |

Consistent with the ISO Services Tariff, LBMPs at Proxy Generator Buses are determined using calculated bus prices as described in this Section 17.1. However, no congestion costs due to Interface ATC Constraints shall be included for the Champlain Hudson Power Express MTF in either the Day-Ahead or Real-Time Market.

17.1.6 Real Time LBMP Calculation Methods for Proxy Generator Buses, Non-Competitive Proxy Generator Buses and Proxy Generator Buses Associated with Designated Scheduled Lines

17.1.6.1 Definitions

Interface ATC Constraint: An Interface ATC Constraint exists when proposed economic transactions over an Interface between the NYCA and the Control Area with which one or more Proxy Generator Bus(es) are associated would exceed the transfer capability for the Interface or for an associated Proxy Generator Bus.

Interface Ramp Constraint: An Interface Ramp Constraint exists when proposed interchange schedule changes pertaining to an Interface between the NYCA and the Control Area with which one or more Proxy Generator Bus(es) are associated would exceed any Ramp Capacity limit imposed by the ISO for the Interface or for an associated Proxy Generator Bus.

NYCA Ramp Constraint: A NYCA Ramp Constraint exists when proposed interchange schedule changes pertaining to the NYCA as a whole would exceed any Ramp Capacity limits in place for the NYCA as a whole.

Proxy Generator Bus Constraint: Any of an Interface ATC Constraint, an Interface Ramp Constraint, or a NYCA Ramp Constraint (individually and collectively).

External Interface Congestion: The product of: (i) the portion of the Congestion Component of the LBMP at a Proxy Generator Bus that is associated with a Proxy Generator Bus Constraint and (ii) a factor, between zero and 1, calculated pursuant to ISO Procedures.

Proxy Generator Bus Border LBMP: The LBMP at a Proxy Generator Bus minus External Interface Congestion at that Proxy Generator Bus.

Unconstrained RTD LBMP: The LBMP as calculated by RTD less any congestion associated with a Proxy Generator Bus Constraint.

17.1.6.2 General Rules

Transmission Customers and Customers with External Generators and Loads can bid into the LBMP Market or participate in Bilateral Transactions. Those with External Generators may arrange LBMP Market sales and/or Bilateral Transactions with Internal or External Loads and External Loads may arrange LBMP Market purchases and/or Bilateral Transactions with Internal Generators.

The Generator and Load locations for which LBMPs will be calculated will initially be limited to a pre-defined set of Proxy Generator Buses. LBMPs will be calculated for each Proxy

Generator Bus within this limited set. When an Interface with multiple Proxy Generator Buses is constrained, the ISO will apply the constraint to all of the Proxy Generator Buses located at that Interface. Except as set forth in Sections 17.1.6.3 and 17.1.6.4, the NYISO will calculate the three components of LBMP for Transactions at a Proxy Generator Bus as provided in the tables below.

When determining the External Interface Congestion, if any, to apply to determine the LBMP for RTD intervals that bridge two RTC intervals, the NYISO shall use the External Interface Congestion associated with the second (later) RTC interval.

17.1.6.2.1 Pricing rules for Dynamically Scheduled Proxy Generator Buses

The pricing rules for Dynamically Scheduled Proxy Generator Buses are to be determined.

17.1.6.2.2 Pricing rules for Variably Scheduled Proxy Generator Buses

The pricing rules for Variably Scheduled Proxy Generator Buses are provided in the following table.

| Rule No. | Proxy Generator Bus Constraint affecting External Schedules at location <i>a</i> | Direction of Proxy Generator Bus Constraint | Real-Time Pricing Rule (for location <i>a</i>) |
|-----------------|---|--|---|
| 1 | Unconstrained in RTC ₁₅ , Rolling RTC and RTD | N/A | Real-Time LBMP _{<i>a</i>} = RTD LBMP _{<i>a</i>} |
| 2 | The Rolling RTC used to schedule External Transactions in a given 15-minute interval is subject to a Proxy Generator Bus Constraint | Into NYCA or out of NYCA (Import or Export) | Real-Time LBMP _{<i>a</i>} = RTD LBMP _{<i>a</i>} + Rolling RTC External Interface Congestion _{<i>a</i>} |

17.1.6.2.3 Pricing rules for Proxy Generator Buses that are not Dynamically Scheduled or Variably Scheduled

The pricing rules for Proxy Generator Buses that are not Dynamically Scheduled or Variably Scheduled Proxy Generator Buses are provided in the following table.

| Rule No. | Proxy Generator Bus Constraint affecting External Schedules at location a | Direction of Proxy Generator Bus Constraint | Real-Time Pricing Rule (for location a) |
|----------|---|---|---|
| 1 | Unconstrained in RTC ₁₅ , Rolling RTC and RTD | N/A | Real-Time LBMP _{a} = RTD LBMP _{a} |
| 3 | RTC ₁₅ is subject to a Proxy Generator Bus Constraint | Into NYCA or out of NYCA (Import or Export) | Real-Time LBMP _{a} = RTD LBMP _{a} + RTC ₁₅ External Interface Congestion _{a} |

17.1.6.3 Rules for Non-Competitive Proxy Generator Buses and Associated Interfaces

Real-Time LBMPs for an Interface that is associated with one or more Non-Competitive Proxy Generator Buses or for a Non-Competitive Proxy Generator Bus shall be determined as provided in the tables below. Non-Competitive Proxy Generator Buses are identified in Section 4.4.4 of the Services Tariff.

17.1.6.3.1 Pricing rules for Non-Competitive, Dynamically Scheduled Proxy Generator Buses

The pricing rules for Non-Competitive, Dynamically Scheduled Proxy Generator Buses are to be determined.

17.1.6.3.2 Pricing rules for Non-Competitive, Variably Scheduled Proxy Generator Buses

The pricing rules for Non-Competitive, Variably Scheduled Proxy Generator Buses are provided in the following table.

| Rule No. | Proxy Generator Bus Constraint affecting External Schedules at location <i>a</i> | Direction of Proxy Generator Bus Constraint | Real-Time Pricing Rule (for location <i>a</i>) |
|-----------------|---|--|--|
| 1 | Unconstrained in RTC ₁₅ , Rolling RTC and RTD | N/A | Real-Time LBMP _{<i>a</i>} = RTD LBMP _{<i>a</i>} |
| 4 | The Rolling RTC used to schedule External Transactions in a given 15-minute interval is subject to an Interface ATC* or Interface RampConstraint | Into NYCA (Import) | <p>If Rolling RTC Proxy Generator Bus LBMP_{<i>a</i>} > 0, then Real-Time LBMP_{<i>a</i>} = RTD LBMP_{<i>a</i>} + Rolling RTC External Interface Congestion_{<i>a</i>}</p> <p>Otherwise, Real-Time LBMP_{<i>a</i>} = Minimum of (i) RTD LBMP_{<i>a</i>} and (ii) zero</p> |
| 5 | The Rolling RTC used to schedule External Transactions in a given 15-minute interval is subject to an Interface ATC* or Interface Ramp Constraint | Out of NYCA (Export) | <p>If Rolling RTC Proxy Generator Bus LBMP_{<i>a</i>} < 0, then Real-Time LBMP_{<i>a</i>} = RTD LBMP_{<i>a</i>} + Rolling RTC External Interface Congestion_{<i>a</i>}</p> <p>Otherwise, Real-Time LBMP_{<i>a</i>} = RTD LBMP_{<i>a</i>}</p> |

* However, no congestion costs due to Interface ATC Constraints shall be included for the Champlain Hudson Power Express MTF.

17.1.6.3.3 Pricing rules for Non-Competitive Proxy Generator Buses that are not Dynamically Scheduled or Variably Scheduled Proxy Generator Buses

The pricing rules for Non-Competitive Proxy Generator Buses that are not Dynamically Scheduled or Variably Scheduled Proxy Generator Buses are provided in the following table.

| Rule No. | Proxy Generator Bus Constraint affecting External Schedules at location <i>a</i> | Direction of Proxy Generator Bus Constraint | Real-Time Pricing Rule (for location <i>a</i>) |
|----------|--|---|--|
| 1 | Unconstrained in RTC ₁₅ , Rolling RTC and RTD | N/A | Real-Time LBMP _{<i>a</i>} = RTD LBMP _{<i>a</i>} |
| 6 | RTC ₁₅ is subject to an Interface ATC or Interface Ramp Constraint | Into NYCA (Import) | If RTC ₁₅ Proxy Generator Bus LBMP _{<i>a</i>} > 0, then Real-Time LBMP _{<i>a</i>} = RTD LBMP _{<i>a</i>} + RTC ₁₅ External Interface Congestion _{<i>a</i>} Otherwise, Real-Time LBMP _{<i>a</i>} = Minimum of (i) RTD LBMP _{<i>a</i>} and (ii) zero |
| 7 | RTC ₁₅ is subject to an Interface ATC or Interface Ramp Constraint | Out of NYCA (Export) | If RTC ₁₅ Proxy Generator Bus LBMP _{<i>a</i>} < 0, then Real-Time LBMP _{<i>a</i>} = RTD LBMP _{<i>a</i>} + RTC ₁₅ External Interface Congestion _{<i>a</i>} Otherwise, Real-Time LBMP _{<i>a</i>} = RTD LBMP _{<i>a</i>} |

17.1.6.4 Special Pricing Rules for Proxy Generator Buses Associated with Designated Scheduled Lines

Real-Time LBMPs for the Proxy Generator Buses associated with designated Scheduled Lines shall be determined as provided in the tables below. The Proxy Generator Buses that are associated with designated Scheduled Lines are identified in Section 4.4.4 of the Services Tariff.

17.1.6.4.1 Pricing rules for Dynamically Scheduled Proxy Generator Buses that are associated with Designated Scheduled Lines

The pricing rules for Dynamically Scheduled Proxy Generator Buses that are associated with designated Scheduled Lines are to be determined.

17.1.6.4.2 Pricing rules for Variably Scheduled Proxy Generator Buses that are associated with Designated Scheduled Lines

The pricing rules for Variably Scheduled Proxy Generator Buses that are associated with designated Scheduled Lines are provided in the following table.

| Rule No. | Proxy Generator Bus Constraint affecting External Schedules at location <i>a</i> | Direction of Proxy Generator Bus Constraint | Real-Time Pricing Rule (for location <i>a</i>) |
|----------|--|---|--|
| 1 | Unconstrained in RTC_{15} , Rolling RTC and RTD | N/A | Real-Time $LBMP_a = RTD\ LBMP_a$ |
| 4 | The Rolling RTC used to schedule External Transactions in a given 15-minute interval is subject to an Interface ATC Constraint | Into NYCA (Import) | If Rolling RTC Proxy Generator Bus $LBMP_a > 0$, then Real-Time $LBMP_a = RTD\ LBMP_a + \text{Rolling RTC External Interface Congestion}_a$ Otherwise, Real-Time $LBMP_a = \text{Minimum of (i) } RTD\ LBMP_a \text{ and (ii) zero}$ |
| 5 | The Rolling RTC used to schedule External Transactions in a given 15-minute interval is subject to an Interface ATC Constraint | Out of NYCA (Export) | If Rolling RTC Proxy Generator Bus $LBMP_a < 0$, then Real-Time $LBMP_a = RTD\ LBMP_a + \text{Rolling RTC External Interface Congestion}_a$ Otherwise, Real-Time $LBMP_a = RTD\ LBMP_a$ |

17.1.6.4.3 Pricing rules for Proxy Generator Buses that are associated with Designated Scheduled Lines that are not Dynamically Scheduled or Variably Scheduled Proxy Generator Buses

The pricing rules for Proxy Generator Buses that are associated with designated Scheduled Lines that are not Dynamically Scheduled or Variably Scheduled Proxy Generator Buses, are provided in the following table.

| Rule No. | Proxy Generator Bus Constraint affecting External Schedules at location <i>a</i> | Direction of Proxy Generator Bus Constraint | Real-Time Pricing Rule (for location <i>a</i>) |
|----------|--|---|---|
| 1 | Unconstrained in RTC_{15} , Rolling RTC and RTD | N/A | Real-Time $LBMP_a = RTD\ LBMP_a$ |
| 6 | RTC_{15} is subject to an Interface ATC Constraint | Into NYCA (Import) | If RTC_{15} Proxy Generator Bus $LBMP_a > 0$, then Real-Time $LBMP_a = RTD\ LBMP_a + RTC_{15}\ \text{External Interface Congestion}_a$ Otherwise, Real-Time $LBMP_a = \text{Minimum of (i) } RTD\ LBMP_a \text{ and (ii) zero}$ |

| Rule No. | Proxy Generator Bus Constraint affecting External Schedules at location <i>a</i> | Direction of Proxy Generator Bus Constraint | Real-Time Pricing Rule (for location <i>a</i>) |
|----------|--|---|---|
| 7 | RTC ₁₅ is subject to an Interface ATC Constraint | Out of NYCA (Export) | <p>If RTC₁₅ Proxy Generator Bus LBMP_a < 0, then Real-Time LBMP_a = RTD LBMP_a + RTC₁₅ External Interface Congestion_a</p> <p>Otherwise, Real-Time LBMP_a = RTD LBMP_a</p> |

17.1.6.5 Method of Calculating Marginal Loss and Congestion Components of Real-Time LBMP at Non-Competitive Proxy Generator Buses and Proxy Generator Buses that are Subject to the Special Pricing Rule for Designated Scheduled Lines

Under the conditions specified below, the Marginal Losses Component and the Congestion Component of the Real-Time LBMP, calculated pursuant to the preceding paragraphs in Sections 17.1.6.3 and 17.1.6.4, shall be constructed as follows:

When the Real-Time LBMP is set to zero and that zero price was not the result of using the RTD, RTC or SCUC-determined LBMP;

$$\text{Marginal Losses Component of the Real-Time LBMP} = \text{Losses}_{\text{RTD PROXY GENERATOR BUS}}$$

and

$$\text{Congestion Component of the Real-Time LBMP} = -(\text{Energy}_{\text{RTD REF BUS}} + \text{Losses}_{\text{RTD PROXY GENERATOR BUS}})$$

where:

$\text{Energy}_{\text{RTD REF BUS}}$ = The marginal Bid cost of providing Energy at the reference Bus, as calculated by RTD for that 5-minute interval; and

$\text{Losses}_{\text{RTD PROXY GENERATOR BUS}}$ = The Marginal Losses Component of the LBMP as calculated by RTD for that 5-minute interval at the Non-Competitive Proxy Generator Bus or Proxy Generator Bus associated with a designated Scheduled Line.