

August 1, 2016

Hon. Kimberly Bose
Secretary
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426

Dear Secretary Bose:

Pursuant to Section 2.13 of its Open Access Transmission Tariff (“OATT”), the New York Independent System Operator, Inc. (“NYISO”) hereby notifies the Commission that an “Emergency State” existed in the New York Control Area on July 30, 2016 at 08:26. As a result, the NYISO was required to take special action to ensure that the reliability of the New York State Transmission System was not adversely affected. The NYISO has enclosed documentation describing the Emergency State and its actions. As required by Section 2.13 of the OATT, the NYISO has also notified the New York State Public Service Commission of the Emergency State and its actions.

Please feel free to contact me at (518) 356-6159 if you have any questions or comments.

Sincerely,

/s/ Gregory Campoli

Gregory Campoli
Manager, Reliability, Compliance & Industry Affairs
New York Independent System Operator

Enclosure

Cc: Wes Yeomans
Ray Stalter
Chris Sharp

NYISO Major Emergency Report

At 08:26 on 07/30/2016 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East L/O NE GEN exceeded its Voltage Transfer Limit by more than 105%

This was caused by: trip of the Gilboa-Fraser (GF5-35) 345kV line

To correct this the NYISO Curtailed transactions, started and redispatched generation, and Shift Supervisor: moved Phase Angle Regulators (PAR) to reduce flow.

Load relief was not required.

The Major Emergency was terminated at 08:32 on 07/30/2016