

November 7, 2019

Hon. Kimberly Bose
Secretary
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426

**Re: New York Independent System Operator, Inc., Notification of Major Emergency
in the New York Control Area; Docket No. EY20-__-000**

Dear Secretary Bose:

Pursuant to Section 2.13 of its Open Access Transmission Tariff (“OATT”), the New York Independent System Operator, Inc. (“NYISO”) hereby notifies the Commission that an “Emergency State” existed in the New York Control Area on November 7, 2019 at 00:04. As a result, the NYISO was required to take special action to ensure that the reliability of the New York State Transmission System was not adversely affected. The NYISO has enclosed documentation describing the Emergency State and its actions. As required by Section 2.13 of the OATT, the NYISO has also notified the New York State Public Service Commission of the Emergency State and its actions.

Please feel free to contact me at (518) 356-6159 if you have any questions or comments.

Sincerely,

/s/ Gregory Campoli

Gregory Campoli
Manager, Reliability, Compliance & Industry Affairs
New York Independent System Operator

Enclosure

Cc: Wes Yeomans
Ray Stalter
Chris Sharp

NYISO Major Emergency Report

At 0004 on 11/07/2019 a Major Emergency was declared by the NYISO Shift Supervisor

when the power flow on Central East VC
exceeded its Voltage Transfer Limit by
more than 105%

This was caused by: Energy flows into ISO-NE exceeded scheduled amounts.

To correct this the
NYISO Shift
Supervisor:

Requested ISO-NE reduce flows to scheduled amounts, moved Phase
Angle Regulators (PARs) to reduce flows and placed a capacitor in
service to increase the limit.

Load relief was not required.

The Major Emergency was terminated at 0006 on 11/07/2019