

April 5, 2017

Hon. Kimberly Bose  
Secretary  
Federal Energy Regulatory Commission  
888 First Street, N.E.  
Washington, D.C. 20426

Dear Secretary Bose:

Pursuant to Section 2.13 of its Open Access Transmission Tariff (“OATT”), the New York Independent System Operator, Inc. (“NYISO”) hereby notifies the Commission that an “Emergency State” existed in the New York Control Area on April 4, 2017 at 20:59. As a result, the NYISO was required to take special action to ensure that the reliability of the New York State Transmission System was not adversely affected. The NYISO has enclosed documentation describing the Emergency State and its actions. As required by Section 2.13 of the OATT, the NYISO has also notified the New York State Public Service Commission of the Emergency State and its actions.

Please feel free to contact me at (518) 356-6159 if you have any questions or comments.

Sincerely,

*/s/ Gregory Campoli*

Gregory Campoli  
Manager, Reliability, Compliance & Industry Affairs  
New York Independent System Operator

Enclosure  
Cc: Wes Yeomans  
Ray Stalter  
Chris Sharp

# NYISO Major Emergency Report

At 2059 on 04/04/2017	a Major Emergency was declared by the NYISO Shift Supervisor
	when the power flow on Central East VC exceeded its Voltage Transfer Limit by more than 105%
This was caused by:	the loss of 1250MW of generation in ISONE
To correct this the NYISO Shift Supervisor:	Curtailed transactions, started and redispatched generation, and placed capacitors in service.

Load relief was not required.

The Major Emergency was terminated at 2106 on 04/04/2017