

NYISO Major Emergency Report

At 1719 on 05/21/2017 a Major Emergency was declared by the NYISO Shift Supervisor when the power flow on Central East VC exceeded its Transient Stability Limit by more than 105%

This was caused by: Loss of Phase 2 loaded at 1000MW

To correct this the NYISO Shift Supervisor: Curtailed transactions, placed capacitors in service, moved Phase Angle Regulators (PAR) to reduce flow, and redispatched generation.

Load relief was not required.

The Major Emergency was terminated at 1725 on 05/21/2017