



ORIGINAL

EY13-2-005

3890 Carman Road • Schenectady, NY 12303

November 28, 2012

FILED
SECRETARY OF THE
COMMISSION

2012 DEC -4 A 9 23

FEDERAL ENERGY
REGULATORY COMMISSION

Hon. Kimberly Bose
Secretary
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426

Dear Secretary Bose:

Pursuant to Section 10.B.0 of its Open Access Transmission Tariff ("OATT"), the New York Independent System Operator, Inc. ("NYISO") hereby notifies the Commission that an "Emergency State" existed in the New York Control Area on November 28, 2012. As a result, the NYISO was required to take special action to ensure that the reliability of the New York State Transmission System was not adversely affected. The NYISO has enclosed documentation describing the Emergency State and its actions. As required by Section 10.B.0 of the OATT, the NYISO has also notified the New York State Public Service Commission of the Emergency State and its actions.

Please feel free to contact me at (518) 356-6159 if you have any questions or comments.

Sincerely,

A handwritten signature in black ink, appearing to read "John Ravalli".

John Ravalli
Manager, Operations
New York Independent System Operator

Enclosure

NYISO Major Emergency Report

**At 13:40 on
11/28/2012**

**a Major Emergency was declared by the NYISO Shift Supervisor
when the power flow on Central East VC
exceeded its Voltage Transfer Limit
by more than 105%**

This was caused by:

Fitzpatrick AVR was forced out of service.

**To correct this the
NYISO Shift
Supervisor:**

**Curtailed imports from Hydro Quebec. Adjusted NYCA
generation reducing Central East flows. Adjusted phase angle regulators
on L33P Moses-St.Lawrence.**

Load relief was not required.

The Major Emergency was terminated at 13:47 on 11/28/2012

Document Content(s)

13124785.tif.....1-2