

# NYISO Major Emergency Report

At 16:17 on 10/13/2019

a Major Emergency was declared by the NYISO Shift Supervisor

when the power flow on HQ Cedars exceeded its Transient Stability Limit by more than 105%

This was caused by:

Resources producing above schedule

To correct this the NYISO Shift Supervisor:

Directed resources to return to schedule

Load relief was not required.

The Major Emergency was terminated at 16:20 on 10/13/2019