

Attachment I

4.2 Day-Ahead Markets and Schedules

4.2.1 Day-Ahead Load Forecasts, Bids and Bilateral Schedules

4.2.1.1 General Customer Forecasting and Bidding Requirements

Subject to the two earlier submission deadlines set forth below, by 5 a.m. on the day prior to the Dispatch Day: (i) All LSEs serving Load in the NYCA shall provide the ISO with Load forecasts for the Dispatch Day and the day after the Dispatch Day; and (ii) Customers and Transmission Customers submitting Bids in the Day-Ahead Market shall provide the ISO, consistent with ISO Procedures:

- a. Bids to supply Energy, including Bids to supply Energy in Virtual Transactions;
- b. Bids to supply Ancillary Services;
- c. Requests for Bilateral Transaction schedules;
- d. Bids to purchase Energy, including Bids to purchase Energy in Virtual Transactions and Bids to withdraw Energy by Withdrawal-Eligible Generators;
- e. Demand Reduction Bids; and
- f. For Behind-the-Meter Net Generation Resources, the forecasted Host Load for each hour of the Dispatch Day.

By 4:50 a.m. on the day prior to the Dispatch Day, all Customers or Transmission Customers shall submit Bids for External Transactions at the Proxy Generator Bus associated with the Cross-Sound Scheduled Line, the Neptune Scheduled Line, the Linden VFT Scheduled Line, or the HTP Scheduled Line.

By 4:45 a.m. on the day prior to the Dispatch Day, all Customers or Transmission Customers shall submit Bids that include revised fuel type or fuel price information to the ISO's Market Information System.

In general, the information provided to the ISO shall include the following:

4.2.1.2 Load Forecasts

The Load forecast shall indicate the predicted level of Load in MW by Point of Withdrawal for each hour.

4.2.1.3 Bids by Suppliers Using the ISO-Committed Flexible, Self-Committed Flexible or ISO-Committed Fixed Bid Modes to Supply Energy and/or Ancillary Services

4.2.1.3.1 General Rules

Day-Ahead Bids by Suppliers using the ISO-Committed Flexible, Self-Committed Flexible or ISO-Committed Fixed bid modes shall identify the Capacity, in MW, available for commitment in the Day-Ahead Market (for every hour of the Dispatch Day) and the price(s) at which the Supplier will voluntarily enter into dispatch commitments. If the Supplier elects to participate in the Day-Ahead Market, and is within a defined electrical boundary, electrically interconnected with, and routinely serves a Host Load (which Host Load does not consist solely of Station Power) at a single PTID, it can only participate in the Day-Ahead Market as a Behind-the-Meter Net Generation Resource. If the Supplier is a Behind-the-Meter Net Generation Resource, the ISO shall only consider price-MW pairs in excess of the forecasted Host Load for the Resource.

A Supplier's Day-Ahead Bids for an Energy Storage Resource to withdraw Energy and to inject Energy shall be submitted as a single, continuous, bid curve representing the Capacity, in MW, available for commitment in the Day-Ahead Market for each hour of the Dispatch Day, and shall indicate whether the Resource's Energy Level will be ISO- or Self-Managed. An Energy Storage Resource may not change its Energy Level Management election within the Day-Ahead Market evaluation period (*i.e.*, within a single day).

If the Supplier using the ISO-Committed Flexible or Self-Committed Flexible bid mode is eligible to provide Regulation Service or Operating Reserves under Rate Schedules 3 and 4 respectively of this ISO Services Tariff, the Supplier's Bid may specify the quantity of Regulation Capacity it is making available and shall specify an emergency response rate that determines the quantity of Operating Reserves that it is capable of providing. Offers to provide Regulation Service and Operating Reserves must comply with the rules set forth in Rate Schedules 3 and 4 of this ISO Services Tariff. If a Supplier that is eligible to provide Operating Reserves does not submit a Day-Ahead Availability Bid for Operating Reserves, its Day-Ahead Bid shall be rejected in its entirety. A Behind-the-Meter Net Generation Resource that is comprised of more than one generating unit that is dispatched as a single aggregate unit at a single PTID is not qualified to provide Regulation Service or Spinning Reserves. A Supplier may resubmit a complete Day-Ahead Bid, provided that the new Bid is timely. See Section 4.2.1.9 for bidding requirements for Demand Side Resources offering Energy in the Day-Ahead Market.

Suppliers other than Demand Side Resources entering a Bid into the Day-Ahead Market may also enter Day-Ahead Bids for each of the next nine (9) Dispatch Days. If not subsequently modified or withdrawn, these offers for subsequent Dispatch Days may be used by the ISO as offers from these Suppliers in the Day-Ahead Market for these subsequent Dispatch Days. For Suppliers that are providing Unforced Capacity in the ISO-administered ICAP Market for the month in which the Dispatch Day and the nine-day advance bidding period are encompassed, the ISO may enter the eighth day offer as the Bid for that Supplier's ninth day, if there is, otherwise no ninth-day Bid.

4.2.1.3.2 Bid Parameters

Day-Ahead Bids by Suppliers using the ISO-Committed Flexible, Self-Committed Flexible or ISO-Committed Fixed bid modes may identify-variable Energy price Bids, consisting of up to eleven monotonically increasing, constant cost incremental Energy steps, and other parameters described in ISO Procedures. Day-Ahead Bids from Demand Side Resources offering Operating Reserves or Regulation Service shall be ISO-Committed Flexible and shall have an Energy Bid price no lower than the Monthly Net Benefit Offer Floor. Day-Ahead offers by Intermittent Power Resources that depend on wind as their fuel shall be ISO-Committed Flexible and shall include a Minimum Generation Bid of zero megawatts and zero costs and a Start-Up Bid of zero cost.

Day-Ahead Bids by ISO-Committed Fixed and ISO-Committed Flexible Generators, other than bids from Intermittent Power Resources that depend on wind as their fuel, shall also include Minimum Generation Bids and hourly Start-Up Bids. Bids shall specify whether a Supplier is offering to be ISO-Committed Fixed, ISO-Committed Flexible, Self-Committed Fixed, or Self-Committed Flexible.

4.2.1.3.3 Upper Operating Limits, Lower Operating Limits, and Response Rates

All Bids to supply Energy and Ancillary Services must specify a UOL_N and a UOL_E for each hour. A Resource's UOL_E may not be lower than its UOL_N . Bids from Withdrawal-Eligible Generators shall also specify the Generator's Lower Operating Limit for each hour.

Bids from Suppliers for Generators supplying Energy and Ancillary Services must specify a normal response rate and may provide up to three normal response rates provided the minimum normal response rate may be no less than one percent (1%) of the Generator's Operating Capacity per minute. All Bids from Suppliers for Generators supplying Energy and

Ancillary Services must also specify an emergency response rate which shall be equal to or greater than the maximum normal response rate of the Generator.

Bids from Suppliers offering Operating Reserves or Regulation Service from Demand Side Resources must specify a normal response rate and an emergency response rate provided that the emergency response rate may not be lower than the normal response rate. For Demand Side Resources the minimum acceptable response rate is one percent (1%) of the quantity of Demand Reduction the Demand Side Resource produces per minute.

4.2.1.3.4 Additional Parameters for Energy Storage Resources

In addition to the parameters that Suppliers submit for Energy Storage Resources because they are Generators, specific parameters may apply to some Bids for Energy Storage Resources. Consistent with the ISO Procedures, Bids from Suppliers for Energy Storage Resources supplying Energy and Ancillary Services may be required to specify the Beginning Energy Level and the Energy Storage Resource's Roundtrip Efficiency, and must specify its Upper and Lower Storage Limits. The Energy Level for an Energy Storage Resource shall be managed by the Supplier unless the Supplier elects, in its Bids, to be ISO-Managed.

The Day-Ahead Schedule for Energy Storage Resources with ISO-Managed Energy Levels will reflect the Resource's Energy Level constraints, including the Beginning Energy Level, the Upper and Lower Storage Limits, and the Resource's Roundtrip Efficiency. An Energy Storage Resource that self-manages its Energy Level is obligated to submit Bids that are consistent with its Energy Level constraints, and the Day-Ahead optimization will not honor the above-identified Energy Level constraints.

4.2.1.4 Offers to Supply Energy from Self-Committed Fixed Generators

Self-Committed Fixed Generators shall provide the ISO with a schedule of their expected Energy output and withdrawals (when applicable) for each hour. Self-Committed Fixed Generators are responsible for ensuring that any hourly changes in output are consistent with their response rates. Self-Committed Fixed Generators shall also submit UOL_{NS}, UOL_{ES} and variable Energy Bids for possible use by the ISO in the event that RTD-CAM initiates a maximum generation pickup, as described in Section 4.4.3 of this ISO Services Tariff.

4.2.1.5 Bids to Supply Energy in Virtual Transactions

Customers submitting Bids to supply Energy in Virtual Transactions shall identify the Energy, in MW, available in the Day-Ahead Market (for every hour of the Dispatch Day) and the price(s) at which the Customer will voluntarily make it available.

4.2.1.6 Bids to Purchase Energy in Virtual Transactions

Customers submitting bids to purchase Energy in Virtual Transactions shall identify the Energy, in MW, to be purchased in the Day-Ahead Market (for every hour of the Dispatch Day) and the price(s) at which the Customer will voluntarily purchase it.

4.2.1.7 Bilateral Transactions

Transmission Customers requesting Bilateral Transaction schedules shall identify hourly Transaction quantities (in MW) by Point of Injection and Point of Withdrawal, minimum run times associated with Firm Point-to-Point Transmission Service, if any, and shall provide other information (as described in ISO Procedures).

4.2.1.8 Bids to Purchase LBMP Energy in the Day-Ahead Market

Each purchaser shall submit Bids indicating the hourly quantity of Energy, in MW, that it will purchase from the Day-Ahead Market for each hour of the following Dispatch Day. These Bids shall indicate the quantities to be purchased by Point of Withdrawal. The Bids may identify prices at which the purchaser will voluntarily enter into the Transaction.

4.2.1.9 Day-Ahead Bids from Demand Reduction Providers and DSASP Providers to Supply Energy from Demand Reductions

Demand Reduction Providers and DSASP Providers offering Energy from Demand Side Resources shall submit Bids: (i) identifying the amount of Demand Reduction, in MWs in accordance with Section 4.1.4, that is available for commitment in the Day-Ahead Market (for every hour of the dispatch day) and (ii) identifying the prices at which the Demand Reduction Provider or DSASP Provider will voluntarily enter into dispatch commitments to reduce demand; provided, however, the price at which the Demand Reduction Provider or DSASP Provider will voluntarily enter into dispatch commitments to reduce demand shall be no lower than the Monthly Net Benefit Offer Floor, as determined in accordance with this section. The Bids will identify the minimum period of time that the Demand Reduction Provider or DSASP Provider is willing to reduce demand, however the minimum period may not be less than one hour. The Bid may separately identify the Demand Reduction Provider's Curtailment Initiation Cost. Demand Reduction Bids from Demand Reduction Providers that are not accepted in the Day-Ahead Market shall expire at the close of the Day-Ahead Market.

The ISO shall perform the Net Benefits Test and post on its web site the Monthly Net Benefit Offer Floor for each month by the 15th of the preceding month in accordance with ISO Procedures. The Net Benefits Test shall establish the threshold price below which the dispatch of Energy from Demand Side Resources is not cost-effective. The Net Benefits Test shall

consist of the following steps: (1) the ISO shall compile hourly supply curves for the Reference Month; (2) the ISO shall develop the average supply curve for the Study Month by updating the Reference Month supply curves for retirements and new entrants, and adjusting offers for changes in fuel prices; (3) the ISO shall apply an appropriate mathematical formula to smooth the average supply curve; and (4) the ISO shall evaluate the smoothed average supply curve to determine the Monthly Net Benefit Floor for the Study Month. The ISO shall apply the Monthly Net Benefit Offer Floor, as so calculated, to Bids submitted by Demand Response Providers for all hours in the Study Month.

The ISO shall promptly post corrections, where necessary, to the Monthly Net Benefit Offer Floor. Corrections shall only apply to errors in conducting the calculations described above and/or in posting the properly calculated Monthly Net Benefit Offer Floor. Corrections shall not include recalculations based on changes in gas prices as set forth above. The ISO shall not use any correction to the Monthly Net Benefit Offer Floor to determine revised Day-Ahead Market clearing prices for periods prior to the imposition of the correction.

4.2.2 ISO Responsibility to Establish a Statewide Load Forecast

By 8 a.m., or as soon thereafter as is reasonably possible, the ISO will develop and publish its statewide Load forecast on the OASIS. The ISO will use this forecast to perform the SCUC for the Dispatch Day.

4.2.3 Security Constrained Unit Commitment (“SCUC”)

Subject to ISO Procedures and Good Utility Practice, the ISO will develop a SCUC schedule over the Dispatch Day using a computer algorithm which simultaneously minimizes the total Bid Production Cost of: (i) supplying power or Demand Reductions to satisfy accepted purchasers’ Bids to buy Energy from the Day-Ahead Market; (ii) providing sufficient Ancillary

Services to support Energy purchased from the Day-Ahead Market consistent with the Regulation Service Demand curve and Operating Reserve Demand Curves set forth in Rate Schedules 3 and 4 respectively of this ISO Services Tariff; (iii) committing sufficient Capacity to meet the ISO's Load forecast and provide associated Ancillary Services; and (iv) meeting Bilateral Transaction schedules submitted Day-Ahead excluding schedules of Bilateral Transactions with Trading Hubs as their POWs. The computer algorithm shall consider whether accepting Demand Reduction Bids will reduce the total Bid Production Cost.

The ISO shall compute all NYCA Interface Transfer Capabilities prior to scheduling Transmission Service Day-Ahead. The ISO shall run the SCUC utilizing the computed Transfer Capabilities, submitted Firm Point-to-Point Transmission Service requests, Load forecasts, and submitted Incremental Energy Bids, Decremental Bids and Sink Price Cap Bids.

The schedule will include commitment of sufficient Generators and/or Demand Side Resources to provide for the safe and reliable operation of the NYS Power System. SCUC will treat a Behind-the-Meter Net Generation Resources and Energy Storage Resources as already being committed and available to be scheduled. Pursuant to ISO Procedures, the ISO may schedule any Resource to run above its UOL_N up to the level of its UOL_E . In cases in which the sum of all Bilateral Schedules, excluding Bilateral Schedules for Transactions with Trading Hubs as their POWs, and all Day-Ahead Market purchases to serve Load within the NYCA in the Day-Ahead schedule is less than the ISO's Day-Ahead forecast of Load, the ISO will commit Resources in addition to the Operating Reserves it normally maintains to enable it to respond to contingencies. The purpose of these additional resources is to ensure that sufficient Capacity is available to the ISO in real-time to enable it to meet its Load forecast (including associated Ancillary Services). In considering which additional Resources to schedule to meet the ISO's

Load forecast, the ISO will evaluate unscheduled Imports, and will not schedule those Transactions if its evaluation determines the cost of those Transactions would effectively exceed a Bid Price cap in the hours in which the Energy provided by those Transactions is required. In addition to all Reliability Rules, the ISO shall consider the following information when developing the SCUC schedule: (i) Load forecasts; (ii) Ancillary Service requirements as determined by the ISO given the Regulation Service Demand Curve and Operating Reserve Demand Curves referenced above; (iii) Bilateral Transaction schedules excluding Bilateral Schedules for Transactions with Trading Hubs as their POWs; (iv) price Bids and operating Constraints submitted for Generators or for Demand Side Resources; (v) price Bids for Ancillary Services; (vi) Decremental Bids and Sink Price Cap Bids for External Transactions; and (vii) Bids to purchase or sell Energy from or to the Day-Ahead Market. External Transactions with minimum run times greater than one hour will only be scheduled at the requested Bid for the full minimum run time. External Transactions with identical Bids and minimum run times greater than one hour will not be prorated. The SCUC schedule shall list the hourly injections and withdrawals for: (a) each Customer whose Bid the ISO accepts for the Dispatch Day; and (b) each Bilateral Transaction scheduled Day-Ahead excluding Bilateral Transactions with Trading Hubs as their POWs.

In the development of its SCUC schedule, the ISO may commit and de-commit Generators and Demand Side Resources, based upon any flexible Bids, including Minimum Generation Bids, Start-Up Bids, Curtailment Initiation Cost Bids, Energy, and Incremental Energy Bids and Decremental Bids received by the ISO provided however that: (a) the ISO shall commit zero megawatts of Energy for Demand Side Resources committed to provide Operating Reserves and Regulation Service; and (b) for Behind-the-Meter Net Generation Resources, the

ISO will consider for dispatch only those segments of the Resource's Incremental Energy Bids above the forecasted Host Load and subject to the Injection Limit.

The ISO may disable the ISO-Managed Energy Level bid parameter that is ordinarily available to Energy Storage Resources if it determines that there is a significant risk that including the ISO-Managed Energy Level bid parameter in the SCUC evaluation could delay the completion and posting of the Day-Ahead Market beyond the 11:00 a.m. deadline specified in Section 4.2.5 of this Services Tariff. The ISO shall post a notice to its public website by 4:00 p.m. on the day before the Day-Ahead Market closes if it decides to disable the ISO-Managed Energy Level bid parameter. The ISO-Managed Energy Level bid parameter shall remain disabled until the ISO posts a notice that complies with the notice requirement specified above reinstating the bid parameter's availability.

When the ISO-Managed Energy Level bid parameter is disabled, Bids that utilized the ISO-Managed Energy Level functionality that were submitted prior to the issuance of the ISO's notice will be rejected. The ISO will inform affected Suppliers, so that the Suppliers will have the opportunity to resubmit their Day-Ahead Market Bids using Self-Managed Energy Levels prior to the deadlines specified in Section 4.2.1.1 of the Services Tariff. Bids that utilize ISO-Managed Energy Levels will continue to be rejected until the ISO reinstates the ISO-Managed Energy Level bid parameter, following notice.

The ISO will select the least cost mix of Ancillary Services and Energy from Suppliers, Demand Side Resources, and Customers submitting Virtual Transactions bids. The ISO may substitute higher quality Ancillary Services (*i.e.*, shorter response time) for lower quality Ancillary Services when doing so would result in an overall least bid cost solution. For example, 10-Minute Non-Synchronized Reserve may be substituted for 30-Minute Reserve if doing so

would reduce the total bid cost of providing Energy and Ancillary Services.

4.2.3.1 Reliability Forecast for the Dispatch Day

At the request of a Transmission Owner to meet the reliability of its local system, the ISO may incorporate into the ISO's Security Constrained Unit Commitment constraints specified by the Transmission Owner.

A Transmission Owner may request commitment of certain Generators for a Dispatch Day if it determines that certain Generators are needed to meet the reliability of its local system. Such request shall be made before the Day-Ahead Market for that Dispatch Day has closed if the Transmission Owner knows of the need to commit certain Generators before the Day-Ahead Market close. The ISO may commit one or more Generator(s) in the Day-Ahead Market for a Dispatch Day if it determines that the Generator(s) are needed to meet NYCA reliability requirements.

A Transmission Owner may request commitment of additional Generators for a Dispatch Day following the close of the Day-Ahead Market to meet changed or local system conditions for the Dispatch Day that may cause the Day-Ahead schedules for the Dispatch Day to be inadequate to ensure the reliability of its local system. The ISO will use SRE to fulfill a Transmission Owner's request for additional units.

All Generator commitments made in the Day-Ahead Market pursuant to this Section 4.2.3.1 shall be posted on the ISO website following the close of the Day-Ahead Market, in accordance with ISO procedures. In addition, the ISO shall post on its website a non-binding, advisory notification of a request, or any modifications thereto, made pursuant to this Section 4.2.3.1 in the Day-Ahead Market by a Transmission Owner to commit a Generator that is located within a Constrained Area, as defined in Attachment H of this Services Tariff. The advisory

notification shall be provided upon receipt of the request and in accordance with ISO procedures. The postings described here may be included with the operator-initiated commitment report that the ISO posts in accordance with Section 4.1.3.4 of this Services Tariff.

After the Day-Ahead schedule is published, the ISO shall evaluate any events, including, but not limited to, the loss of significant Generators or transmission facilities that may cause the Day-Ahead schedules to be inadequate to meet the Load or reliability requirements for the Dispatch Day.

In order to meet Load or reliability requirements in response to such changed conditions the ISO may: (i) commit additional Resources, beyond those committed Day-Ahead, using a SRE and considering (a) Bids submitted to the ISO that were not previously accepted but were designated by the bidder as continuing to be available; or (b) new Bids from all Suppliers, including neighboring systems; or (ii) take the following actions: (a) after providing notice, require all Resources to run above their UOL_{NS}, up to the level of their UOL_{ES} (pursuant to ISO Procedures) and/or raise the UOL_{NS} of Capacity Limited Resources and Energy Limited Resources to their UOL_E levels, or (b) cancel or reschedule transmission facility maintenance outages when possible. Actions taken by the ISO in performing supplemental commitments will not change any financial commitments that resulted from the Day-Ahead Market.

4.2.4 Reliability Forecast for the Six Days Following the Dispatch Day

In the SCUC program, system operation shall be optimized based on Bids over the Dispatch Day. However, to preserve system reliability, the ISO must ensure that there will be sufficient resources available to meet forecasted Load and reserve requirements over the seven (7)-day period that begins with the next Dispatch Day. The ISO will perform a Supplemental Resource Evaluation (“SRE”) for days two (2) through seven (7) of the commitment cycle. If it

is determined that a long start-up time Generator (*i.e.*, a Generator that cannot be scheduled by SCUC to start up in time for the next Dispatch Day) is needed for reliability, the ISO shall accept a Bid from the Generator and the Generator will begin its start-up sequence. During each day of the start-up sequence, the ISO will perform an SRE to determine if long start-up time Generators will still be needed as previously forecasted. If at any time it is determined that the Generator will not be needed as previously forecasted, the ISO shall order the Generator to abort its start-up sequence.

The ISO will commit to long start-up time Generators to preserve reliability. However, the ISO will not commit resources with long start-up times to reduce the cost of meeting Loads that it expects to occur in days following the next Dispatch Day.

A Supplier that bids on behalf of a long start-up time Generator, including one that is committed and whose start is subsequently aborted by the ISO as described in this Section 4.2.4, may be eligible for a Bid Production Cost Guarantee pursuant to the provisions of Section 4.6.6 and Attachment C of this ISO Services Tariff. The costs of such a Bid Production Cost guarantee will be recovered by the ISO under Rate Schedule 1 of the ISO OATT.

The ISO shall perform the SRE as follows: (1) The ISO shall develop a forecast of daily system peak Load for days two (2) through seven (7) in this seven (7)-day period and add the appropriate reserve margin; (2) the ISO shall then forecast its available Generators for the day in question by summing the Operating Capacity for all Generators currently in operation that are available for the commitment cycle, the Operating Capacity of all other Generators capable of starting on subsequent days to be available on the day in question, and an estimate of the net Imports from External Bilateral Transactions; (3) if the forecasted peak Load plus reserves exceeds the ISO's forecast of available Generators for the day in question, then the ISO shall

commit additional Generators capable of starting prior to the day in question (*e.g.*, start-up period of two (2) days when looking at day three (3)) to assure system reliability; (4) in choosing among Generators with comparable start-up periods, the ISO shall schedule Generators to minimize Minimum Generation Bid and Start-Up Bid costs of meeting forecasted peak Load plus Ancillary Services consistent with the Reliability Rules; (5) in determining the appropriate reserve margin for days two (2) through seven (7), the ISO will supplement the normal reserve requirements to allow for forced outages of the short start-up period units (*e.g.*, gas turbines) assumed to be operating at maximum output in the unit commitment analysis for reliability.

Energy Bids are binding for day one (1) only for units in operation or with start-up periods less than one (1) day. Minimum Generation Bids for Generators with start-up periods greater than one (1) day will be binding only for units that are committed by the ISO and only for the first day in which those units could produce Energy given their start-up periods. For example, Minimum Generation Bids for a Generator with a start-up period of two (2) days would be binding only for day three (3) because, if that unit begins to start up at any time during day one (1), it would begin to produce Energy forty-eight (48) hours later on day three (3). Similarly, the Minimum Generation Bids for a Generator with a start-up period of three (3) days would be binding only for day four (4).

4.2.5 Post the Day-Ahead Schedule

By 11 a.m. on the day prior to the Dispatch Day, the ISO shall close the Day-Ahead scheduling process and post on the Bid/Post System the Day-Ahead schedule for each entity that submits a Bid or Bilateral Transaction schedule. All schedules shall be considered proprietary, with the posting only visible to the appropriate scheduling Customer and Transmission Owners subject to the applicable Code of Conduct (See Attachment F to the ISO OATT). The ISO will

post on the OASIS the statewide aggregate resources (Day-Ahead Energy schedules and total operating capability forecast), Day-Ahead scheduled Load, forecast Load for each Load Zone, and the Day-Ahead LBMP prices (including the Congestion Component and the Marginal Losses Component) for each Load Zone in each hour of the upcoming Dispatch Day. The ISO shall conduct the Day-Ahead Settlement based upon the Day-Ahead schedule determined in accordance with this section and Attachment B to this Services Tariff. The ISO will provide the Transmission Owner with the Load forecast (for seven (7) days) as well as the ISO security evaluation data to enable local area reliability to be assessed.

4.2.6 Day-Ahead LBMP Market Settlements

The ISO shall calculate the Day-Ahead LBMPs for each Load Zone and at each Generator bus and Demand Reduction Bus as described in Attachment B. Each Supplier that bids a Generator into the ISO Day-Ahead Market and is scheduled in the SCUC to sell or purchase Energy in the Day-Ahead Market will be settled at the product of: (a) the Day-Ahead hourly LBMP at the applicable Generator bus; and (b) the hourly Energy schedule. Each Supplier that bids an External Transaction into the Day-Ahead LBMP Market and is scheduled in the SCUC to sell Energy into the Day-Ahead LBMP Market will be settled at the product of (a) the Day-Ahead LBMP at the applicable Proxy Generator Bus and (b) the External Transaction schedule. For each Demand Reduction Provider that bids a Demand Reduction into the Day-Ahead Market and is scheduled in SCUC to provide Energy from the Demand Reduction, the LSE providing Energy service to the Demand Side Resource that accounts for the Demand Reduction shall be settled at the product of: (a) the Day-Ahead hourly LBMP at the applicable Demand Reduction Bus; and (b) the hourly demand reduction scheduled Day-Ahead (in MW). In addition, each Demand Reduction Provider that bids a Demand Reduction into the Day-Ahead

Market and is scheduled in the SCUC to provide Energy through Demand Reduction shall receive a Demand Reduction Incentive Payment from the ISO equal to the product of: (a) the Day-Ahead hourly LBMP at the Demand Reduction bus; and (b) the lesser of the verified actual hourly Demand Reduction or the scheduled hourly Demand Reduction (in MW). Each Customer that bids into the Day-Ahead Market, including each Customer that submits a Bid for a Virtual Transaction, and has a schedule accepted by the ISO to purchase Energy in the Day-Ahead Market will pay the product of: (a) the Day-Ahead hourly Zonal LBMP at each Point of Withdrawal; and (b) the scheduled Energy at each Point of Withdrawal. Each Supplier that bids an External Transaction into the Day-Ahead LBMP Market and is scheduled in the SCUC to buy Energy from the Day-Ahead LBMP Market will pay the product of (a) the Day-Ahead LBMP at the applicable Proxy Generator Bus and (b) the External Transaction schedule. Each Customer that submits a Virtual Transaction bid into the ISO Day-Ahead Market and has a schedule accepted by the ISO to sell Energy in a Load Zone in the Day-Ahead Market will receive a payment equal to the product of (a) the Day-Ahead hourly zonal LBMP for that Load Zone; and (b) the hourly scheduled Energy for the Customer in that Load Zone. Each Trading Hub Energy Owner who bids a Bilateral Transaction into the Day-Ahead Market with a Trading Hub as its POI and has its schedule accepted by the ISO will pay the product of: (a) the Day-Ahead hourly zonal LBMP for the Load Zone associated with that Trading Hub; and (b) the Bilateral Transaction scheduled MW. Each Trading Hub Energy Owner who bids a Bilateral Transaction into the Day-Ahead Market with a Trading Hub as its POW and has its schedule accepted by the ISO will be paid the product of: (a) the Day-Ahead hourly zonal LBMP for the Load Zone associated with that Trading Hub; and (b) the Bilateral Transaction scheduled MW.

The ISO shall publish the Day-Ahead Settlement Load Zone LBMPs for each hour in the Dispatch Day.

4.4 Real-Time Markets and Schedules

4.4.1 Real-Time Commitment (“RTC”)

4.4.1.1 Overview

RTC will make binding unit commitment and de-commitment decisions for the periods beginning fifteen minutes (in the case of Resources that can respond in ten minutes) and thirty minutes (in the case of Resources that can respond in thirty minutes) after the scheduled posting time of each RTC run, will provide advisory commitment information for the remainder of the two and a half hour optimization period, and will produce binding schedules for External Transactions to begin at the start of each quarter hour. RTC will treat Behind-the-Meter Net Generation Resources and Energy Storage Resources as already being committed and available to be scheduled. RTC will co-optimize to solve simultaneously for all Load, Operating Reserves and Regulation Service and to minimize the total as-bid production costs over its optimization timeframe. RTC will consider SCUC’s Resource commitment for the day, load forecasts that RTC itself will produce each quarter hour, binding transmission constraints, and all Real-Time Bids and Bid parameters submitted pursuant to Section 4.4.1.2 below.

4.4.1.2 Bids and Other Requests

After the Day-Ahead schedule is published and before the close of the Real-Time Scheduling Window for each hour, Customers may submit Real-Time Bids into the Real-Time Market for real-time evaluation by providing all information required to permit real-time evaluation pursuant to ISO Procedures. If the Supplier elects to participate in the Real-Time Market, and is within a defined electrical boundary, electrically interconnected with, and routinely serves a Host Load (which Host Load does not exclusively consist of Station Power) at a single PTID, it can only participate in the Real-Time Market as a Behind-the-Meter Net

Generation Resource. If a Behind-the-Meter Net Generation Resource submits Bids into the Real-Time Market for real-time evaluation, such Bids shall provide the forecasted Host Load for each hour for which Bids are submitted.

An Energy Storage Resource shall indicate in its Real-Time Bids whether its Energy Level will be ISO- or Self-Managed. An Energy Storage Resource that elects to Self-Manage its Energy Level shall be responsible for managing its Energy Level through its Bids. An Energy Storage Resource, including an Energy Storage Resource that received a Day-Ahead Schedule, may change its Energy Level Management election for each operating hour in the Real-Time Market day.

4.4.1.2.1 Real-Time Bids to Supply or Withdraw Energy and Supply Ancillary Services, other than External Transactions

Intermittent Power Resources that depend on wind as their fuel submitting new or revised offers to supply Energy shall bid as ISO-Committed Flexible and shall submit a Minimum Generation Bid of zero MW and zero cost and a Start-Up Bid at zero cost. Eligible Customers may submit new or revised Bids to supply or withdraw Energy, and to supply Operating Reserves and/or Regulation Service. Customers that submit such Bids may specify different Bid parameters in real-time than they did Day-Ahead. Incremental Energy Bids, for portions of the Capacity of such Resources that were scheduled in the Day-Ahead Market, and/or Start-Up Bids may be submitted by Suppliers bidding Resources using ISO-Committed Fixed, ISO-Committed Flexible, and Self-Committed Flexible bid modes that exceed the Incremental Energy Bids or Start-Up Bids submitted in the Day-Ahead Market or the mitigated Day-Ahead Incremental Energy Bids or Start-Up Bids where appropriate, if not otherwise prohibited pursuant to other provisions of the tariff. Minimum Generation Bids for any hour in which such Resources received a Day-Ahead Energy schedule or a Regulation Service schedule, as appropriate, may

not exceed the Minimum Generation Bids or Regulation Service Bids, as appropriate, submitted for those Resources in the Day-Ahead Market. Additionally, Real-Time Minimum Run Qualified Gas Turbine Customers shall not increase their previously submitted Real-Time Incremental Energy Bids, Minimum Generation Bids, or Start-Up Bids within 135 minutes of the dispatch hour. Bids to supply Energy or Ancillary Services shall be subject to the rules set forth in Section 4.2.1 of this ISO Services Tariff. For Behind-the-Meter Net Generation Resources, the ISO will consider only those segments of the Resource's Incremental Energy Bids above the forecasted Host Load and subject to the Injection Limit.

Suppliers bidding on behalf of Generators that did not receive a Day-Ahead schedule for a given hour may offer their Generators, for those hours, using the ISO-Committed Flexible, Self-Committed Flexible, Self-Committed Fixed bid mode or, with ISO approval, the ISO-Committed Fixed bid modes in real-time. For Behind-the-Meter Net Generation Resources, the ISO will consider only those segments of the Resource's Incremental Energy Bids above the forecasted Host Load and subject to the Injection Limit. Suppliers bidding on behalf of Demand Side Resources that did not receive a Day-Ahead schedule to provide Operating Reserves or Regulation Service for a given hour may offer to provide Operating Reserves or Regulation Service using the ISO-Committed Flexible bid mode for that hour in the Real-Time Market provided, however, that the Demand Side Resource shall have an Energy price Bid no lower than the Monthly Net Benefit Offer Floor. A Supplier bidding on behalf of a Generator that received a Day-Ahead schedule for a given hour may not change the bidding mode for that Generator for the Real-Time Market for that hour provided, however, that Generators that were scheduled Day-Ahead in Self-Committed Fixed mode may switch, with ISO approval, to ISO-Committed Fixed bidding mode in real-time. Generators that were scheduled Day-Ahead in ISO-Committed Fixed

mode will be scheduled as Self-Committed Fixed in the Real-Time Market unless, with ISO approval, they change their bidding mode to ISO-Committed Fixed.

A Generator with a real time physical operating problem that makes it impossible for it to operate in the bidding mode in which it was scheduled Day-Ahead should notify the ISO. Additionally, if the Host Load of a Behind-the-Meter Net Generation Resource is greater in real-time than was forecasted Day-Ahead such that it cannot meet its Day-Ahead schedule, it must notify the ISO.

Generators and Demand Side Resources may not submit separate Operating Reserves Availability Bids in real-time and will instead automatically be assigned a real-time Operating Reserves Availability Bid of zero for the amount of Operating Reserves they are capable of providing in light of their response rate (as determined under Rate Schedule 4).

4.4.1.2.2 Real-Time Bids Associated with Internal and External Bilateral Transactions

Customers may use Real-Time Bids to seek to modify Bilateral Transactions that were previously scheduled Day-Ahead or propose new Bilateral Transactions, including External Transactions, for economic evaluation by RTC, provided however, that Bilateral Transactions with Trading Hubs as their POWs that were previously scheduled Day-Ahead may not be modified. Bids associated with Internal Bilateral Transactions shall be subject to the rules set forth above in Section 4.2.1.7.

Except as provided in this section, External Transaction Bids may not vary over the course of an hour. Each such Bid must offer to import, export or wheel the same amount of Energy at the same price at each point in time within that hour. At Variably Scheduled Proxy Generator Buses the ISO shall permit the submission of Bids to import or export Energy that vary the amount of Energy, and vary the price, for each quarter hour evaluation period.

The ISO may vary External Transaction Schedules at Proxy Generator Buses that are authorized to schedule transactions on an intra-hour basis if the party submitting the Bid for such a Transaction elects to permit variable scheduling. The ISO may also vary External Transaction Schedules at CTS Enabled Proxy Generator Buses. External Transaction Bids submitted to import Energy from, or export Energy to Proxy Generator Buses that are authorized to schedule transactions on either an intra-hour or hourly basis shall indicate whether the ISO may vary schedules associated with those Bids within each hour. Transmission Customers scheduling External Bilateral Transactions shall also be subject to the provisions of Section 16, Attachment J of the ISO OATT.

4.4.1.2.3 Self-Commitment Requests

Self-Committed Flexible Resources must provide the ISO with schedules of their expected minimum operating points in quarter hour increments. Self-Committed Fixed Resources must provide their expected actual operating points in quarter hour increments or, with ISO approval, bid as an ISO-Committed Fixed Generator.

4.4.1.2.4 ISO-Committed Fixed

The ability to use the ISO-Committed Fixed bidding mode in the Real-Time Market shall be subject to ISO approval pursuant to procedures, which shall be published by the ISO. Generators that have exclusively used the Self-Committed Fixed or ISO-Committed Fixed bid modes in the Day-Ahead Market or that do not have the communications systems, operational control mechanisms or hardware to be able to respond to five-minute dispatch basepoints are eligible to bid using the ISO-Committed Fixed bid mode in the Real-Time Market. Real-Time Bids by Generators using the ISO-Committed Fixed bid mode in the Real-Time Market shall provide variable Energy price Bids, consisting of up to eleven monotonically increasing, constant

cost incremental Energy steps, Minimum Generation Bids, hourly Start-Up Bids and other information pursuant to ISO Procedures.

RTC shall schedule ISO-Committed Fixed Generators.

4.4.1.3 External Transaction Scheduling

RTC15 will schedule External Transactions on an hourly basis as part of its development of a co-optimized least-bid cost Real-Time Commitment. For External Transactions that are scheduled on a 15 minute basis, the amount of Energy scheduled to be imported, exported or wheeled in association with that External Transaction may change on the quarter hour. All RTC runs will schedule intra-hour External Transactions on a 15 minute basis at Variably Scheduled Proxy Generator Buses. RTC will alert the ISO when it appears that scheduled External Transactions need to be reduced for reliability reasons but will not automatically Curtail them. Curtailment decisions will be made by the ISO, guided by the information that RTC provides, pursuant to the rules established by Attachment B of this ISO Services Tariff and the ISO Procedures. External Bilateral Transaction schedules are also governed by the provisions of Section 16, Attachment J of the OATT.

4.4.1.4 Posting Commitment/De-Commitment and External Transaction Scheduling Decisions

Except as specifically noted in Section 4.4.2, 4.4.3 and 4.4.4 of this ISO Services Tariff, RTC will make all Resource commitment and de-commitment decisions. RTC will make all economic commitment/de-commitment decisions based upon available offers assuming Suppliers internal to the NYCA have a minimum run time of at least 15 minutes, but not longer than one hour; provided however, Real-Time Minimum Run Qualified Gas Turbines shall be assumed to have a two-hour minimum run time. For Behind-the-Meter Net Generation

Resources, RTC will consider only those segments of the Resource's Incremental Energy Bids above the forecasted Host Load and subject to the Injection Limit.

RTC will produce advisory commitment information and advisory real-time prices. RTC will make decisions and post information in a series of fifteen-minute "runs" which are described below.

RTC₁₅ will begin at the start of the first hour of the RTC co-optimization period and will post its commitment, de-commitment, and External Transaction scheduling decisions no later than fifteen minutes after the start of that hour. During the RTC₁₅ run, RTC will:

- (i) Commit Resources with 10-minute start-up times that should be synchronized by the time that the results of the next RTC run are posted so that they will be synchronized and running at their scheduled dispatch levels by that time;
- (ii) Commit Resources with 30-minute start-up times that should be synchronized by the time that the results of the RTC run following the next RTC run are posted so that they will be synchronized and running at their scheduled dispatch levels by that time;
- (iii) De-commit Resources that should be disconnected from the network by the time that the results of the next RTC run are posted so that they will be disconnected by that time;
- (iv) Issue advisory commitment and de-commitment guidance for periods more than thirty minutes in the future and advisory dispatch information;
- (v) Schedule economic hourly External Transactions for the next hour;

- (vi) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at Variably Scheduled Proxy Generator Buses other than a CTS Enabled Proxy Generator Bus;
- (vii) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at a CTS Enabled Proxy Generator Bus; and
- (viii) Schedule ISO-Committed Fixed Resources.

All subsequent RTC runs in the hour, *i.e.*, RTC₃₀, RTC₄₅, and RTC₀₀ will begin executing at fifteen minutes before their designated posting times (for example, RTC₃₀ will begin in the fifteenth minute of the hour), and will take the following steps:

- (i) Commit Resources with 10-minute start-up times that should be synchronized by the time that the results of the next RTC run are posted so that they will be synchronized and running at that time;
- (ii) Commit Resources with 30-minute start-up times that should be synchronized by the time that the results of the RTC run following the next RTC run are posted so that they will be synchronized and running at that time;
- (iii) De-commit Resources that should be disconnected from the network by the time that the results of the next RTC run are posted so that they will be disconnected at that time;
- (iv) Issue advisory commitment, de-commitment, and dispatching guidance for the period from thirty minutes in the future until the end of the RTC co-optimization period;

- (v) Either reaffirm that the External Transactions scheduled by previous RTC runs should continue to flow in the next hour, or inform the ISO that External Transactions may need to be reduced;
- (vi) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at Variably Scheduled Proxy Generator Buses other than a CTS Enabled Proxy Generator Bus;
- (vii) Schedule economic 15 minute External Transactions, for the quarter hour for which the results of the next RTC run are posted, at a CTS Enabled Proxy Generator Bus; and
- (viii) Schedule ISO-Committed Fixed Resources.

4.4.1.5 External Transaction Settlements

Settlements for External Transactions in the LBMP Market are described in Sections 4.2.6 and 4.5 of this ISO Services Tariff. Settlements for External Bilateral Transactions are also described in Section 16, Attachment J and Rate Schedules 7 and 8 of the OATT.

The calculation of Real-Time LBMPs at Proxy Generator Buses and CTS Enabled Interfaces is described in Section 17, Attachment B to this ISO Services Tariff.

4.4.2 Real-Time Dispatch

4.4.2.1 Overview

The Real-Time Dispatch will make dispatching decisions, send Base Point Signals to Internal Generators and Demand Side Resources, produce schedules for intra-hour External Transactions at Dynamically Scheduled Proxy Generator Buses, calculate Real-Time Market clearing prices for Energy, Operating Reserves, and Real-Time Market Prices for Regulation Service, and establish real-time schedules for those products on a five-minute basis, starting at

the beginning of each hour. The Real-Time Dispatch will not make commitment decisions and will not consider start-up costs in any of its dispatching or pricing decisions, except as specifically provided in Section 4.4.2.4 below. Real-Time Dispatch will review each Energy Storage Resource's Beginning Energy Level in each interval. Real-Time Dispatch will attempt to prevent dispatching a Self-Managed Energy Storage Resource in a manner that would be infeasible based on its Beginning Energy Level. Instead, Real-Time dispatch will consider an Energy Storage Resource's Beginning Energy Level in developing a schedule for the binding interval. An Energy Storage Resource's Beginning Energy Level will be used to ensure that Operating Reserves scheduled from the Resource can be sustained for one hour if the Operating Reserves are converted to Energy. Each Real-Time Dispatch run will co-optimize to solve simultaneously for Load, Operating Reserves, and Regulation Service and to minimize the total cost of production over its bid optimization horizon (which may be fifty, fifty-five, or sixty minutes long depending on where the run falls in the hour.) In addition to producing a binding schedule for the next five minutes, each Real-Time Dispatch run will produce advisory schedules for the remaining four time steps of its bid-optimization horizon (which may be five, ten, or fifteen minutes long depending on where the run falls in the hour). An advisory schedule may become binding in the absence of a subsequent Real-Time Dispatch run. RTD will use the most recent system information and the same set of Bids and constraints that are considered by RTC.

4.4.2.2 External Transaction Scheduling

All RTD runs will schedule External Transactions on a 5 minute basis at Dynamically Scheduled Proxy Generator Buses. For External Transactions that are scheduled on a 5 minute basis, the amount of Energy scheduled to be imported, exported or wheeled in association with

that External Transaction may change every 5 minutes. External Bilateral Transaction Schedules are also governed by the provisions of Attachment J of the OATT.

4.4.2.3 Calculating Real-Time Market LBMPs and Advisory Prices

RTD shall calculate *ex ante* Real-Time LBMPs at each Generator bus, and for each Load Zone in each RTD cycle, in accordance with the procedures set forth in Attachment B to this ISO Services Tariff. RTD will also calculate and post advisory Real-Time LBMPs for the next four quarter hours in accordance with the procedures set forth in Attachment B.

4.4.2.4 Real-Time Pricing Rules for Scheduling Ten Minute Resources

RTD may commit and dispatch, for pricing purposes, Resources capable of starting and meeting Minimum Generation Levels within ten minutes (“eligible Resources”) when necessary to meet load. Eligible Resources committed and dispatched by RTD for pricing purposes may be physically started through normal ISO operating processes. In the RTD cycle in which RTD commits and dispatches an eligible Resource, RTD will consider the Resource’s start-up and incremental energy costs and will assume the Resource has a zero downward response rate for purposes of calculating *ex ante* Real-Time LBMPs pursuant to Section 17, Attachment B to this ISO Services Tariff.

4.4.2.5 Converting to Demand Reduction, Special Case Resource Capacity scheduled as Operating Reserves, Regulation or Energy in the Real-Time Market

The ISO shall convert to Demand Reductions, in hours in which the ISO requests that Responsible Interface Parties notify their Special Case Resources to reduce their demand pursuant to ISO Procedures, any Operating Reserves, Regulation Service or Energy scheduled in the Day-Ahead Market from Demand Side Resources that are also providing Special Case

Resource Capacity. The ISO shall settle the Demand Reduction provided by that portion of the Special Case Resource Capacity that was scheduled Day-Ahead as Operating Reserves, Regulation Service or Energy as being provided by a Supplier of Operating Reserves, Regulation Service or Energy as appropriate. The ISO shall settle any remaining Demand Reductions provided beyond Capacity that was scheduled Day-Ahead as Ancillary Services or Energy as being provided by a Special Case Resource, provided such Demand Reduction is otherwise payable as a reduction by a Special Case Resource.

Operating Reserves or Regulation Service scheduled Day-Ahead and converted to Energy in real time pursuant to this Section 4.4.2.4, will be eligible for a Day-Ahead Margin Assurance Payment, pursuant to Attachment J of this ISO Services Tariff.

Special Case Resource Capacity that has been scheduled in the Day-Ahead Market to provide Operating Reserves, Regulation Service or Energy and that has been instructed as a Special Case Resource to reduce demand shall be considered, for the purpose of determining a Scarcity Reserve Requirement pursuant to Rate Schedule 4 of this ISO Services Tariff, to be a Special Case Resource.

The ISO shall not accept offers of Operating Reserves or Regulation Service in the Real-Time Market from Demand Side Resources that are also providing Special Case Resource Capacity for any hour in which the ISO has requested Special Case Resources to reduce demand.

4.4.2.6 Converting to Demand Reduction Curtailment Services Provider Capacity scheduled as Operating Reserves, Regulation or Energy in the Real-Time Market

The ISO shall convert to Demand Reductions, in hours in which the ISO requests Demand Reductions from the Emergency Demand Response Program pursuant to ISO Procedures, any Operating Reserves, Regulation Service or Energy scheduled in the Day-Ahead

Market by Demand Side Resources that are also providing Curtailment Services Provider Capacity. The ISO shall settle the Demand Reduction provided by that portion of the Curtailment Services Provider Capacity that was scheduled Day-Ahead as Operating Reserves, Regulation Service or Energy as being provided by a Supplier of Operating Reserves, Regulation Service or Energy as appropriate. The ISO shall settle Demand Reductions provided beyond Capacity that was scheduled Day-Ahead as ancillary services or Energy as being provided by a Curtailment Services Provider.

Operating Reserves or Regulation Service scheduled Day-Ahead and converted to Energy in real time pursuant to this Section 4.4.2.5, will be eligible for a Day-Ahead Margin Assurance Payment, pursuant to Attachment J of this ISO Services Tariff.

Curtailment Services Provider Capacity that has been scheduled in the Day-Ahead Market as Operating Reserves, Regulation Service or Energy and that has been instructed to reduce demand shall be considered, for the purpose of determining a Scarcity Reserve Requirement pursuant to Rate Schedule 4 of this ISO Services Tariff, to be a Emergency Demand Response Program Resource.

The ISO shall not accept offers of Operating Reserves and Regulation Service in the Real-Time Market from Demand Side Resources that are also providing Curtailment Services Provider Capacity for any hour in which the ISO has requested participants in the Emergency Demand Response Program pursuant to ISO Procedures to reduce demand.

4.4.2.7 Post the Real-Time Schedule

Subsequent to the close of the Real-Time Scheduling Window, the ISO shall post the real-time schedule for each entity that submits a Bid or Bilateral Transaction schedule. All schedules shall be considered proprietary, with the posting only visible to the appropriate

scheduling Customer, Transmission Customer and Transmission Owners subject to the applicable Code of Conduct (See Attachment F to the ISO OATT). The ISO will post on the OASIS the real-time Load for each Load Zone, and the Real-Time LBMP prices (including the Congestion Component and the Marginal Losses Component) for each Load Zone for each hour of the Dispatch Day. The ISO shall conduct the real-time settlement based upon the real-time schedule determined in accordance with this Section.

4.4.3 Real-Time Dispatch - Corrective Action Mode

When the ISO needs to respond to system conditions that were not anticipated by RTC or the regular Real-Time Dispatch, *e.g.*, the unexpected loss of a major Generator or Transmission line, it will activate the specialized RTD-CAM program. RTD-CAM runs will be nominally either five or ten minutes long, as is described below. Unlike the Real-Time Dispatch, RTD-CAM will have the ability to commit certain Resources, and schedule intra-hour External Transactions at Dynamically Scheduled Proxy Generator Buses. When RTD-CAM is activated, the ISO will have discretion to implement various measures to restore normal operating conditions. These RTD-CAM measures are described below.

The ISO shall have discretion to determine which specific RTD-CAM mode should be activated in particular situations. In addition, RTD-CAM may require Resources to run above their UOL_{NS}, up to the level of their UOL_{ES} as is described in the ISO Procedures. Self-Committed Fixed Resources will not be expected to move in response to RTD-CAM Base Point Signals except when a maximum generation pickup is activated.

Except as expressly noted in this section, RTD-CAM will dispatch the system in the same manner as the normal Real-Time Dispatch.

4.4.3.1 RTD-CAM Modes

4.4.3.1.1 Reserve Pickup

The ISO will enter this RTD-CAM mode when necessary to re-establish schedules when large area control errors occur. When in this mode, RTD-CAM will send 10-minute Base Point Signals and produce schedules for the next ten minutes. RTD-CAM may also commit, or if necessary de-commit, Resources capable of starting or stopping within 10-minutes. The ISO will continue to optimize for Energy and Operating Reserves, will recognize locational Operating Reserve requirements and Scarcity Reserve Requirements, but will set all Regulation Service schedules to zero. If Resources are committed or de-committed in this RTD-CAM mode the schedules for them will be passed to RTC and the Real-Time Dispatch for their next execution.

Resources that are eligible to provide Operating Reserves and that are available to the ISO for dispatch in real-time are required to be able to meet the energy sustainability requirements set forth in applicable NERC, NPCC and/or NYSRC reliability requirements. When the ISO enters a reserve pickup RTD-CAM mode it will determine sustainable Energy schedules for Energy Storage Resources that are eligible to provide Operating Reserves and that are available to the ISO for dispatch based on their telemetered state of charge.

The ISO will have discretion to classify a reserve pickup as a “large event” or a “small event.” In a small event the ISO will have discretion to reduce Base Point Signals in order to reduce transmission line loadings. The ISO will not ordinarily have this discretion in large events, except that it may determine Energy schedules that satisfy Operating Reserve energy sustainability requirements for Energy Storage Resources. The distinction also has significance with respect to a Supplier’s eligibility to receive Bid Production Cost guarantee payment in accordance with Section 4.6.6 and Attachment C of this ISO Services Tariff.

4.4.3.1.2 Maximum Generation Pickup

The ISO will enter this RTD-CAM mode when an Emergency makes it necessary to maximize Energy production in one or more location(s), i.e., Long Island, New York City, Southeastern New York, East of Central East and/or NYCA-wide. RTD-CAM will produce schedules directing all Generators located in a targeted location to increase production at their emergency response rate up to their UOL_E level and to stay at that level until instructed otherwise. Security constraints will be obeyed to the extent possible. The ISO will continue to optimize for Energy and Operating Reserves, will recognize locational Operating Reserve requirements and Scarcity Reserve Requirements, but will set all Regulation Service schedules to zero.

4.4.3.1.3 Base Points ASAP -- No Commitments

The ISO will enter this RTD-CAM mode when changed circumstances make it necessary to issue an updated set of Base Point Signals. Examples of changed circumstances that could necessitate taking this step include correcting line, contingency, or transfer overloads and/or voltage problems caused by unexpected system events. When operating in this mode, RTD-CAM will produce schedules and Base Point Signals for the next five minutes but will only redispatch Generators that are capable of responding within five minutes. RTD-CAM will not commit or de-commit Resources in this mode.

4.4.3.1.4 Base Points ASAP -- Commit As Needed

This operating mode is identical to Base Points ASAP – No Commitments, except that it also allows the ISO to commit Generators that are capable of starting within 10 minutes when doing so is necessary to respond to changed system conditions.

4.4.3.1.5 Re-Sequencing Mode

When the ISO is ready to de-activate RTD-CAM, it will often need to transition back to normal Real-Time Dispatch operation. In this mode, RTD-CAM will calculate normal five-minute Base Point Signals and establish five minute schedules. Unlike the normal RTD-Dispatch, however, RTD-CAM will only look ahead 10-minutes. RTD-CAM re-sequencing will terminate as soon as the normal Real-Time Dispatch software is reactivated and is ready to produce Base Point signals for its entire optimization period.

4.4.3.2 Calculating Real-Time LBMPs

When RTD-CAM is activated, RTD shall calculate *ex ante* Real-Time LBMPs at each Generator bus, and for each Load Zone in accordance with the procedures set forth in Section 17, Attachment B of this ISO Services Tariff.

4.4.4 Identifying the Pricing and Scheduling Rules That Apply to External Transactions

LBMPs will be determined and External Transactions will be scheduled at external Proxy Generator Buses consistent with the table below.

Proxy Generator Bus	PTID	Scheduled Line	Designated Scheduled Line	Non-Competitive	CTS Enabled Proxy Generator Bus		Scheduling Frequencies		
					Requires CTS Bids	Permits CTS Bids	Hourly Scheduled	Variably Scheduled	Dynamically Scheduled (Not Presently Available)
Hydro Quebec									
HQ_GEN_IMPORT	323601			✓			✓	✓	
HQ_LOAD_EXPORT	355639			✓			✓	✓	
HQ_GEN_CEDARS_PROXY	323590	Dennison Scheduled Line		✓			✓		
HQ_LOAD_CEDARS_PROXY	355586	Dennison Scheduled Line		✓			✓		
HQ_GEN_WHEEL	23651			✓			✓		
HQ_LOAD_WHEEL	55856			✓			✓		
PJM									
PJM_GEN_KEYSTONE	24065					✓	✓* (See Notes)	✓	
PJM_LOAD_KEYSTONE	55857					✓	✓* (See Notes)	✓	
PJM_GEN_NEPTUNE_PROXY	323594	Neptune Scheduled Line	✓			✓	✓* (See Notes)	✓	
PJM_LOAD_NEPTUNE_PROXY	355615	Neptune Scheduled Line	✓			✓	✓* (See Notes)	✓	
PJM_GEN_VFT_PROXY	323633	Linden VFT Scheduled Line	✓			✓	✓* (See Notes)	✓	
PJM_LOAD_VFT_PROXY	355723	Linden VFT Scheduled Line	✓			✓	✓* (See Notes)	✓	
PJM_HTP_GEN	323702	HTP Scheduled Line	✓			✓	✓* (See Notes)	✓	

Proxy Generator Bus	PTID	Scheduled Line	Designated Scheduled Line	Non-Competitive	CTS Enabled Proxy Generator Bus		Scheduling Frequencies		
					Requires CTS Bids	Permits CTS Bids	Hourly Scheduled	Variably Scheduled	Dynamically Scheduled (Not Presently Available)
HUDSONTP_345KV_HTP_LOAD	355839	HTP Scheduled Line	✓			✓	✓*	✓	
ISO New England									
N.E._GEN_SANDY_POND	24062				✓		✓**	✓	
NE_LOAD_SANDY_PD	55858				✓		✓**	✓	
NPX_GEN_CSC	323557	Cross Sound Scheduled Line	✓				✓		
NPX_LOAD_CSC	355535	Cross Sound Scheduled Line	✓				✓		
NPX_GEN_1385_PROXY	323591	Northport Norwalk Scheduled Line					✓		
NPX_LOAD_1385_PROXY	355589	Northport Norwalk Scheduled Line					✓		
Ontario									
OH_GEN_PROXY	24063						✓		
OH_LOAD_PROXY	55859						✓		

Notes:

* At specifically identified Proxy Generator Buses (“* See Notes”), only Wheels Through (the NYCA) are scheduled on an hourly basis.

** At specifically identified Proxy Generator Buses (“** See Notes”), only wheels through the NYCA or a neighboring Control Area are scheduled on an hourly basis.

Pricing rules for Proxy Generator Buses are set forth in Section 17 of the Services Tariff.

The ISO may offer a more frequent scheduling option at a Proxy Generator Bus identified on the table. The ISO shall inform its Market Participants of the availability of such an option by providing notice at least two weeks in advance of the implementation of any such change. At the same time, the ISO shall update the above table to reflect the change in scheduling options by submitting a compliance filing in FERC Docket No. ER11-2547. Unless FERC acts on the ISO's compliance filing, the ISO shall effectuate the change in scheduling capability on the date it proposed in its compliance filing. The addition of new Proxy Generator Buses to the table, or changing the pricing rules that apply at a Proxy Generator Bus, may not be accomplished by submitting a compliance filing in Docket No. ER11-2547. The ISO may revert to establishing hourly Import and Export schedules using all available External Transaction Bids at a Proxy Generator Bus that is identified as a Dynamically or Variably Scheduled Proxy Generator Bus when the ISO or a neighboring Balancing Authority is not able to implement schedules as expected, or when necessary to ensure or preserve system reliability. When it reverts to hourly Import and Export schedules at a Dynamically or Variably Scheduled Proxy Generator Bus, the ISO shall apply the pricing rules for a corresponding Proxy Generator Bus that is not Dynamically Scheduled or Variably Scheduled. The ISO may cease evaluating CTS Interface Bids at CTS Enabled Proxy Generator Buses when the ISO or a neighboring Balancing Authority is not able to implement schedules as expected, or when necessary to ensure or preserve system reliability.

5.12 Requirements Applicable to Installed Capacity Suppliers

5.12.1 Installed Capacity Supplier Qualification Requirements

In order to qualify as an Installed Capacity Supplier, Generators and controllable transmission projects electrically located in the NYCA, and transmission projects with associated incremental transfer capability, must have obtained Capacity Resource Interconnection Service (“CRIS”) pursuant to the applicable provisions of Attachment S to the ISO OATT and have entered service: controllable transmission projects must also have obtained Unforced Capacity Deliverability Rights and transmission projects with associated incremental transfer capability must also have obtained External-to-ROS Deliverability Rights. Even if a Generator has otherwise satisfied the requirements to participate in the ISO’s Installed Capacity market, a Generator in Inactive Reserves, an ICAP Ineligible Forced Outage, a Mothball Outage, or that is Retired is ineligible to participate in the ISO’s Installed Capacity market. A Generator that elects to participate in the ICAP Market, and is within a defined electrical boundary, electrically interconnected with, and routinely serves a Host Load (which Host Load does not consist solely of Station Power) at a single PTID can only participate in the Installed Capacity market as a Behind-the-Meter Net Generation Resource.

In addition, to qualify as an Installed Capacity Supplier in the NYCA, Energy Limited Resources, Generators, Installed Capacity Marketers, Intermittent Power Resources, Behind-the-Meter Net Generation Resources, Limited Control Run-of-River Hydro Resources and System Resources rated 1 MW or greater, other than External System Resources and Control Area System Resources which have agreed to certain Curtailment conditions as set forth in the third to last paragraph of Section 5.12.1 below, Responsible Interface Parties, existing municipally-owned generation, Energy Limited Resources, and Intermittent Power Resources, to the extent

those entities are subject to the requirements of Section 5.12.11 of this Tariff, and Energy Storage Resources with a nameplate capacity rating that allows a minimum injection to the NYS Transmission System or distribution system of 0.1 MW or greater shall:

- 5.12.1.1 provide information reasonably requested by the ISO including the name and location of Generators, and System Resources;
- 5.12.1.2 in accordance with the ISO Procedures, perform DMNC or DMGC tests and submit the results to the ISO, or provide to the ISO appropriate historical production data;
- 5.12.1.3 abide by the ISO Generator maintenance coordination procedures;
- 5.12.1.4 provide the expected return date from any outages (including partial outages) to the ISO;
- 5.12.1.5 in accordance with the ISO Procedures,
 - 5.12.1.5.1 provide documentation demonstrating that it will not use the same Unforced Capacity for more than one (1) buyer at the same time, and
 - 5.12.1.5.2 in the event that the Installed Capacity Supplier supplies more Unforced Capacity than it is qualified to supply in any specific month (*i.e.*, is short on Capacity), documentation that it has procured sufficient Unforced Capacity to cover this shortfall.
- 5.12.1.6 except for Installed Capacity Marketers and Intermittent Power Resources that depend upon wind or solar as their fuel, Bid into the Day-Ahead Market, unless the Energy Limited Resource, Generator, Limited Control Run-of-River Hydro Resource or System Resource is unable to do so due to an outage as defined in the ISO Procedures or due to temperature related de-ratings.

Generators may also enter into the MIS an upper operating limit that would define the operating limit under normal system conditions. The circumstances under which the ISO will direct a Generator to exceed its upper operating limit are described in the ISO Procedures;

5.12.1.7 provide Operating Data in accordance with Section 5.12.5 of this Tariff;

5.12.1.8 provide notice to the ISO of any proposed transfers of deliverability rights to be carried out pursuant to Sections 25.9.4 - 25.9.6 of Attachment S to the ISO OATT, on the Class Year Start Date if a request to transfer CRIS at a different location, and upon the submission of the request if it is a request to transfer CRIS at the same location.

5.12.1.9 comply with the ISO Procedures;

5.12.1.10 when the ISO issues a Supplemental Resource Evaluation request (an SRE), NYCA Resources must Bid into the in-day market unless (and only to the extent) the entity has a bid pending in the Real-Time Market when the SRE request is made or is unable to bid in response to the SRE request due to an outage as defined in the ISO Procedures, or due to other operational issues, or due to temperature related deratings.

If an External Installed Capacity Supplier is a Generator, or if an External Generator is associated with an Unforced Capacity sale using UDRs or EDRs, then except to the extent such a Generator is unable to Bid in response to the SRE request due to an outage as defined in the ISO Procedures, due to physical operating limitations affecting the Generator, or due to other operational issues that are outside the Installed Capacity Supplier's control, as determined by the

ISO, it must take all of the following actions for each hour of an SRE request

- (a) Bid an Import to the NYCA in a MW quantity equal to the lesser of (i) the ICAP equivalent of the UCAP sold, or (ii) the maximum MW the Generator is able to produce, at the approved Proxy Generator Bus, at the applicable minimum Bid Price, and
- (b) ensure that the External Generator is operating and is available to provide all of the MW that were Bid to be imported into the NYCA, up to the ICAP equivalent of the UCAP sold, for the entire duration of the SRE request, and
- (c) obtain all reservations and transmission service necessary to deliver all of the MW that were Bid to be imported into the NYCA or to a Locality from the Generator, up to the ICAP equivalent of the UCAP sold from the External Generator, at the approved Proxy Generator Bus.

If the External Installed Capacity Supplier that is a Generator, or the External Generator associated with an Unforced Capacity sale using UDRs or EDRs, is not able to Import the quantity of Energy equal to the ICAP equivalent of the UCAP sold from the Generator or EDR to the NYCA, or if a UDR to the Locality, for every hour of an SRE request then, except to the extent already addressed by a declared outage, the Generator shall provide to the ISO an explanation of the reasons for its failure or inability to perform, including evidence demonstrating any physical operating limitations or other operational issues that prevented the Generator from Importing the quantity of Energy equal to the ICAP equivalent of the UCAP sold from the Generator to the NYCA. To the extent the ISO determines that the information and supporting evidence provided demonstrates that the failure or inability to deliver occurred for reasons

outside the control of the External Installed Capacity Supplier or the External Generator associated with an Unforced Capacity sale using UDRs or EDRs, then the deficiency charge set forth in Section 5.12.12.2 below that applies solely to violations of this Section 5.12.1.10, shall not be assessed.

If an External Installed Capacity Supplier is a Control Area System Resource then, except to the extent it is unable to Bid in response to the SRE request due to an outage as defined in the ISO Procedures or due to operational issues that are outside the Installed Capacity Supplier's control, it must take all of the following actions for each hour of an SRE request (x) Bid an Import in a MW quantity equal to the ICAP equivalent of the UCAP sold, at the approved Proxy Generator Bus, at the applicable minimum Bid Price, and (y) obtain all reservations and transmission service necessary to deliver the ICAP equivalent of the UCAP sold from the Control Area System Resource to the NYCA at the approved Proxy Generator Bus.

If the External Installed Capacity Supplier that is a Control Area System Resource is not able to Import the quantity of Energy equal to the ICAP equivalent of the UCAP sold from the Control Area System Resource to the NYCA for every hour of an SRE request then, except to the extent already addressed by a declared outage, the External Installed Capacity Supplier shall provide to the ISO an explanation of the reasons for its failure or inability to perform, including evidence demonstrating any operational issues that prevented the External ICAP Supplier from Importing the quantity of Energy equal to the ICAP equivalent of the UCAP sold from the Control Area System Resource to the

NYCA. To the extent the ISO determines that the information and supporting evidence provided demonstrates that the failure or inability to deliver occurred for reasons outside the External Installed Capacity Supplier's control, then the deficiency charge set forth in Section 5.12.12.2 below that applies solely to violations of this Section 5.12.1.10, shall not be assessed. A Control Area System Resource must demonstrate that transmission outage(s) prevented delivery of all available Resources in order for the ISO to determine that the Control Area System Resource's failure to Import the quantity of Energy equal to the ICAP equivalent of the UCAP sold occurred for a reason that was outside the External Installed Capacity Supplier's control.

When an External Installed Capacity Supplier that is responding to an ISO SRE request Bids its Import at a Non-Competitive Proxy Generator Bus, its obligation to Bid an Import at the applicable minimum Bid Price includes the obligation to ensure that neither the External Installed Capacity Supplier nor any of its Affiliates are offering other Imports at an equivalent or greater economic priority at the Non-Competitive Proxy Generator Bus.

5.12.1.11 Installed Capacity Suppliers located East of Central-East shall Bid in the Day-Ahead and Real-Time Markets all Capacity available for supplying 10-Minute Non-Synchronized Reserve (unless the Generator is unable to meet its commitment because of an outage as defined in the ISO Procedures), except for the Generators described in Subsections 5.12.1.11.1, 5.12.1.11.2 and 5.12.1.11.3 below;

- 5.12.1.11.1 Generators providing Energy under contracts executed and effective on or before November 18, 1999 (including PURPA contracts) in which the power purchasers do not control the operation of the supply source but would be responsible for penalties for being off-schedule, with the exception of Generators under must-take PURPA contracts executed and effective on or before November 18, 1999, who have not provided telemetering to their local TO and historically have not been eligible to participate in the NYPP market, which will continue to be treated as TO Load modifiers under the ISO-administered markets;
- 5.12.1.11.2 Existing topping turbine Generators and extraction turbine Generators producing Energy resulting from the supply of steam to the district steam system located in New York City (LBMP Zone J) in operation on or before November 18, 1999 and/or topping or extraction turbine Generators used in replacing or repowering steam supplies from such units (in accordance with good engineering and economic design) that cannot follow schedules, up to a maximum total of 523 MW of such units; and
- 5.12.1.11.3 Units that have demonstrated to the ISO that they are subject to environmental, contractual or other legal or physical requirements that would otherwise preclude them from providing 10-Minute NSR.
- 5.12.1.12 A Resource that was determined by the ISO to be qualified as a Behind-the-Meter Net Generation Resource and for which Net Unforced Capacity was calculated by the ISO for a Capability Year can annually, by written notice received by the NYISO prior to August 1, elect not to participate in the ISO Administered Markets as a Behind-the-Meter Net Generation Resource. Such

notice shall be in accordance with ISO Procedures. A Resource that makes such an election cannot participate as a Behind-the-Meter Net Generation Resource for the entire Capability Year for which it made the election, but can, however, prior to August 1 of any subsequent Capability Year, provide all required information in order to seek to re-qualify as a Behind-the-Meter Net Generation Resource.

5.12.1.13 For Energy Storage Resources, be capable of running for a minimum of four (4) consecutive hours each day (except for days when it is not capable of doing so because of an outage reported pursuant to Sections 5.12.3, 5.12.5.3, 5.12.5.4, 5.12.7 and in accordance with ISO Procedures). An Energy Storage Resource may de-rate its maximum capability in order to meet the four (4) consecutive hour run-time requirement. ESRs electing to de-rate their maximum capability shall perform a DMNC test at an output level consistent with its de-rated capability in accordance with ISO Procedures (*see*, Installed Capacity Manual § 4).

The ISO shall inform each potential Installed Capacity Supplier that the ISO must receive and approve DMNC or DMGC data, as applicable of its approved DMNC or DMGC ratings for the Summer Capability Period and the Winter Capability Period in accordance with the ISO Procedures.

Requirements to qualify as Installed Capacity Suppliers for External System Resources and Control Area System Resources located in External Control Areas that have agreed not to Curtail the Energy associated with such Installed Capacity or to afford it the same Curtailment priority that it affords its own Control Area Load shall be established in the ISO Procedures.

External Installed Capacity not associated with UDRs, including capacity associated with External CRIS Rights, EDRs, Grandfathered External Installed Capacity Agreements listed in Attachment E of the ISO Installed Capacity Manual, the Existing Transmission Capacity for Native Load listed for New York State Electric & Gas Corporation in Table 3 of Attachment L to the ISO OATT, Import Rights, and External System Resources, is only qualified to satisfy a NYCA Minimum Unforced Capacity Requirement and is not eligible to satisfy a Locational Minimum Installed Capacity Requirement.

Not later than 30 days prior to each ICAP Spot Market Auction, each Market Participant that may make offers to sell Unforced Capacity in such auction shall submit information to the ISO, in accordance with ISO Procedures and in the format specified by the ISO that identifies each Affiliated Entity, as that term is defined in Section 23.2.1 of Attachment H of the Services Tariff, of the Market Party or with which the Market Party is an Affiliated Entity. The names of entities that are Affiliated Entities shall not be treated as Confidential Information, but such treatment may be requested for the existence of an Affiliated Entity relationship. The information submitted to the ISO shall identify the nature of the Affiliated Entity relationship by the applicable category specified in the definition of “Affiliated Entity” in Section 23.2.1 of Attachment H of the Services Tariff.

5.12.2 Additional Provisions Applicable to External Installed Capacity Suppliers

Terms in this Section 5.12.2 not defined in the Services Tariff have the meaning set forth in the OATT.

5.12.2.1 Provisions Addressing the Applicable External Control Area

External Generators, External System Resources, and Control Area System Resources qualify as Installed Capacity Suppliers if they demonstrate to the satisfaction of the NYISO that

the Installed Capacity Equivalent of their Unforced Capacity is deliverable to the NYCA; in the case of an entity using a UDR to meet a Locational Minimum Installed Capacity Requirement, to the NYCA interface associated with that UDR transmission facility and will not be recalled or curtailed by an External Control Area to satisfy its own Control Area Loads; in the case of an EDR, to the NYCA interface over which it creates increased transfer capability; and in the case of Control Area System Resources, if they demonstrate that the External Control Area will afford the NYCA Load the same curtailment priority that they afford their own Control Area Native Load Customers. The amount of Unforced Capacity that may be supplied by such entities qualifying pursuant to the alternative criteria may be reduced by the ISO, pursuant to ISO Procedures, to reflect the possibility of curtailment. External Installed Capacity associated with Import Rights, EDRs or UDRs is subject to the same deliverability requirements applied to Internal Installed Capacity Suppliers associated with UDRs.

5.12.2.2 Additional Provisions Addressing Internal Deliverability and Import Rights

In addition to the provisions contained in Section 5.12.2.1 above, External Installed Capacity not associated with UDRs, EDRs, or External CRIS Rights will be subject to the deliverability test in Section 25.7.8 and 25.7.9 of Attachment S to the ISO OATT. The deliverability of External Installed Capacity not associated with UDRs, EDRs, or External CRIS Rights will be evaluated annually as a part of the process that sets import rights for the upcoming Capability Year, to determine the amount of External Installed Capacity that can be imported to the New York Control Area across any individual External Interface and across all of those External Interfaces, taken together. The External Installed Capacity deliverability test will be performed using the ISO's forecast, for the upcoming Capability Year, of New York Control Area CRIS resources, transmission facilities, and load. Under this process (i) Grandfathered

External Installed Capacity Agreements listed in Attachment E of the ISO Installed Capacity Manual, and (ii) the Existing Transmission Capacity for Native Load listed for New York State Electric & Gas Corporation in Table 3 of Attachment L to the ISO OATT, will be considered deliverable within the Rest of State. Additionally, 1090 MW of imports made over the Quebec (via Chateauguay) Interface will be considered to be deliverable until the end of the 2010 Summer Capability Period.

The import limit set for External Installed Capacity not associated with UDRs, EDRs or External CRIS Rights will be set no higher than the amount of imports deliverable into Rest of State that (i) would not increase the LOLE as determined in the upcoming Capability Year IRM consistent with Section 2.7 of the NYISO Installed Capacity Manual, “Limitations on Unforced Capacity Flow in External Control Areas,” (ii) are deliverable within the Rest of State Capacity Region when evaluated with the New York Control Area CRIS resources (including EDRs and UDRs) and External CRIS Rights forecast for the upcoming Capability Year, and (iii) would not degrade the transfer capability of any Other Interface by more than the threshold identified in Section 25.7.9 of Attachment S to the ISO OATT. Import limits set for External Installed Capacity will reflect the modeling of awarded External CRIS rights, but the awarded External CRIS rights will not be adjusted as part of import limit-setting process. Procedures for qualifying selling, and delivery of External Installed Capacity are detailed in the Installed Capacity Manual.

Until the grandfathered import rights over the Quebec (via Chateauguay) Interface expire at the end of the 2010 Summer Capability Period, the 1090 MW of grandfathered import rights will be made available on a first-come, first-served basis pursuant to ISO Procedures. Any of the grandfathered import rights over the Quebec (via Chateauguay) Interface not utilized for a

Capability Period will be made available to other external resources for that Capability Period, pursuant to ISO Procedures, to the extent the unutilized amount is determined to be deliverable.

Additionally, any of the Existing Transmission Capacity for Native Load listed for New York State Electric & Gas Corporation not utilized by New York State Electric & Gas Corporation for a Capability Period will be made available to other external resources for that Capability Period, pursuant to ISO procedures, to the extent the unutilized amount is determined to be deliverable within the Rest of State Capacity Region.

LSEs with External Installed Capacity as of the effective date of this Tariff will be entitled to designate External Installed Capacity at the same NYCA Interface with another Control Area, in the same amounts in effect on the effective date of this Tariff. To the extent such External Installed Capacity corresponds to Existing Transmission Capacity for Native Load as reflected in Table 3 of Attachment L to the ISO OATT, these External Installed Capacity rights will continue without term and shall be allocated to the LSE's retail access customers in accordance with the LSE's retail access program on file with the PSC and subject to any necessary filings with the Commission. External Installed Capacity rights existing as of September 17, 1999 that do not correspond to Table 3 of Attachment L to the ISO OATT shall survive for the term of the relevant External Installed Capacity contract or until the relevant External Generator is retired.

5.12.2.3 One-Time Conversion of Grandfathered Quebec (via Chateauguay) Interface Rights.

An entity can request to convert a specified number of MW, up to 1090 MW over the Quebec External Interface (via Chateauguay), into External CRIS Rights by making either a Contract Commitment or Non-Contract Commitment that satisfies the requirements of Section 25.7.11.1 of Attachment S to the ISO OATT. The converted number of MW will not be

subject to further evaluation for deliverability within a Class Year Deliverability Study under Attachment S to the ISO OATT, as long as the External CRIS Rights are in effect.

5.12.2.3.1 The External CRIS Rights awarded under this conversion process will first become effective for the 2010-2011 Winter Capability Period.

5.12.2.3.2 Requests to convert these grandfathered rights must be received by the NYISO on or before 5:00 pm Eastern Time on February 1, 2010, with the following information: (a) a statement that the entity is electing to convert by satisfying the requirements of a Contract Commitment or a Non-Contract Commitment in accordance with Section 25.7.11.1 of Attachment S to the ISO OATT; (b) the length of the commitment in years; (c) for the Summer Capability Period, the requested number of MW; (d) for the Winter Capability Period, the Specified Winter Months, if any, and the requested number of MW; and (e) a minimum number of MW the entity will accept if granted (“Specified Minimum”) for the Summer Capability Period and for all Specified Winter Months, if any.

5.12.2.3.3 An entity cannot submit one or more requests to convert in the aggregate more than 1090 MW in any single month.

5.12.2.3.4 If requests to convert that satisfy all other requirements stated herein are equal to or less than the 1090 MW limit, all requesting entities will be awarded the requested number of MW of External CRIS Rights. If conversion requests exceed the 1090 MW limit, the NYISO will prorate the allocation based on the weighted average of the requested MW times the length of the contract/commitment (*i.e.*, number of Summer Capability Periods) in accordance with the following formula:

$$\begin{aligned}
& \text{Rights allocated to entity } i \\
& = 1090 \\
& * (MW_i * \text{contract/commitment length}_i) \\
& / \sum_j (MW_j * \text{contract/commitment length}_j)
\end{aligned}$$

$j = 1, \dots, \#$ entities requesting import rights

In the formula, contract/commitment length means the lesser of the requested contract/commitment length and twenty (20) years. The NYISO will perform separate calculations for the Summer and Winter Capability Periods. The NYISO will determine whether the prorated allocated number of MW for any requesting entity is less than the entity's Specified Minimum. If any allocation is less, the NYISO will remove such request(s) and recalculate the prorated allocations among the remaining requesting entities using the above formula. This process will continue until the prorated allocation meets or exceeds the specified minimum for all remaining requests.

5.12.2.3.5 Any portion of the previously grandfathered 1090 MW not converted through this process will no longer be grandfathered from deliverability. Previously grandfathered rights converted to External CRIS Rights but then terminated will no longer be grandfathered from deliverability.

5.12.2.4 Offer Cap Applicable to Certain External CRIS Rights

Notwithstanding any other capacity mitigation measures or obligations that may apply, the offers of External Installed Capacity submitted pursuant to a Non-Contract Commitment, as described in Section 25.7.11.1.2 of Attachment S of the ISO OATT, will be subject to an offer cap in each month of the Summer Capability Period and for all Specified Winter Months. This offer cap will be determined as the higher of:

5.12.2.4.1 1.1 times the price corresponding to all available Unforced Capacity determined from the NYCA ICAP Demand Curve for that Period; and

5.12.2.4.2 The most recent auction clearing price (a) in the External market supplying the External Installed Capacity, if any, and if none, then the most recent auction clearing price in an External market to which the capacity may be wheeled, less (b) any transmission reservation costs in the External market associated with providing the Installed Capacity, in accordance with ISO Procedures.

5.12.3 Installed Capacity Supplier Outage Scheduling Requirements

All Installed Capacity Suppliers, except for Control Area System Resources and Responsible Interface Parties, that intend to supply Unforced Capacity to the NYCA shall submit a confidential notification to the ISO of their proposed outage schedules in accordance with the ISO Procedures. Transmission Owners will be notified of these and subsequently revised outage schedules. Based upon a reliability assessment, if Operating Reserve deficiencies are projected to occur in certain weeks for the upcoming calendar year, the ISO will request voluntary rescheduling of outages. In the case of Generators actually supplying Unforced Capacity to the NYCA, if voluntary rescheduling is ineffective, the ISO will invoke forced rescheduling of their outages to ensure that projected Operating Reserves over the upcoming year are adequate.

A Generator that refuses a forced rescheduling of its outages for any unit shall be prevented from supplying Unforced Capacity in the NYCA with that unit during any month where it undertakes such outages. The rescheduling process is described in the ISO Procedures.

A Generator that intends to supply Unforced Capacity in a given month that did not qualify as an Installed Capacity Supplier prior to the beginning of the Capability Period must

notify the ISO in accordance with the ISO Procedures so that it may be subject to forced rescheduling of its proposed outages in order to qualify as an Installed Capacity Supplier. A Supplier that refuses the ISO's forced rescheduling of its proposed outages shall not qualify as an Installed Capacity Supplier for that unit for any month during which it schedules or conducts an outage.

Outage schedules for External System Resources and Control Area System Resources shall be coordinated by the External Control Area and the ISO in accordance with the ISO Procedures.

5.12.4 Required Certification for Installed Capacity

- (a) Each Installed Capacity Supplier must confirm to the ISO, in accordance with ISO Procedures that the Unforced Capacity it has certified has not been sold for use in an External Control Area.
- (b) Each Installed Capacity Supplier holding rights to UDRs or EDRs from an External Control Area must confirm to the ISO, in accordance with ISO Procedures, that it will not use as self-supply or offer, and has not sold, Installed Capacity associated with the quantity of MW for which it has not made its one time capability adjustment year election pursuant to Section 5.11.4 (if applicable.)
- (c) On and after the execution of an RMR Agreement, and for the duration of its term, an RMR Generator shall not enter into any new agreement or extend any other agreement that impairs or otherwise diminishes its ability to comply with its obligation under an RMR Agreement, or that limits its ability to provide Energy, Capacity, or Ancillary Services directly to the ISO Administered Markets. An Interim Service Provider that is required to keep its generating unit(s) in service

shall not enter into any new agreement or extend any other agreement that limits its ability to provide Energy, Capacity, or Ancillary Services directly to the ISO Administered Markets or otherwise meet its obligations as an Interim Service Provider.

5.12.5 Operating Data Reporting Requirements

To qualify as Installed Capacity Suppliers in the NYCA, Resources shall submit to the ISO Operating Data in accordance with this Section 5.12.5 and the ISO Procedures. Resources that do not submit Operating Data in accordance with the following subsections and the ISO Procedures may be subject to the sanctions provided in Section 5.12.12.1 of this Tariff.

Resources that were not in operation on January 1, 2000 shall submit Operating Data to the ISO no later than one month after such Resources commence commercial operation, and in accordance with the ISO Procedures and the following subsections as applicable.

5.12.5.1 Generators, System Resources, Energy Limited Resources, Energy storage Resources, Responsible Interface Parties, Intermittent Power Resources, Limited Control Run-of-River Hydro Resources and Municipally Owned Generation

To qualify as Installed Capacity Suppliers in the NYCA, Generators, External Generators, System Resources, External System Resources, Energy Limited Resources, Responsible Interface Parties, Intermittent Power Resources, Limited Control Run-of-River Hydro Resources, Energy Storage Resources, and municipally owned generation or the purchasers of Unforced Capacity associated with those Resources shall submit GADS Data, data equivalent to GADS Data, or other Operating Data to the ISO in accordance with the ISO Procedures. Prior to the successful implementation of a software modification that allows gas turbines to submit multiple bid points, these units shall not be considered to be forced out for any

hours that the unit was available at its base load capability in accordance with the ISO Procedures. This section shall also apply to any Installed Capacity Supplier, External or Internal, using UDRs to meet Locational Minimum Installed Capacity Requirements.

5.12.5.2 Control Area System Resources

To qualify as Installed Capacity Suppliers in the NYCA, Control Area System Resources, or the purchasers of Unforced Capacity associated with those Resources, shall submit CARL Data and actual system failure occurrences data to the ISO each month in accordance with the ISO Procedures.

5.12.5.3 Transmission Projects Granted Unforced Capacity Deliverability Rights

An owner of a transmission project that receives UDRs must, among other obligations, submit outage data or other operational information in accordance with the ISO procedures to allow the ISO to determine the number of UDRs associated with the transmission facility.

5.12.5.4 Transmission Projects Granted External-to ROS Deliverability Rights

An owner of a transmission project that receives EDRs must, among other obligations, submit outage data or other operational information when determined applicable by the ISO and in accordance with ISO Procedures.

5.12.6 Capacity Calculations, Operating Data Default, Value and Collection

5.12.6.1 ICAP Calculation for Behind-the-Meter Net Generation Resources

The ISO shall calculate the amount of Net-ICAP for each Behind-the-Meter Net Generation Resource as the Adjusted DMGC of the Generator of the Behind-the-Meter Net Generation Resource minus the Resource's Adjusted Host Load in accordance with this Tariff and ISO Procedures.

5.12.6.1.1 Adjusted DMGC

The ISO's calculation of the Adjusted DMGC of a Behind-the-Meter Net Generation Resource shall be the least of: (i) its DMGC for the Capability Period; (ii) its Adjusted Host Load plus its applicable Injection Limit; and (iii) its Adjusted Host Load plus the number of MW of CRIS it has obtained, as determined in accordance with OATT Section 25 (OATT Attachment S) and ISO Procedures.

If the Station Power of a Behind-the-Meter Net Generation Resource is separately metered from all other Load of the Resource, such that the Station Power Load can be independently measured and verified, the Generator of a Behind-the-Meter Net Generation Resource may elect to perform a DMNC Test instead of a DMGC Test pursuant to ISO Procedures. Such election must be made in writing to the ISO prior to the start of the DMNC Test Period.

If a Behind-the-Meter Net Generation Resource elects to take a DMNC Test, the Station Power measured during such DMNC Test shall not be included in the Resource's Host Load. A Behind-the-Meter Net Generation Resource's DMNC value for the Capability Period shall be used in lieu of a DMGC value in the calculation of the Resource's Adjusted DMGC for the purposes of Sections 5.12.6.1 and 5.12.6.2 of this Services Tariff.

5.12.6.1.2 Adjusted Host Load

A Behind-the-Meter Net Generation Resource's Adjusted Host Load shall be equal to the product of the Average Coincident Host Load multiplied by one plus the Installed Reserve Margin.

The Adjusted Host Load shall be calculated by the ISO on an annual basis prior to the start of the Summer Capability Period and in accordance with ISO Procedures, based upon the

Behind-the-Meter Net Generation Resource's Average Coincident Host Load for the prior Summer Capability Period and the Winter Capability Period before that.

5.12.6.1.2.1 Average Coincident Host Load

The ISO must receive the Behind-the-Meter Net Generation Resource's applicable metered Load data required to calculate an Average Coincident Host Load in accordance with ISO Procedures. The ISO shall compute the Average Coincident Host Load for each Capability Year (i) using the metered Host Load data for the applicable NYCA peak Load hours, except as provided below in this Section, and (ii) adjusted for weather normalization and Load growth as determined by the ISO in relation to developing the NYCA Minimum Installed Capacity Requirement in accordance with ISO Procedures.

For each Capability Year, the NYISO shall use the average of the highest twenty (20) one-hour peak Loads of the Host Load of the Behind-the-Meter Net Generation Resource that occur during the top forty (40) NYCA peak Load hours of the prior Summer Capability Period and the Winter Capability Period before that to calculate the Average Coincident Host Load.

If a facility meets the criteria to be, and has not previously been, a Behind-the-Meter Net Generation Resource, but does not have all of the appropriate meter data, its Average Coincident Host Load shall be a value forecasted by the Behind-the-Meter Net Generation Resource. The Behind-the-Meter Net Generation Resource's forecast shall be based on actual meter data, or if not available, billing data or other business data of the Host Load. An estimated Average Coincident Host Load can only be applicable to a Behind-the-Meter Net Generation Resource until actual data becomes available, but in any event no longer than three (3) consecutive Capability Years beginning with the Capability Year it is first an Installed Capacity Supplier.

5.12.6.1.2.2 Determination of Adjusted Host Load

After the ISO has calculated a Behind-the-Meter Net Generation Resource's Average Coincident Host Load, it shall then apply the NYCA Installed Reserve Margin. The Behind-the-Meter Net Generation Resource's Adjusted Host Load will be established by multiplying the Resource's Average Coincident Host Load for the Capability Year by the quantity of one plus the NYCA Installed Reserve Margin.

5.12.6.2 UCAP Calculations

The ISO shall calculate for each Resource the amount of Unforced Capacity that each Installed Capacity Supplier is qualified to supply in the NYCA in accordance with formulae provided in the ISO Procedures.

The amount of Unforced Capacity that each Generator, except for the Generator of a Behind-the-Meter Net Generation Resource, System Resource, Energy Limited Resource, Special Case Resource, and municipally-owned generation is authorized to supply in the NYCA shall be based on the ISO's calculations of individual Equivalent Demand Forced Outage Rates. The amount of Unforced Capacity that each Energy Storage Resource is authorized to supply in the NYCA shall be based on the individual availability of the Energy Storage Resource in the Real-Time Market and calculated by the ISO in accordance with ISO Procedures. Except as provided in Section 5.12.6.2.1 of this Services Tariff, this calculation shall not include hours in any month that the Energy Storage Resource was in an outage state that started on or after May 1, 2015 and that precluded its eligibility to participate in the Installed Capacity market. The amount of Unforced Capacity that each Control Area System Resource is authorized to supply in the NYCA shall be based on the ISO's calculation of each Control Area System Resource's availability. The amount of Unforced Capacity that each Intermittent Power Resource is

authorized to supply in the NYCA shall be based on the NYISO's calculation of the amount of capacity that the Intermittent Power Resource can reliably provide during system peak Load hours in accordance with ISO Procedures. Except as provided in Section 5.12.6.2.1 of this Services Tariff, this calculation shall not include hours in any month that the Intermittent Power Resource was in an outage state that started on or after May 1, 2015 and that precluded its eligibility to participate in the Installed Capacity market. The amount of Unforced Capacity that each Limited Control Run-of-River Hydro Resource is authorized to provide in the NYCA shall be determined separately for Summer and Winter Capability Periods as the rolling average of the hourly net Energy provided by each such Resource during the 20 highest NYCA integrated real-time load hours in each of the five previous Summer or Winter Capability Periods, as appropriate, stated in megawatts. Except as provided in Section 5.12.6.2.1 of this Services Tariff, for a Limited Control Run-of-River Hydro Resource in an outage state that started on or after May 1, 2015 and that precluded its eligibility to participate in the Installed Capacity market during one of the 20 highest NYCA integrated real-time load hours in any one of the five previous Summer or Winter Capability Periods, the ISO shall replace that Winter or Summer Capability Period, as appropriate, with the next most recent Winter or Summer Capability Period such that the rolling average of the hourly net Energy provided by each such Resource shall be calculated from the 20 highest NYCA integrated real-time load hours in the five most recent prior Summer or Winter Capability Periods in which the Resource was not in an outage state that precluded its eligibility to participate in the Installed Capacity market on one of the 20 highest NYCA integrated real-time load hours in that Capability Period.

The ISO shall calculate separate Summer and Winter Capability Period Unforced Capacity values for each Generator, System Resource, Special Case Resource, Energy Limited

Resource, and municipally owned generation and update them periodically using a twelve-month calculation in accordance with formulae provided in the ISO Procedures; provided, however, except as provided in Section 5.12.6.2.1 of this Services Tariff, for a Generator in an outage state that started on or after May 1, 2015 and that precluded its eligibility to participate in the Installed Capacity market at any time during any month from which GADS or other operating data would otherwise be used to calculate an individual Equivalent Demand Forced Outage Rate, the ISO shall replace such month's GADS or other operating data with GADS or other operating data from the most recent prior month in which the Generator was not in an outage state that precluded its eligibility to participate in the Installed Capacity market.

The ISO shall calculate separate Summer and Winter Capability Period Unforced Capacity values for Energy Storage Resource and update them seasonally as described in ISO Procedures.

The ISO shall calculate separate Summer and Winter Capability Period Unforced Capacity values for Intermittent Power Resources and update them seasonally as described in ISO Procedures.

The amount of Unforced Capacity that each Behind-the-Meter Net Generation Resource is authorized to supply in the NYCA shall be its Net-UCAP. Net-UCAP is the lesser of (i) the ISO's calculation of the Generator of the Behind-the-Meter Net Generation Resource Adjusted DMGC multiplied by one minus its Equivalent Demand Forced Outage Rate, and then decreased by its Adjusted Host Load translated into Unforced Capacity terms consistent with Section 5.11.1 of this Tariff, and (ii) the Resource's Net-ICAP.

5.12.6.2.1 Exceptions

A Generator returning to the Energy market after taking an outage that precluded its

participation in the Installed Capacity market and which returns with modifications to its operating characteristics determined by the ISO to be material and which, therefore, requires the submission of a new Interconnection Request will receive, as the initial derating factor for calculation of the Generator's Unforced Capacity upon its return to service, the derating factor it would have received as a newly connecting unit in lieu of a derating factor developed from unit-specific data. A Generator returning to the Energy market after taking an outage that precluded its participation in the Installed Capacity market and which, upon its return, uses as its primary fuel a fuel not previously used at the facility for any purpose other than for ignition purposes will receive, as the initial derating factor for calculation of the Generator's Unforced Capacity upon its return to service, the NERC class average derating factor in lieu of a derating factor developed from unit-specific data even if the modifications to allow use of a new primary fuel are not material and do not require the submission of a new Interconnection Request.

This Section 5.12.6.2.1 shall apply to a Generator returning to the Energy market after taking an outage that started on or after May 1, 2015 and that precluded its participation in the Installed Capacity market.

5.12.6.3 Default Unforced Capacity

In its calculation of Unforced Capacity, the ISO shall deem a Resource to be completely forced out for each month for which the Resource has not submitted its Operating Data in accordance with Section 5.12.5 of this Tariff and the ISO Procedures. A Resource that has been deemed completely forced out for a particular month may submit new Operating Data, for that month, to the ISO at any time. The ISO will use such new Operating Data when calculating, in a timely manner in accordance with the ISO Procedures, a Unforced Capacity value for the Resource.

Upon a showing of extraordinary circumstances, the ISO retains the discretion to accept at any time Operating Data which have not been submitted in a timely manner, or which do not fully conform with the ISO Procedures.

5.12.6.4 Exception for Certain Equipment Failures

When a Generator, Special Case Resource, Energy Limited Resource, or System Resource is forced into an outage by an equipment failure that involves equipment located on the high voltage side of the electric network beyond the step-up transformer, and including such step-up transformer, the outage will not be counted for purposes of calculating that Resource's Equivalent Demand Forced Outage Rate.

5.12.6.5 Unforced Capacity, Outage Data and Operational Information Associated with External-to-ROS Deliverability Rights

The ISO shall calculate the availability of the External interface associated with each project granted EDRs, in accordance with ISO Procedures. The availability factor (percentage) of the interface will be used to reduce the amount of EDRs for which Unforced Capacity may be offered. This calculation is distinct from and in addition to the calculation the ISO performs for each Installed Capacity Resource qualified for use with EDRs.

5.12.7 Availability Requirements

Subsequent to qualifying, each Installed Capacity Supplier shall, except as noted in Section 5.12.11 of this Tariff, on a daily basis: (i) schedule a Bilateral Transaction; (ii) Bid Energy in each hour of the Day-Ahead Market in accordance with the applicable provisions of Section 5.12.1 of this Tariff; or (iii) notify the ISO of any outages. An RMR Generator can only schedule a Bilateral Transaction to the extent expressly authorized in its RMR Agreement. The total amount of Energy that an Installed Capacity Supplier schedules, bids, or declares to be

unavailable on a given day must equal or exceed the Installed Capacity Equivalent of the Unforced Capacity it supplies. For Energy Storage Resources, the total amount of Energy that is scheduled, Bid, or declared to be unavailable shall also include the maximum of the Energy Storage Resource's (i) negative Installed Capacity Equivalent, or (ii) Lower Operating Limit, such that amount scheduled, Bid, or declared to be unavailable reflects the entire withdrawal to injection operating range.

5.12.8 Unforced Capacity Sales

Each Installed Capacity Supplier will, after satisfying the deliverability requirements set forth in the applicable provisions of Attachment X, Attachment Z and Attachment S to the ISO OATT, be authorized to supply an amount of Unforced Capacity during each Obligation Procurement Period, based on separate seasonal Unforced Capacity calculations performed by the ISO for the Summer and Winter Capability Periods. Unforced Capacity may be sold in six-month strips, or in monthly, or multi-monthly segments.

External Unforced Capacity (except External Installed Capacity associated with UDRs) may only be offered into Capability Period Auctions or Monthly Auctions for the Rest of State, and ICAP Spot Market Auctions for the NYCA, and may not be offered into a Locality for an ICAP Auction. Bilateral Transactions which certify External Unforced Capacity using Import Rights, EDRs, or External CRIS Rights may not be used to satisfy a Locational Minimum Unforced Capacity Requirement.

UCAP from an RMR Generator may only be offered into the ICAP Spot Market Auction, except and only to the extent that the RMR Agreement expressly permits the RMR Generator's UCAP to be certified in a Bilateral Transaction.

If an Energy Limited Resource's, Generator's, System Resource's or Control Area System Resource's DMNC rating, or the DMGC rating of a Generator of a Behind-the-Meter Net Generation Resource, if applicable, is determined to have increased during an Obligation Procurement Period, pursuant to testing procedures described in the ISO Procedures, the amount of Unforced Capacity that it shall be authorized to supply in that or future Obligation Procurement Periods shall also be increased on a prospective basis in accordance with the schedule set forth in the ISO Procedures provided that it first has satisfied the deliverability requirements set forth in the applicable provisions of Attachment X, Attachment Z and Attachment S to the ISO OATT.

New Generators and Generators that have increased their Capacity since the previous Summer Capability Period due to changes in their generating equipment may, after satisfying the deliverability requirements set forth in the applicable provisions of Attachment X, Attachment Z and Attachment S to the ISO OATT, qualify to supply Unforced Capacity on a foregoing basis during the Summer Capability Period based upon a DMNC test, or the DMGC test of a Generator of a Behind-the-Meter Net Generation Resource, that is performed and reported to the ISO after March 1 and prior to the beginning of the Summer Capability Period DMNC Test Period. The Generator will be required to verify the claimed DMNC or DMGC rating by performing an additional test during the Summer DMNC Test Period. Any shortfall between the amount of Unforced Capacity supplied by the Generator for the Summer Capability Period and the amount verified during the Summer DMNC Test Period will be subject to deficiency charges pursuant to Section 5.14.2 of this Tariff. The deficiency charges will be applied to no more than the difference between the Generator's previous Summer Capability Period Unforced Capacity

and the amount of Unforced Capacity equivalent the Generator supplied for the Summer Capability Period.

New Generators and Generators that have increased their Capacity since the previous Winter Capability Period due to changes in their generating equipment may, after satisfying the deliverability requirements set forth in the applicable provisions of Attachment X, Attachment Z and Attachment S to the ISO OATT, qualify to supply Unforced Capacity on a foregoing basis during the Winter Capability Period based upon a DMNC test, or the DMGC test of a Generator of a Behind-the-Meter Net Generation Resource, that is performed and reported to the ISO after September 1 and prior to the beginning of the Winter Capability Period DMNC Test Period. The Generator will be required to verify the claimed DMNC or DMGC rating by performing an additional test during the Winter Capability Period DMNC Test Period. Any shortfall between the amount of Unforced Capacity certified by the Generator for the Winter Capability Period and the amount verified during the Winter Capability Period DMNC Test Period will be subject to deficiency charges pursuant to Section 5.14.2 of this Tariff. The deficiency charges will be applied to no more than the difference between the Generator's previous Winter Capability Period Unforced Capacity and the amount of Unforced Capacity equivalent the Generator supplied for the Winter Capability Period.

Any Installed Capacity Supplier, except as noted in Section 5.12.11 of this ISO Services Tariff, which fails on a daily basis to schedule, Bid, or declare to be unavailable in the Day-Ahead Market an amount of Unforced Capacity, expressed in terms of Installed Capacity Equivalent, that it certified for that day, rounded down to the nearest 0.1 MW, or rounded down to the nearest whole MW for an External Installed Capacity Supplier, is subject to sanctions pursuant to Section 5.12.12.2 of this Tariff. If an entity other than the owner of an Energy

Limited Resource, Generator, System Resource, Behind-the-Meter Net Generation Resource, or Control Area System Resource that is providing Unforced Capacity is responsible for fulfilling bidding, scheduling, and notification requirements, the owner and that entity must designate to the ISO which of them will be responsible for complying with the scheduling, bidding, and notification requirements. The designated bidding and scheduling entity shall be subject to sanctions pursuant to Section 5.12.12.2 of this ISO Services Tariff.

5.12.9 Sales of Unforced Capacity by System Resources

Installed Capacity Suppliers offering to supply Unforced Capacity associated with Internal System Resources shall submit for each of their Resources the Operating Data and DMNC testing data or historical data described in Sections 5.12.1 and 5.12.5 of this ISO Services Tariff in accordance with the ISO Procedures. Such Installed Capacity Suppliers will be allowed to supply the amount of Unforced Capacity that the ISO determines pursuant to the ISO Procedures to reflect the appropriate Equivalent Demand Forced Outage Rate. Installed Capacity Suppliers offering to sell the Unforced Capacity associated with System Resources may only aggregate Resources in accordance with the ISO Procedures.

5.12.10 Curtailment of External Transactions In-Hour

All Unforced Capacity that is not out of service, or scheduled to serve the Internal NYCA Load in the Day-Ahead Market may be scheduled to supply Energy for use in External Transactions provided, however, that such External Transactions shall be subject to Curtailment within the hour, consistent with ISO Procedures. Such Curtailment shall not exceed the Installed Capacity Equivalent committed to the NYCA.

5.12.11 Responsible Interface Parties, Municipally-Owned Generation, Energy Limited Resources and Intermittent Power Resources

5.12.11.1 Responsible Interface Parties

Responsible Interface Parties may qualify as Installed Capacity Suppliers, without having to comply with the daily bidding, scheduling, and notification requirements set forth in Section 5.12.7 of this Tariff, if their Special Case Resources are available to operate at the direction of the ISO in order to reduce Load from the NYS Transmission System and/or the distribution system for a minimum of four (4) consecutive hours each day, except for those subject to operating limitations established by environmental permits, which will not be required to operate in excess of two (2) hours and which will be derated by the ISO pursuant to ISO Procedures to account for the Load serving equivalence of the hours actually available, following notice of the potential need to operate twenty-one (21) hours in advance if notification is provided by 3:00 P.M. ET, or twenty-four (24) hours in advance otherwise, and a notification to operate two (2) hours ahead. In order for a Responsible Interface Party to enroll an SCR that uses an eligible Local Generator, any amount of generation that can reduce Load from the NYS Transmission System and/or distribution system at the direction of the ISO that was produced by the Local Generator during the hour coincident with the NYCA or Locality peaks, upon which the LSE Unforced Capacity Obligation of the LSE that serves that SCR is based, must be accounted for when the LSE's Unforced Capacity Obligation for the upcoming Capability Year is established. Responsible Interface Parties must provide this generator data in accordance with ISO Procedures so that the ISO can adjust upwards the LSE Unforced Capacity Obligation to prevent double-counting.

Responsible Interface Parties supplying Unforced Capacity cannot offer the Demand Reduction associated with such Unforced Capacity in the Emergency Demand Response

Program. A Resource with sufficient metering to distinguish MWs of Demand Reduction may participate as a Special Case Resource and in the Emergency Demand Response Program provided that the same MWs are not committed both as Unforced Capacity and to the Emergency Demand Response Program.

The ISO will have discretion, pursuant to ISO Procedures, to exempt Local Generators that are incapable of starting in two (2) hours from the requirement to operate on two (2) hours notification. Local Generators that can be operated to reduce Load from the NYS Transmission System and/or distribution system at the direction of the ISO and Loads capable of being interrupted upon demand, that are not available on certain hours or days will be derated by the ISO, pursuant to ISO Procedures, to reflect the Load serving equivalence of the hours they are actually available.

Responsible Interface Parties must submit a Minimum Payment Nomination, in accordance with ISO Procedures. The ISO may request Special Case Resource performance from less than the total number of Special Case Resources within the NYCA or a Load Zone in accordance with ISO Procedures.

Local Generators that can be operated to reduce Load from the NYS Transmission System and/or distribution system at the direction of the ISO and Loads capable of being interrupted upon demand will be required to comply with verification and validation procedures set forth in the ISO Procedures. Such procedures will not require metering other than interval billing meters on customer Load or testing other than DMNC or sustained disconnect, as appropriate, unless agreed to by the customer, except that Special Case Resources not called to supply Energy in a Capability Period will be required to run a test once every Capability Period in accordance with the ISO Procedures.

Unforced Capacity supplied in a Bilateral Transaction by a Special Case Resource pursuant to this subsection may only be resold if the purchasing entity or the Installed Capacity Marketer has agreed to become a Responsible Interface Party and comply with the ISO notification requirements for Special Case Resources. LSEs and Installed Capacity Marketers may become Responsible Interface Parties and aggregate Special Case Resources and sell the Unforced Capacity associated with them in an ISO-administered auction if they comply with ISO notification requirements for Special Case Resources.

Responsible Interface Parties that were requested to reduce Load in any month shall submit performance data to the NYISO, within 75 days of each called event or test, in accordance with ISO Procedures. Failure by a Responsible Interface Party to submit performance data for any Special Case Resources required to respond to the event or test within the 75-day limit will result in zero performance attributed to those Special Case Resources for purposes of satisfying the Special Case Resource's capacity obligation as well as for determining energy payments. All performance data are subject to audit by the NYISO and its market monitoring unit. If the ISO determines that it has made an erroneous payment to a Responsible Interface Party, the ISO shall have the right to recover it either by reducing other payments to that Responsible Interface Parties or by resolving the issue pursuant to other provisions of this Services Tariff or other lawful means.

Provided the Responsible Interface Party supplies evidence of such reductions in 75 days, the ISO shall pay the Responsible Interface Party that, through their Special Case Resources, caused a verified Load reduction in response to (i) an ISO request to perform due to a forecast reserve shortage (ii) an ISO declared Major Emergency State, (iii) an ISO request to perform made in response to a request for assistance for Load relief purposes or as a result of a Local

Reliability Rule, or (iv) a test called by the ISO, for such Load reduction, in accordance with ISO Procedures. Subject to performance evidence and verification, in the case of a response pursuant to clauses (i), (ii), of (iii) of this subsection, Suppliers that schedule Responsible Interface Parties shall be paid the zonal Real-Time LBMP for the period of requested performance or four (4) hours, whichever is greater, in accordance with ISO Procedures; provided, however, Special Case Resource Capacity shall settle Demand Reductions, in the interval and for the capacity for which Special Case Resource Capacity has been scheduled Day-Ahead to provide Operating Reserves, Regulation Service or Energy, as being provided by a Supplier of Operating Reserves, Regulation Service or Energy.

In the event that a Responsible Interface Party's Minimum Payment Nomination for a Special Case Resource, for the number of hours of requested performance or the minimum four (4) hour period, whichever is greater, exceeds the LBMP revenue received, the Special Case Resource will be eligible for a Bid Production Cost Guarantee to make up the difference, in accordance with Section 4.23 of this Services Tariff and ISO Procedures; provided, however, the ISO shall set to zero the Minimum Payment Nomination for Special Case Resource Capacity in each interval in which such Capacity was scheduled Day-Ahead to provide Operating Reserves, Regulation Service or Energy. Subject to performance evidence and verification, in the case of a response pursuant to clause (iv) of this subsection, payment for participation in tests called by the ISO shall be equal to the zonal Real Time LBMP for the MWh of Energy reduced within the test period.

Transmission Owners that require assistance from enrolled Local Generators larger than 100 kW and Loads capable of being interrupted upon demand for Load relief purposes or as a result of a Local Reliability Rule, shall direct their requests for assistance to the ISO for

implementation consistent with the terms of this section. Within Load Zone J, participation in response to an ISO request to perform made as a result of a request for assistance from a Transmission Owner for less than the total number of Special Case Resources, for Load relief purposes or as a result of a Local Reliability Rule, in accordance with ISO Procedures, shall be voluntary and the responsiveness of the Special Case Resource shall not be taken into account for performance measurement.

5.12.11.1.1 Special Case Resource Average Coincident Load

The ISO must receive from the Responsible Interface Party that enrolls a Special Case Resource, the applicable metered Load data required to calculate an ACL for that SCR as provided below and in accordance with ISO Procedures. The ACL shall be computed using the metered Load for the applicable Capability Period SCR Load Zone Peak Hours that indicates the Load consumed by each SCR that is supplied by the NYS Transmission System and/or distribution system and is exclusive of any generation produced by a Local Generator, other behind-the-meter generator, or other supply source located behind the SCR's meter, that served some of the SCR's Load.

Beginning with the Winter 2011-2012 Capability Period and thereafter, the ISO shall use the average of the highest twenty (20) one-hour peak Loads of the SCR taken from the Load data reported for the Capability Period SCR Load Zone Peak Hours during the Prior Equivalent Capability Period, and taking into account the resource's reported verified Load reduction in a Transmission Owner's demand response program in hours coincident with any of these hours, to create a SCR ACL baseline. In addition, beginning with the Summer 2014 Capability Period, the resource's verified Load reduction in either of the ISO's economic demand response programs (the Day Ahead Demand Response Program and the Demand Side Ancillary Services Program)

in hours coincident with any of the applicable Capability Period SCR Load Zone Peak Hours will be taken into account when creating the SCR ACL. For the Day Ahead Demand Response Program, the verified Load reduction that occurred in response to a DADRP schedule shall be added to the Capability Period SCR Load Zone Peak Hour for which the reduction in response to a DADRP schedule occurred. For the Demand Side Ancillary Services Program, the Load value to be used in calculating the ACL for each hour during the Capability Period SCR Load Zone Peak Hours in which a non-zero Base Point Signal the ISO provides to the resource, shall be the greater of (a) the DSASP Baseline MW value in the interval immediately preceding the first non-zero Base Point Signal in the Capability Period SCR Load Zone Peak Hour and (b) the metered Load of the resource as reported by the RIP for the Capability Period SCR Load Zone Peak Hour. When the non-zero Base Point Signal dispatch of a DSASP resource begins in one hour and continues into consecutive hours, and the consecutive hour is identified as being a Capability Period SCR Load Zone Peak Hour, the DSASP Baseline MW value in effect at the beginning of the dispatch of the non-zero Base Point Signal shall be the MW value used for purposes of determining the applicable Load value for that Capability Period SCR Load Zone Peak Hour, in accordance with the preceding sentence. The ISO will post to its website the Capability Period SCR Load Zone Peak Hours for each zone ninety (90) days prior to the beginning of the Capability Period for which the ACL will be in effect.

In the SCR enrollment file uploaded by the RIP each month within the Capability Period, among other required information, the RIP shall provide the SCR's metered Load values for the applicable Capability Period SCR Load Zone Peak Hours necessary to compute the ACL for each SCR.

The exception to this requirement to report the required metered Load data for the ACL, when enrolling a SCR prior to the Summer 2014 Capability Period, is if (i) the SCR has not previously been enrolled with the ISO and (ii) never had interval metering Load data for each month in the Prior Equivalent Capability Period needed to compute the SCR's ACL. Beginning with the Summer 2014 Capability Period, the exception to this requirement to report the required metered Load data for the ACL, is dependent upon one or more of the eligibility conditions for SCR enrollment with a Provisional ACL provided in Section 5.12.11.1.2 of this Services Tariff and ISO Procedures. For SCRs that meet the criteria to enroll with a Provisional ACL, the ISO must receive from the RIP a Provisional ACL as provided in Section 5.12.11.1.2 of this Services Tariff and in accordance with ISO Procedures.

Beginning with the Summer 2014 Capability Period, in addition to the requirement for RIPs to report each SCR's metered Load values that occurred during the Capability Period SCR Load Zone Peak Hours, in accordance with this Services Tariff and ISO Procedures during the enrollment process, any qualifying increase in a SCR's Load that will be supplied by the NYS Transmission System and/or distribution system may be reported as an Incremental ACL, subject to the limitations and verification reporting requirements provided in Section 5.12.11.1.5 of this Services Tariff and in accordance with ISO Procedures. Incremental ACL values must be reported using the required enrollment file that may be uploaded by the RIP during each month's enrollment period. RIPs may not report Incremental ACL values for any SCRs that are enrolled in the Capability Period with a Provisional ACL.

A reduction in a SCR's Load that is supplied by the NYS Transmission System and/or distribution system and meets the criteria for a SCR Change of Status must be reported as a SCR

Change of Status as provided by Section 5.12.11.1.3 of this Services Tariff and in accordance with ISO Procedures.

The ACL is the basis for the upper limit of ICAP, except in circumstances when the SCR has reported a SCR Change of Status or reported an Incremental ACL pursuant to Sections 5.12.11.1.3 and 5.12.11.1.5 of this Services Tariff. The basis for the upper limit of ICAP for a SCR that has experienced a SCR Change of Status or reported an Incremental ACL shall be the Net ACL.

5.12.11.1.2 Use of a Provisional Average Coincident Load

Prior to the Summer 2014 Capability Period, as provided in Section 5.12.11.1.1 of this Services Tariff, if a new Special Case Resource has not previously been enrolled with the ISO and never had interval billing meter data from the Prior Equivalent Capability Period, its Installed Capacity value shall be its Provisional Average Coincident Load for the Capability Period for which the new SCR is enrolled. The Provisional ACL may be applicable to a new SCR for a maximum of three (3) consecutive Capability Periods, beginning with the Capability Period in which the SCR is first enrolled.

Beginning with the Summer 2014 Capability Period, a SCR may be enrolled using a Provisional ACL in lieu of an ACL when one of the following conditions has been determined by the ISO to apply: (i) the SCR has not previously been enrolled with the ISO for the seasonal Capability Period for which the SCR enrollment with a Provisional ACL is intended, (ii) the SCR was enrolled with a Provisional ACL in the Prior Equivalent Capability Period and was required to report fewer than twenty (20) hours of metered Load verification data that correspond with the Capability Period SCR Load Zone Peak Hours based on the meter installation date of the SCR, (iii) the RIP attempting to enroll the SCR with a Provisional ACL is not the same RIP

that enrolled the SCR in the Prior Equivalent Capability Period and interval billing meter data for the SCR from the Prior Equivalent Capability Period is not obtainable by the enrolling RIP and not available to be provided to the enrolling RIP by the ISO. The Provisional ACL may be applicable to a SCR for a maximum of three (3) consecutive Capability Periods when enrolled with the same RIP, beginning with the Capability Period in which the SCR is first enrolled by the RIP.

A SCR enrolled in the Capability Period with a Provisional ACL may not be enrolled by another RIP for the remainder of the Capability Period and the Provisional ACL value shall apply to the resource for the entire Capability Period for which the value is established.

The Provisional ACL is the RIP's forecast of the SCR's ACL and shall be the basis for the upper limit of ICAP for which the RIP may enroll the SCR during the Capability Period.

Any SCR enrolled with a Provisional ACL shall be subject to actual in-period verification. A Verified ACL shall be calculated by the ISO using the top twenty (20) one-hour peak Loads reported for the SCR from the Capability Period SCR Load Zone Peak Hours that are applicable to verify the Provisional ACL in accordance with ISO Procedures and taking into account the resource's reported verified Load reductions in a Transmission Owner's demand response program that are coincident with any of the applicable Capability Period SCR Load Zone Peak Hours. In addition, beginning with the Summer 2014 Capability Period, the resource's verified Load reduction in either of the ISO's economic demand response programs (the Day Ahead Demand Response Program and the Demand Side Ancillary Services Program) in hours coincident with any of the applicable Capability Period SCR Load Zone Peak Hours will be taken into account when creating the SCR Verified ACL. For the Day Ahead Demand Response Program, the verified Load reduction that occurred in response to a DADRP schedule

shall be added to the Capability Period SCR Load Zone Peak Hour for which the reduction in response to a DADRP schedule occurred. For the Demand Side Ancillary Services Program, the Load value to be used in calculating the Verified ACL for each hour during the Capability Period SCR Load Zone Peak Hours in which a non-zero Base Point Signal the ISO provides to the resource, shall be the greater of (a) the DSASP Baseline MW value in the interval immediately preceding the first non-zero Base Point Signal in the Capability Period SCR Load Zone Peak Hour and (b) the metered Load of the resource as reported by the RIP for the Capability Period SCR Load Zone Peak Hour. When the non-zero Base Point Signal dispatch of a DSASP resource begins in one hour and continues into consecutive hours, and the consecutive hour is identified as being a Capability Period SCR Load Zone Peak Hour, the DSASP Baseline MW value in effect at the beginning of the dispatch of the non-zero Base Point Signal shall be the MW value used for purposes of determining the applicable Load value for that Capability Period SCR Load Zone Peak Hour, in accordance with the preceding sentence.

Following the Capability Period for which a resource with a Provisional ACL was enrolled, the RIP shall provide to the ISO the metered Load data required to compute the Verified ACL of the resource. The ISO shall compare the Provisional ACL to the Verified ACL to determine, after applying the applicable performance factor, whether the UCAP of the SCR had been oversold and whether a shortfall has occurred as provided under Section 5.14.2 of this Services Tariff. If the RIP fails to provide verification data required to compute the Verified ACL of the resource enrolled with a Provisional ACL by the deadline: (a) the Verified ACL of the resource shall be set to zero for each Capability Period in which the resource with a Provisional ACL was enrolled and verification data was not reported, and (b) the RIP may be subject to penalties in accordance with this Services Tariff.

5.12.11.1.3 Reporting a SCR Change of Load or SCR Change of Status

5.12.11.1.3.1 SCR Change of Load

The Responsible Interface Party shall report any SCR Change of Load in accordance with ISO Procedures. The RIP is required to document the SCR Change of Load and when the total Load reduction for SCRs that have a SCR Change of Load within the same Load Zone is greater than or equal to 5 MWs, the RIP shall report the SCR Change of Load for each SCR in accordance with ISO Procedures.

5.12.11.1.3.2 SCR Change of Status

The Responsible Interface Party shall report any SCR Change of Status in accordance with ISO Procedures. The ISO shall adjust the reported ACL of the SCR for a reported SCR Change of Status to the Net ACL, for all prospective months to which the SCR Change of Status is applicable. When a SCR Change of Status is reported under clause (i), (ii) or (iii) within the definition of a Qualified Change of Status Condition and the SCR has sold capacity, the SCR shall be evaluated for a potential shortfall under Section 5.14.2 of this Services Tariff. Failure by the RIP to report a SCR Change of Status shall be evaluated as a potential shortfall under Section 5.14.2 of this Service Tariff and evaluated for failure to report under Section 5.12.12.2 of this Services Tariff.

Beginning with the Summer 2014 Capability Period, SCRs that were required to perform in the first performance test in the Capability Period in accordance with ISO Procedures and that subsequently report or change a reported SCR Change of Status value after the first performance test in the Capability Period shall be required to demonstrate the performance of the resource against the Net ACL value in the second performance test in the Capability Period. The exceptions to this provision occur when a SCR's eligible Installed Capacity is set to zero

throughout the period of the SCR Change of Status, when a SCR's eligible Installed Capacity is decreased by at least the same kW value as the reported SCR Change of Status, or if a SCR Change of Status is reported, and prior to the second performance test, the SCR returns to the full applicable ACL enrolled prior to the SCR Change of Status. Performance in both performance tests shall be used in calculation of the resource's performance factors and all associated performance factors, deficiencies and penalties. If the RIP fails to report the performance for a resource that was required to perform in the second performance test in the Capability Period: (a) the resource will be assigned a performance of zero (0) for the test hour, and (b) the RIP shall be evaluated for failure to report under Section 5.12.12.2 of this Services Tariff.

5.12.11.1.4 Average Coincident Load of an SCR Aggregation

The ISO shall compute the Average Coincident Load of an SCR Aggregation each month in accordance with ISO Procedures.

5.12.11.1.5 Use of an Incremental Average Coincident Load

Beginning with the Summer 2014 Capability Period, a Responsible Interface Party may report any qualifying increase to a Special Case Resource's Average Coincident Load as Incremental Average Coincident Load in the RIP enrollment file upload and in accordance with this Services Tariff and ISO Procedures.

For SCRs with a total Load increase equal to or greater than twenty (20) percent and less than thirty (30) percent of the applicable ACL, the RIP may enroll the SCR with an Incremental ACL provided that the eligible Installed Capacity does not increase from the prior enrollment months within the same Capability Period and prior to enrollment with an Incremental ACL. If the SCR is enrolled with an Incremental ACL and it is the first month of the SCR's enrollment in the applicable Capability Period, the enrolled eligible Installed Capacity value shall not exceed

the maximum eligible Installed Capacity of the SCR from the Prior Equivalent Capability Period. When no enrollment exists for the SCR in the Prior Equivalent Capability Period and it is the first month of the SCR's enrollment in the applicable Capability Period, the enrolled eligible Installed Capacity of the SCR shall not exceed the ACL calculated from the Capability Period SCR Load Zone Peak Hours. For SCRs with a total Load increase equal to or greater than thirty (30) percent of the applicable ACL, the RIP may enroll the SCR with an Incremental ACL and an increase to the SCR's eligible Installed Capacity and is required to test as described in this section of the Service Tariff.

The ISO shall adjust the ACL of the SCR for an Incremental ACL for all months for which the Incremental ACL is reported by the RIP. For resources reporting an Incremental ACL, the Net ACL shall equal the enrolled ACL plus the reported Incremental ACL less any applicable SCR Change of Status and shall be the basis for the upper limit of ICAP for which the RIP may enroll the SCR during the Capability Period.

An Incremental ACL is a discrete change to the SCR operations that is expected to result in an increase to the Load that the SCR will consume from the NYS Transmission System and/or distribution system. It is not available to account for random fluctuations in Load, such as those caused by weather or other seasonal Load variations. Therefore, the ACL of a SCR may only be increased once per Capability Period and the amount of the increase enrolled must remain the same for all months for which the Incremental ACL is reported. A SCR enrolled in the Capability Period with an Incremental ACL may not be enrolled by another RIP for the remainder of the Capability Period. A SCR enrolled in the Capability Period with a Provisional ACL is not eligible to enroll with an Incremental ACL.

Following the Capability Period for which a SCR has been enrolled with an Incremental ACL, the RIP shall provide the hourly metered Load verification data that corresponds to the Monthly SCR Load Zone Peak Hours identified by the ISO for all months in which an Incremental ACL value was reported for the SCR. For each month for which verification data was required to be reported, the ISO shall calculate a Monthly ACL that will be used in the calculation of a Verified ACL. The Monthly ACL shall equal the average of the SCR's top twenty (20) one-hour metered Load values that correspond with the applicable Monthly SCR Load Zone Peak Hours, and taking into account (i) the resource's reported verified Load reduction in a Transmission Owner's demand response program in hours coincident with any of these hours and (ii) the resource's verified Load reduction in either of the ISO's economic demand response programs (the Day Ahead Demand Response Program and the Demand Side Ancillary Services Program) in hours coincident with any of these hours. For the Day Ahead Demand Response Program, the verified Load reduction that occurred in response to a DADRP schedule shall be added to the Monthly SCR Load Zone Peak Hour for which the reduction in response to a DADRP schedule occurred. For the Demand Side Ancillary Services Program, the Load value to be used in calculating the Monthly ACL for each hour during the Monthly SCR Load Zone Peak Hours in which a non-zero Base Point Signal the ISO provides to the resource, shall be the greater of (a) the DSASP Baseline MW value in the interval immediately preceding the first non-zero Base Point Signal in the Monthly SCR Load Zone Peak Hour and (b) the metered Load of the resource as reported by the RIP for the Monthly SCR Load Zone Peak Hour. When the non-zero Base Point Signal dispatch of a DSASP resource begins in one hour and continues into consecutive hours, and the consecutive hour is identified as being a Monthly SCR Load Zone Peak Hour, the DSASP Baseline MW value in effect at the beginning of the dispatch

of the non-zero Base Point Signal shall be the MW value used for purposes of determining the applicable Load value for that Monthly SCR Load Zone Peak Hour, in accordance with the preceding sentence. The Verified ACL shall be the average of the two (2) highest Monthly ACLs during the Capability Period in which the SCR was enrolled with an Incremental ACL within the same Capability Period.

For any month in which verification data for the Incremental ACL is required but not timely submitted to the ISO in accordance with ISO procedures, the ISO shall set the metered Load values to zero. When a Monthly ACL is set to zero, the Verified ACL will be calculated as the average of: a) the two (2) highest Monthly ACLs during the Capability Period in which the SCR was enrolled with an Incremental ACL within the same Capability Period; plus b) the Monthly ACLs for all months in which the SCR was enrolled within the same Capability Period with an Incremental ACL in the Capability Period in which the RIP failed to provide the minimum verification data required. In addition, a RIP may be subject to a penalty for each month for which verification data was required and not reported in accordance with this Services Tariff.

For each SCR that is enrolled with an Incremental ACL, the ISO shall compare the Net ACL calculated from the resource enrollment (ACL plus Incremental ACL less any applicable SCR Change of Status) to the Verified ACL calculated for the SCR to determine if the RIP's use of an Incremental ACL may have resulted in a shortfall pursuant to Section 5.14.2.

A Special Case Resource that was required to perform in the first performance test in the Capability Period in accordance with ISO Procedures and was subsequently enrolled using an Incremental ACL and an increase in the amount of Installed Capacity that the SCR is eligible to sell, shall be required to demonstrate performance against the maximum amount of eligible

Installed Capacity reported for the SCR in the second performance test in the Capability Period. Performance in this test shall be measured from the Net ACL. Performance in both performance tests shall be used in calculation of the resource's performance factor and all associated performance factors, deficiencies and penalties. If the RIP fails to report the performance for a resource that was required to perform in the second performance test in the Capability Period: (a) the resource will be assigned a performance of zero (0) for the test hour, and (b) the RIP shall be evaluated for failure to report under Section 5.12.12.2 of this Services Tariff.

5.12.11.2 Existing Municipally-Owned Generation

A municipal utility that owns existing generation in excess of its Unforced Capacity requirement, net of NYPA-provided Capacity may, consistent with the deliverability requirements set forth in Attachment X and Attachment S to the ISO OATT, offer the excess Capacity for sale as Installed Capacity provided that it is willing to operate the generation at the ISO's request, and provided that the Energy produced is deliverable to the New York State Power System. Such a municipal utility shall not be required to comply with the requirement of Section 5.12.7 of this Tariff that an Installed Capacity Supplier bid into the Energy market or enter into Bilateral Transactions. Municipal utilities shall, however, be required to submit their typical physical operating parameters, such as their start-up times, to the ISO. This subsection is only applicable to municipally-owned generation in service or under construction as of December 31, 1999.

5.12.11.3 Energy Limited Resources

An Energy Limited Resource may, consistent with the deliverability requirements set forth in Attachment X and Attachment S to the ISO OATT, qualify as an Installed Capacity Supplier if it Bids its Installed Capacity Equivalent into the Day-Ahead Market each day and if it

is able to provide the Energy equivalent of the Unforced Capacity for at least four (4) consecutive hours each day. Energy Limited Resources shall also Bid a Normal Upper Operating Limit or Emergency Upper Operating Limit, as applicable, designating their desired operating limits. Energy Limited Resources that are not scheduled in the Day-Ahead Market to operate at a level above their bid-in upper operating limit, may be scheduled in the RTC, or may be called in real-time pursuant to a manual intervention by ISO dispatchers, who will account for the fact that Energy Limited Resource may not be capable of responding.

5.12.11.4 Intermittent Power Resources

Intermittent Power Resources that depend upon wind or solar as their fuel may qualify as Installed Capacity Suppliers, without having to comply with the daily bidding and scheduling requirements set forth in Section 5.12.7 of this Tariff, and may, consistent with the deliverability requirements set forth in Attachment X and Attachment S to the ISO OATT, claim up to their nameplate Capacity as Installed Capacity. To qualify as Installed Capacity Suppliers, such Intermittent Power Resources shall comply with the requirements of Section 5.12.1 and the outage notification requirements of 5.12.7 of this Tariff.

5.12.12 Sanctions Applicable to Installed Capacity Suppliers and Transmission Owners

Pursuant to this section, the ISO may impose financial sanctions on Installed Capacity Suppliers and Transmission Owners that fail to comply with certain provisions of this Tariff. The ISO shall notify Installed Capacity Suppliers and Transmission Owners prior to imposing any sanction and shall afford them a reasonable opportunity to demonstrate that they should not be sanctioned and/or to offer mitigating reasons why they should be subject to a lesser sanction. The ISO may impose a sanction lower than the maximum amounts allowed by this section at its

sole discretion. Installed Capacity Suppliers and Transmission Owners may challenge any sanction imposed by the ISO pursuant to the ISO Dispute Resolution Procedures.

Any sanctions collected by the ISO pursuant to this section will be applied to reduce the Rate Schedule 1 charge under this Tariff.

5.12.12.1 Sanctions for Failing to Provide Required Information

If (i) an Installed Capacity Supplier fails to provide the information required by Sections 5.12.1.1, 5.12.1.2, 5.12.1.3, 5.12.1.4, 5.12.1.7 or 5.12.1.8 of this Tariff in a timely fashion, or (ii) a Supplier of Unforced Capacity from External System Resources located in an External Control Area or from a Control Area System Resource that has agreed not to Curtail the Energy associated with such Installed Capacity, or to afford it the same Curtailment priority that it affords its own Control Area Load, fails to provide the information required for certification as an Installed Capacity Supplier established in the ISO Procedures, the ISO may take the following actions: On the first day that required information is late, the ISO shall notify the Installed Capacity Supplier that required information is past due and that it reserves the right to impose financial sanctions if the information is not provided by the end of the following day. Starting on the third day that the required information is late, the ISO may impose a daily financial sanction of up to the higher of \$500 or \$5 per MW of Installed Capacity that the Generator, System Resource, or Control Area System Resource in question is capable of providing. Starting on the tenth day that the required information is late, the ISO may impose a daily financial sanction of up to the higher of \$1000 or \$10 per MW of Installed Capacity that the Generator, System Resource, or Control Area System Resource in question is capable of providing.

If an Installed Capacity Supplier fails to provide the information required by Subsection 5.12.1.5 of this Tariff in a timely fashion, the ISO may take the following actions: On the first

calendar day that required information is late, the ISO shall notify the Installed Capacity Supplier that required information is past due and that it reserves the right to impose financial sanctions if the information is not provided by the end of that first calendar day. Starting on the second calendar day that the required information is late, the ISO may impose a daily financial sanction up to the higher of \$500 or \$5 per MW of Installed Capacity that the Generator, System Resource, or Control Area System Resource in question is capable of providing.

If a TO fails to provide the information required by Subsection 5.11.3 of this Tariff in a timely fashion, the ISO may take the following actions: On the first day that required information is late, the ISO shall notify the TO that required information is past due and that it reserves the right to impose financial sanctions if the information is not provided by the end of the following day. Starting on the third day that the required information is late, the ISO may impose a daily financial sanction up to \$5,000 a day. Starting on the tenth day that required information is late, the ISO may impose a daily financial sanction up to \$10,000.

5.12.12.2 Sanctions for Failing to Comply with Scheduling, Bidding, and Notification Requirements

On any day in which an Installed Capacity Supplier fails to comply with the scheduling, bidding, or notification requirements of Sections 5.12.1.6 or 5.12.1.10, or with Section 5.12.7 of this Tariff, or in which a Supplier of Installed Capacity from External System Resources or Control Area System Resources located in an External Control Area that has agreed not to Curtail the Energy associated with such Installed Capacity, or to afford it the same Curtailment priority that it affords its own Control Area Load, fails to comply with scheduling, bidding, or notification requirements for certification as an Installed Capacity Supplier established in the ISO Procedures, the ISO may impose a financial sanction up to the product of a deficiency charge (pro-rated on a daily basis) and the maximum number of MWs that the Installed Capacity

Supplier failed to schedule or Bid in any hour in that day provided, however, that no financial sanction shall apply to any Installed Capacity Supplier who demonstrates that the Energy it schedules, bids, or declares to be unavailable on any day is not less than the Installed Capacity that it supplies for that day rounded down to the nearest 0.1 MW, or rounded down to the nearest whole MW for an External Installed Capacity Supplier. The deficiency charge may be up to one and one-half times the applicable Market-Clearing Price of Unforced Capacity determined in the ICAP Spot Market Auction corresponding to where the Installed Capacity Supplier's capacity cleared, and for each month in which the Installed Capacity Supplier is determined not to have complied with the foregoing requirements.

In addition, if any Installed Capacity Supplier fails to comply with the scheduling, bidding, or notification requirements of Sections 5.12.1.6 or 5.12.1.10, or with Section 5.12.7 of this Tariff, or if an Installed Capacity Supplier of Unforced Capacity from an External Control Area fails to comply with the scheduling, bidding, or notification requirements for certification as an Installed Capacity Supplier established in the ISO Procedures, during an hour in which the ISO curtails Exports associated with NYCA Installed Capacity Suppliers consistent with Section 5.12.10 of this Tariff and with ISO Procedures, then the ISO may impose an additional financial sanction equal to the product of the number of MWs the Installed Capacity Supplier failed to schedule during that hour and the corresponding Real-Time LBMP at the applicable Proxy Generator Bus.

To the extent an Installed Capacity Supplier of Unforced Capacity from an External Control Area or an External Generator associated with an Unforced Capacity sale using UDRs or EDRs fails to comply with Section 5.12.1.10 of this Tariff, the Installed Capacity Supplier or External Generator associated with an Unforced Capacity sale using UDRs or EDRs shall be

subject to a deficiency charge calculated in accordance with the formula set forth below for each Obligation Procurement Period:

$$Deficiency\ charge = 1.5 * PRICE * \left(\frac{1000kW}{1MW} \right) * \left(\frac{\sum_{n=1}^N (\max(ICAP_n^{MWh} - SRE_n^{MWh}, 0))}{N} \right)$$

Where:

N = total number of hours of SRE calls during the relevant Obligation Procurement Period

PRICE = ICAP Spot Market Auction clearing price for the relevant Obligation Procurement Period

$ICAP_n^{MWh}$ = for each hour n of SRE calls during the relevant Obligation Procurement Period, the ICAP equivalent of the UCAP sold from the External Installed Capacity Supplier that is a Generator, or the External Generator associated with an Unforced Capacity sale using UDRs or EDRs, or the Control Area System Resource in MWh, minus (x) any MWh that are unavailable due to an outage as defined in the ISO Procedures, or due to physical operating limitations affecting the External Installed Capacity Supplier that is a Generator, or the External Generator associated with an Unforced Capacity sale using UDRs or EDRs, or due to other operational issues that the ISO determines to be outside the Installed Capacity Supplier's control, and (y) any MWh that were Bid as Imports to the NYCA at the appropriate Proxy Generator Bus at a price that was designed to ensure the Import was scheduled to the greatest extent possible, but that were not scheduled by the ISO

SRE_n^{MWh} = MWh provided to the NYCA at the appropriate Proxy Generator Bus from the External Installed Capacity Supplier that is a Generator, or the External

Generator associated with an Unforced Capacity sale using UDRs or EDRs, or the Control Area System Resource, during each hour n of SRE calls during the relevant Obligation Procurement Period.

If an Installed Capacity Supplier's failure to fully comply with this Tariff would, in addition to being assessed a deficiency charge calculated in accordance with the formula set forth above, also permit the ISO to impose a different deficiency charge or a financial sanction under this Section 5.12.12.2, or to impose a deficiency charge for a shortfall under Section 5.14.2.2 of this Tariff, then the ISO shall only impose the penalty for failure to comply with Section 5.12.1.10 of this Tariff on the Installed Capacity Supplier for the hour(s) in which the Installed Capacity Supplier failed to meet its obligations under Section 5.12.1.10 of this Tariff.

If the Installed Capacity Supplier is a Responsible Interface Party that enrolled a SCR with an Incremental ACL in accordance with this Services Tariff, and also reported an increase to the Installed Capacity the SCR has eligible to sell after the first performance test in the Capability Period, the ISO may impose an additional financial sanction due to the failure of the RIP to report the required performance of the SCR against the Net ACL value in the second performance test in the Capability Period. This sanction shall be the value of the reported increase in the eligible Installed Capacity associated with the SCR that was sold by the RIP in each month of the Capability Period, during which the reported increase was in effect, multiplied by up to one and one-half times the applicable Market-Clearing Price of Unforced Capacity determined in the ICAP Spot Market Auction for each such month.

If the Installed Capacity Supplier is a Responsible Interface Party, and the Average Coincident Load of the Special Case Resource has been decreased after the first performance test in the Capability Period, due to a SCR Change of Status in accordance with this Services Tariff

and ISO Procedures, the ISO may impose an additional financial sanction resulting from the failure of the RIP to report the required performance of the SCR against the Net ACL value of the SCR when the SCR was required to perform in the second performance test in the Capability Period in accordance with Section 5.12.11.1.3.2 of this Services Tariff. This sanction shall be the value of the Unforced Capacity equivalent of the SCR Change of Status MW reported for the SCR during the months for which the SCR was enrolled with a SCR Change of Status and was required to demonstrate in the second performance test as specified in Section 5.12.11.1.3.2 of this Services Tariff, multiplied by up to one and one-half times the applicable Market-Clearing Price of Unforced Capacity determined in the ICAP Spot Market Auction for each such month.

If a RIP fails to provide the information required by Section 5.12.11.1.3 of this Services Tariff in accordance with the ISO Procedures for reporting a Qualified Change of Status Condition, and the ISO determines that a SCR Change of Status occurred within a Capability Period, the ISO may impose a financial sanction equal to the difference, if positive, between the enrolled ACL and the maximum one hour metered Load for the month multiplied by up to one-half times the applicable Market-Clearing Price of Unforced Capacity determined in the ICAP Spot Market Auction for each month the Installed Capacity Supplier is deemed to have a shortfall in addition to the corresponding shortfall penalty as provided in Section 5.14.2.

For each month in which a RIP fails to report required verification data and the applicable ACL value is set to zero in accordance with Section 5.12.11 of this Services Tariff, the ISO shall have the right to recover any energy payments made to the RIP for performance of the SCR by reducing other payments or other lawful means.

23.3 Criteria for Imposing Mitigation Measures

23.3.1 Identification of Conduct Inconsistent with Competition

Conduct that may potentially warrant the imposition of a mitigation measure includes the categories described in Section 23.2.4 above, which shall be detected through the use of indices and screens developed, adopted and made available as specified in Attachment O. The thresholds listed in Sections 23.3.1.1 to 23.3.1.3 below shall be used to identify substantial departures from competitive conduct indicative of an absence of workable competition.

23.3.1.1 Thresholds for Identifying Physical Withholding

23.3.1.1.1 The following initial thresholds will be employed by the ISO to identify physical withholding of a Generator or generation by a Market Party and its Affiliates:

23.3.1.1.1.1 Except for conduct addressed in Section 23.3.1.1.1.2: Withholding that exceeds (i) 10 percent of a Generator's capability, or (ii) 100 MW of a Generator's capability, or (iii) 5 percent of the total capability of a Market Party and its Affiliates, or (iv) 200 MW of the total capability of a Market Party and its Affiliates.

For a Generator or a Market Party in a Constrained Area for intervals in which an interface or facility into the area in which the Generator or generation is located has a Shadow Price greater than \$0.04/MWh, indicating an active constraint, withholding that exceeds (i) 10 percent of a Generator's capability, or (ii) 50 MW of a Generator's capability, or (iii) 5 percent of the total capability of a Market Party and its Affiliates, or (iv) 100 MW of the total capability of a Market Party and its Affiliates.

23.3.1.1.1.2 Operating a Generator or generation in real-time at a lower output level than would have been expected had the Market Party's and its Affiliate's Generator or generation followed the ISO's dispatch instructions, resulting in a difference in output that exceeds (i) 15 minutes times a Generator's stated response rate per minute at the output level that would have been expected had the Generator followed the ISO's dispatch instructions, or (ii) 100 MW for a Generator, or (iii) 200 MW of the total capability of a Market Party and its Affiliates. For a Generator or a Market Party in a Constrained Area for intervals in which an interface or facility into the area in which the generation is located has a Shadow Price greater than \$0.04/MWh, indicating an active constraint, operating a Generator or generation in real-time at a lower output level than would have been expected had the Market Party's and its Affiliate's Generator or generation followed the ISO's dispatch instructions, resulting in a difference in output that exceeds (i) 15 minutes times a Generator's stated response rate per minute at the output level that would have been expected had the Generator followed the ISO's dispatch instructions, or (ii) 50 MW of a Generator's capability, or (iii) 100 MW of the total capability of a Market Party and its Affiliates.

23.3.1.1.2 The amounts of generating capacity considered withheld for purposes of applying the thresholds in this Section 23.3.1.1 shall include unjustified deratings, and the portions of a Generator's output that is not Bid or subject to economic withholding. The amounts deemed withheld shall not include (i) generating output that is subject to a forced outage, subject to verification by the ISO as may

be appropriate that an outage was forced, (ii) capacity that is out of service for maintenance in accordance with an ISO maintenance schedule, or (iii) generating capacity that is not Bid in the Real-Time Market, because and to the extent it would have to use unauthorized natural gas to operate, subject to verification by the ISO as may be appropriate that operation would require the use of unauthorized natural gas. See Section 23.3.1.4.6.2.1.1 below.

23.3.1.1.3 A transmission facility shall be deemed physically withheld if it is not operated in accordance with ISO instructions and such failure to conform to ISO instructions causes or contributes to transmission congestion. A transmission facility shall not be deemed withheld if it is subject to a forced outage or is out of service for maintenance in accordance with an ISO maintenance schedule.

23.3.1.2 Thresholds for Identifying Economic Withholding

23.3.1.2.1 The following thresholds shall be employed by the ISO to identify economic withholding that may warrant the mitigation of a Generator in an area that is not a Constrained Area, or in a Constrained Area during periods not subject to transmission constraints affecting the Constrained Area, and shall be determined with respect to a reference level determined as specified in Section 23.3.1.4:

23.3.1.2.1.1 Incremental Energy and Minimum Generation Bids: An increase exceeding 300 percent or \$100 per MWh, whichever is lower; provided, however, that Incremental Energy or Minimum Generation Bids below \$25 per MWh shall be deemed not to constitute economic withholding when evaluating Bids to produce Energy.

23.3.1.2.1.1.1 Threshold for Bids to withdraw Incremental Energy: an increase exceeding 300 percent or \$100 per MWh, whichever is lower. However, the threshold for Bids to withdraw Incremental Energy that have an associated reference level that is between -\$25 and \$25 per MWh (inclusive) is, instead, \$75 per MWh.

23.3.1.2.1.1.2 Additional Thresholds used to assess Bids for Generators that the ISO evaluates as a price spread for purposes of scheduling and dispatch.

The following hourly and daily thresholds will be employed to evaluate the spread between the minimum and maximum dollar values included in a Withdrawal-Eligible Generator's multi-step incremental Energy Bid. The time periods over which the comparisons are performed are specified below.

(a) Hourly Threshold (applies to both the Day-Ahead and Real-Time Markets)—the Incremental Energy Bid spread is compared to the Incremental Energy reference level spread for the same market hour. The Bid spread is determined by subtracting the least Incremental Energy Bid price from the greatest Incremental Energy Bid price. This value is compared to the reference level spread, which is determined by subtracting the Incremental Energy reference level price that corresponds to the least Incremental Energy Bid price from the Incremental Energy reference level price that corresponds to the greatest Incremental Energy Bid price. A Bid spread that exceeds the reference level spread by more than 300 percent or by more than \$100 per MWh, whichever is lower, exceeds the conduct threshold.

(b) Daily Threshold (only applies to the Day-Ahead Market)—the Incremental Energy Bid spread across the Day-Ahead market day is compared to the Incremental Energy reference level spread. The Bid spread is determined by subtracting the least Incremental Energy Bid price submitted for any hour of the Day-Ahead market day (“Hour X”) from the greatest Incremental Energy Bid price submitted for any hour of the same market-day (“Hour Y”). Hour X and Hour Y can be the same market hour. This value is compared to the reference level spread, which is determined by subtracting the Incremental Energy reference level price Bid that corresponds to the least Incremental Energy Bid price in Hour X from the Incremental Energy reference level price that corresponds to the greatest Incremental Energy Bid price in Hour Y. A Bid spread that exceeds the reference level spread by more than 300 percent or by more than \$100 per MWh, whichever is lower, exceeds the conduct threshold.

23.3.1.2.1.2 Operating Reserves and Regulation Service Bids:

23.3.1.2.1.2.1 Operating Reserves and Regulation Capacity Bids: A 300 percent increase or an increase of \$50 per MW, whichever is lower; provided, however, that such Bids below \$5 per MW shall be deemed not to constitute economic withholding.

23.3.1.2.1.2.2 Regulation Movement Bids: A 300 percent increase.

23.3.1.2.1.3 Start-Up Bids: A 200 percent increase.

23.3.1.2.1.4 Time-based Bid parameters: An increase of 3 hours, or an increase of 6 hours in total for multiple time-based Bid parameters. Time-based Bid parameters include, but are not limited to, start-up times, minimum run times,

minimum down times, and temporal minimum and maximum parameters related to the withdrawal and injection of Energy by Withdrawal-Eligible Generators.

23.3.1.2.1.5 Bid parameters expressed in units other than time or dollars, including the MW component of a Minimum Generation Bid (also referred to as the “minimum operating level”): A 100 percent increase for parameters that are minimum values, or a 50 percent decrease for parameters that are maximum values (including but not limited to ramp rates, maximum stops, and operating parameters related to the withdrawal and injection of Energy by Withdrawal-Eligible Generators).

23.3.1.2.2 The following thresholds shall be employed by the ISO to identify economic withholding that may warrant the mitigation of a Generator in an area that is a Constrained Area, and shall be determined with respect to a reference level determined as specified in Section 23.3.1.4:

23.3.1.2.2.1 For Energy and Minimum Generation Bids for the Real-Time Market: for intervals in which an interface or facility into the area in which a Generator is located has a Shadow Price greater than \$0.04/MWh, indicating an active constraint, the lower of the thresholds specified for areas that are not Constrained Areas or a threshold determined in accordance with the following formula:

$$\textit{Threshold} = \frac{2\% * \textit{Average Price} * 8760}{\textit{Constrained Hours}}$$

where:

Average Price = the average price in the Real-Time Market in the Constrained Area over the past 12 months, adjusted for fuel price changes, and adjusted for Out-of-Merit Generation dispatch as feasible and appropriate; and

Constrained Hours = the total number of minutes over the prior 12 months, converted to hours (retaining fractions of hours), in which the real-time Shadow

Price has been greater than \$0.04/MWh, indicating an active constraint, on any interface or facility leading into the Constrained Area in which the Generator is located. For the In-City area, “Constrained Hours” shall also include the number of minutes that a Storm Watch is in effect. Determination of the number of Constrained Hours shall be subject to adjustment by the ISO to account for significant changes in system conditions.

23.3.1.2.2.2 For so long as the In-City area is a Constrained Area, the thresholds specified in subsection 23.3.1.2.2.1 shall also apply: (a) in intervals in which the transmission capacity serving the In-City area is subject to Storm Watch limitations; (b) to an In-City Generator that is operating as Out-of-Merit Generation; and (c) to a Generator dispatched as a result of a Supplemental Resource Evaluation.

23.3.1.2.2.3 For Energy and Minimum Generation Bids for the Day-Ahead Market: for all Constrained Hours for the Generator being Bid, a threshold determined in accordance with the formula specified in subsection 23.3.1.2.2.1 above, but where Average Price shall mean the average price in the Day-Ahead Market in the Constrained Area over the past twelve months, adjusted for fuel price changes, and where Constrained Hours shall mean the total number of hours over the prior 12 months in which the Shadow Price in the Day-Ahead Market has been greater than \$0.04/MWh, indicating an active constraint, on any interface or facility leading into the Constrained Area in which the Generator is located. Determination of the number of Constrained Hours shall be subject to adjustment by the ISO to account for significant changes in system conditions.

23.3.1.2.2.4 For Start-Up Bids; a 50% increase.

23.3.1.2.2.5 The thresholds listed in Sections 23.3.1.2.1.2 and 23.3.1.2.1.4 through 23.3.1.2.1.5.

23.3.1.2.2.6 For intervals in which an interface or facility into the area in which a Generator is located has a Shadow Price greater than \$0.04/MWh, indicating an active constraint in the Day-Ahead Market or in the Real-Time Market, the additional thresholds used to assess Bids for Generators that the ISO evaluates as a price spread for purposes of scheduling and dispatch are set forth below. The evaluation method is described in Section 23.3.1.2.1.1.2 of these Mitigation Measures.

(a) Hourly Threshold (applies to both the Day-Ahead and Real-Time Markets)—the Incremental Energy Bid spread is compared to the Incremental Energy reference level spread for the same market hour. The Bid spread is determined by subtracting the least Incremental Energy Bid price from the greatest Incremental Energy Bid price. This value is compared to the reference level spread, which is determined by subtracting the Incremental Energy reference level price that corresponds to the least Incremental Energy Bid price from the Incremental Energy reference level price that corresponds to the greatest Incremental Energy Bid price. A Bid spread that exceeds the reference level spread by more than the lower of the threshold specified for areas that are not Constrained Areas, or a threshold determined in accordance with the formulae set forth in Section 23.3.1.2.2.1 (real-time) or Section 23.3.1.2.2.3 (Day-Ahead) of these Mitigation Measures, exceeds the conduct threshold.

(b) Daily Threshold (only applies to the Day-Ahead Market)—the Incremental Energy Bid spread across the Day-Ahead market day is compared to the Incremental Energy reference level spread. The Bid spread is determined by

subtracting the least Incremental Energy Bid price submitted for any hour of the Day-Ahead market day (“Hour X”) from the greatest Incremental Energy Bid price submitted for any hour of the same market-day (“Hour Y”). Hour X and Hour Y can be the same market hour. This value is compared to the reference level spread, which is determined by subtracting the Incremental Energy reference level price Bid that corresponds to the least Incremental Energy Bid price in Hour X from the Incremental Energy reference level price that corresponds to the greatest Incremental Energy Bid price in Hour Y. A Bid spread that exceeds the reference level spread by more than the lower of the threshold specified for areas that are not Constrained Areas, or a threshold determined in accordance with the formula set forth in Section 23.3.1.2.2.3 (Day-Ahead) of these Mitigation Measures, exceeds the conduct threshold.

23.3.1.2.3 The following thresholds shall be employed by the ISO to identify economic withholding that requires the mitigation of a Generator that is committed outside the ISO’s economic evaluation process to protect NYCA or local area reliability in an area that is not a designated Constrained Area. Whether the thresholds specified in Sections 23.3.1.2.3.3(i) through 23.3.1.2.3.3(vi) below have been exceeded shall be determined with respect to a reference level determined as specified in Section 23.3.1.4 of these Mitigation Measures.

If provisions 23.3.1.2.3.1 and 23.3.1.2.3.2 below are met for a Generator in the New York Control Area that is not located in a designated Constrained Area, the ISO shall substitute a reference level for each Bid, or component of a Bid, for

which the applicable threshold specified in provisions 23.3.1.2.3.3(i) through 23.3.1.2.3.3(vi) below is exceeded. Where mitigation is determined to be appropriate, the mitigated results will be used in all aspects of the NYISO's settlement process.

23.3.1.2.3.1 The Generator was committed outside the ISO's economic merit order selection process to protect or maintain New York Control Area or local system reliability as a Day-Ahead Reliability Unit ("DARU") or via a Supplemental Resource Evaluation ("SRE"), or was committed as a DARU or via SRE and was also dispatched Out-of-Merit above its minimum generation level to protect or maintain New York Control Area or local system reliability; and

23.3.1.2.3.2 One of the following three (i) – (iii) conditions in this Section 23.3.1.2.3.2 must be satisfied in order for mitigation to be applied:

- i the Market Party (including its Affiliates) that owns or offers the Generator is the only Market Party that could effectively solve the reliability need for which the Generator was committed or dispatched, or
- ii when evaluating an SRE that was issued to address a reliability need that multiple Market Parties' Generators are capable of solving, the NYISO only received Bids from one Market Party (including its Affiliates), or
- iii when evaluating a DARU, if the Market Party was notified of the need for the reliability commitment of its Generator prior to the close of the Day-Ahead Market.

23.3.1.2.3.3 The Bids or Bid components submitted for the Generator that were accepted outside the economic evaluation process to protect or maintain New York Control Area or local system reliability:

- i exceeded the Generator's Minimum Generation Bid reference level by the greater of 10% or \$10/MWh, or
- ii. exceeded the Generator's Incremental Energy Bid reference level by the greater of 10% or \$10/MWh, or
- iii. exceeded the Generator's Start-Up Bid reference level by 10%, or
- iv. exceeded the Generator's minimum run time, start-up time, and minimum down time reference levels by more than one hour in aggregate, or
- v. exceeded the Generator's minimum generation MW reference level by more than 10%, or
- vi. decreased the Generator's maximum number of stops per day below the Generator's reference level by more than one stop per day, or to one stop per day.

23.3.1.2.4 For In-City Generators committed in the Day-Ahead Market for local reliability, additional Mitigation Measures are specified in Section 23.5.2.1.

23.3.1.3 Thresholds for Identifying Uneconomic Production and Uneconomic Withdrawal of Energy

23.3.1.3.1 The following thresholds will be employed by the ISO to identify uneconomic production that may warrant the imposition of a mitigation measure:

23.3.1.3.1.1 Energy scheduled at an LBMP that is less than 20 percent of the applicable reference level and causes or contributes to transmission congestion; or

23.3.1.3.1.2 Real-time output from a Generator or generation resulting in real-time operation at a higher output level than would have been expected had the Market

Party's and the Affiliate's Generator or generation followed the ISO's dispatch instructions, if such failure to follow ISO dispatch instructions in real-time causes or contributes to transmission congestion, and it results in an output difference that exceeds (i) 15 minutes times a Generator's stated response rate per minute at the output level that would have been expected had the Generator followed the ISO's dispatch instructions, or (ii) 100 MW for a Generator, or (iii) 200 MW of the total capability of a Market Party and its Affiliates.

23.3.1.3.2 The following thresholds will be employed by the ISO to identify uneconomic withdrawals of Energy by Withdrawal-Eligible Generators that may warrant the imposition of a mitigation measure:

23.3.1.3.2.1 Energy withdrawn at an LBMP that is at least 300 percent or \$75/MWh, whichever is greater, more than the Withdrawal-Eligible Generator's applicable reference level and that causes or contributes to transmission congestion; provided, however, that schedules to withdraw Energy that are determined by the ISO based on the economics of an offer to withdraw Energy, including the Incremental Energy Bid spread of a Withdrawal-Eligible Generator, shall not be considered uneconomic withdrawals under this Section 23.3.1.3.2.1; or

23.3.1.3.2.2 Real-time withdrawals by a Withdrawal-Eligible Generator resulting in different real-time operation than would have been expected had the Market Party's and the Affiliate's Generator or generation followed the ISO's dispatch instructions, if such failure to follow ISO dispatch instructions in real-time causes or contributes to transmission congestion, and it results in an output difference that exceeds (i) 15 minutes times a Generator's stated response rate per minute at

the output level that would have been expected had the Generator followed the ISO's dispatch instructions, or (ii) 100 MW for a Generator, or (iii) 200 MW of the total capability of a Market Party and its Affiliates.

23.3.1.4 Reference Levels

23.3.1.4.1 Except as provided in Sections 23.3.1.4.3 – 23.3.1.4.6 below, a reference level for each component of a Generator's Bid to produce Energy shall be calculated on the basis of the following methods, listed in the order of preference subject to the existence of sufficient data.

A reference level for each component of a Withdrawal-Eligible Generator's Bid to produce or withdraw Energy shall be calculated consistent with Sections 23.3.1.4.1.3 or 23.3.1.4.2 below, subject to the existence of sufficient data.

23.3.1.4.1.1 The lower of the mean or the median of a Generator's accepted Bids or Bid components, in hour beginning 6 to hour beginning 21 but excluding weekend and designated holiday hours, in competitive periods over the most recent 90 day period for which the necessary input data are available to the ISO's reference level calculation systems, adjusted for changes in fuel prices consistent with Section 23.3.1.4.6, below. To maintain appropriate reference levels (i) the ISO shall exclude all Incremental Energy and Minimum Generation Bids below \$15/MWh from its development of Bid-based reference levels, (ii) the ISO shall exclude Minimum Generation Bids submitted for a Generator that was committed on the day prior to the Dispatch Day for the hours during the Dispatch Day that the Generator needs to operate in order to complete the minimum run time specified in the Bid it submitted for the hour in which it was committed, and (iii)

the ISO may exclude other Bids that would cause a reference level to deviate substantially from a Generator's marginal cost when developing Bid-based reference levels;

23.3.1.4.1.2 Calculate incremental energy and minimum generation reference levels for a Generator using the mean of the LBMP at the Generator's location during the lowest-priced 50 percent of the hours that the Generator was dispatched over the most recent 90 day period for which the necessary LBMP data are available to the ISO's reference level calculation systems, adjusted for changes in fuel prices consistent with Section 23.3.1.4.6, below. To maintain appropriate reference levels (i) the ISO shall exclude all LBMPs below \$15/MWh from its development of LBMP-based reference levels, (ii) the ISO shall exclude LBMPs during hours when a Generator was scheduled as a Day-Ahead Reliability Unit or via a Supplemental Resource Evaluation or was Out-of-Merit Generation, from its development of that Generator's LBMP-based reference levels, (iii) for a Generator that was committed on the day prior to the Dispatch Day, the ISO shall exclude LBMPs for the hours during the Dispatch Day that the Generator needs to operate in order to complete the minimum run time specified in the Bid it submitted for the hour in which the Generator was committed from the ISO's development of that Generator's LBMP-based reference levels, and (iv) the ISO may exclude LBMPs that would cause a reference level to deviate substantially below a Generator's marginal cost when developing LBMP-based reference levels; or

23.3.1.4.1.3 A level determined in consultation with the Market Party submitting the Bid or Bids at issue, provided such consultation has occurred prior to the occurrence of the conduct being examined by the ISO, and provided the Market Party has provided data on a Generator's operating costs in accordance with specifications provided by the ISO.

The reference level for a Generator's Energy and Ancillary Service Bids are intended to reflect the Generator's marginal costs. The ISO's determination of a Generator's Energy marginal costs shall include an assessment of the Generator's incremental operating costs in accordance with the following formula:

$$\begin{aligned} & (\text{heat rate} * \text{fuel costs}) + (\text{emissions rate} * \text{emissions allowance price}) \\ & \quad + (\text{other variable operating and maintenance costs}) \\ & \quad + \text{opportunity costs} \end{aligned}$$

Opportunity cost is the cost, in dollars, representing (a) the total net revenue in the future time periods that is expected to be forgone by being dispatched by the ISO in the current time period, or (b) the total net cost in future time periods that is expected to be avoided by being dispatched by the ISO in the current time period.

Opportunity costs are limited to costs that the ISO reasonably determines to be appropriate based on such data as may be furnished by the Market Party or otherwise available to the ISO. Reference levels shall also include such other factors or adjustments as the ISO shall reasonably determine to be appropriate based on such data as may be furnished by the Market Party or otherwise available to the ISO.

23.3.1.4.2 If sufficient data do not exist to calculate a reference level on the basis of either of the first two methods, or if the ISO determines that none of the three

methods are applicable to a particular type of Bid component, or an attempt to determine a reference level in consultation with a Market Party has not been successful, or if the reference level produced does not reasonably approximate a Generator's marginal cost, the ISO shall determine a reference level on the basis of:

- 23.3.1.4.2.1 the ISO's estimate of the costs or physical parameters of an Electric Facility, taking into account available operating costs data, appropriate input from the Market Party, and the best information available to the ISO; or
- 23.3.1.4.2.2 an appropriate average of competitive bids of one or more similar Electric Facilities.
- 23.3.1.4.3 Notwithstanding the foregoing provisions, the reference level for Incremental Energy Bids for New Capacity, excluding Energy Storage Resources, for the three year and six month period following the New Capacity's first production of Energy while synchronously interconnected to the New York State Transmission System shall be the higher of (i) the amount determined in accordance with the provision of Section 23.3.1.4.1 or 23.3.1.4.2, or (ii) the average of the fuel price-adjusted peak LBMPs over the twelve months prior to the New Capacity's first production of Energy while synchronously interconnected to the New York State Transmission System of the New Capacity in the Load Zone in which the New Capacity is located during hours when Generators with operating characteristics similar to the New Capacity would be expected to run. For entities owning or otherwise controlling the output of capacity in the New York Control Area other than New Capacity, the provisions

of this Section 23.3.1.4.3 shall apply only to net additions of capacity during the applicable three year and six month period.

23.3.1.4.4 Notwithstanding the foregoing provisions, a reference level for a Generator's start-up costs Bid shall be calculated on the basis of the following methods, listed in the order of preference subject to the existence of sufficient data:

23.3.1.4.4.1 If sufficient bidding histories under the applicable bidding rules for a given Generator's start-up costs Bids have been accumulated, the lower of the mean or the median of the Generator's accepted start-up costs Bids in competitive periods over the previous 90 days for similar down times, adjusted for changes in fuel prices consistent with Section 23.3.1.4.6 below. However, accepted Start-Up Bids that incorporate anticipated costs of operating on the day after the Dispatch Day in which the Generator is committed in order to permit the Generator to satisfy its minimum run time shall not be used to develop Bid-based start-up reference levels;

23.3.1.4.4.2 A level determined in consultation with the Market Party submitting the Bid or Bids at issue and intended to reflect the costs incurred for a Generator to achieve its specified minimum operating level from an offline state, provided such consultation has occurred prior to the occurrence of the conduct being examined by the ISO, and provided the Market Party has provided data on the Generator's operating costs in accordance with specifications provided by the ISO; or

23.3.1.4.4.3 Generators committed in the Day-Ahead Market or via Supplemental Resource Evaluation that are not able to complete their minimum run time within

the Dispatch Day in which they are committed are eligible to include in their Start-Up Bid expected net costs of operating on the day following the dispatch day at the minimum operating level (in MW) specified in the Generator's Bid for the commitment hour, for the hours necessary to complete the Generator's minimum run time. The NYISO will calculate a start-up reference level that incorporates the net costs the Generator is expected to incur on the day following the Dispatch Day as follows:

23.3.1.4.4.3.1 Calculation of a start-up reference level that includes expected net costs of operating on the day following the Dispatch Day

The NYISO will use the following calculation to develop a reference level that incorporates the costs that a Generator is expected to incur on the day following the Dispatch Day.

$$LateDayAdjusted_{g,i} = StrtUpRef_g + \max\left(0, MinGenRef_{g,i} * BidMinGen_{g,i} * \sum_{h=0}^{Z_{g,i}-1} SR_{g,h,i}\right)$$

Where:

$LateDayAdjusted_{g,i}$ = calculated start-up reference level for Generator g for hour i in \$ (reflects the applicable start-up reference level ($StrtUpRef_g$), plus the expected net cost of operating on the day following the Dispatch Day)

$StrtUpRef_g$ = the start-up reference level for Generator g in \$ that is in effect at the time the calculation is performed (does not include the expected net cost of operating on the day following the Dispatch Day)

$MinGenRef_{g,i}$ = the minimum generation cost reference level for Generator g for hour i in \$/MW that is in effect at the time the calculation is performed

$BidMinGen_{g,i}$ = Generator g's Day-Ahead minimum operating level for hour i, in MW

$Z_{g,i}$ = the number of hours the Generator must operate during the day following the Dispatch Day in order to complete its minimum run time if it starts in hour i

$SR_{g,h,i}$ = shortfall ratio for Generator g that is bidding to start in hour i which must run during hour h in order to complete its minimum run time, calculated in accordance with Section 23.3.3.4.4.3.2, below

23.3.1.4.4.3.2 Calculation of the shortfall ratio for use in Section 23.3.1.4.4.3.1, above

$SR_{g,h,i}$ = the shortfall ratio calculated for Generator g that is bidding to start in hour i, and that must run during hour h to complete its minimum run time.

In all cases in which Generator g's Day-Ahead minimum operating level deviates from the average of the previous seven days' Day-Ahead minimum operating levels for the same hour by less than 5 MW (i.e., if $|AvgBidMinGen_{g,h,i} - BidMinGen_{g,i}| < 5MW$) or by less than 10% (i.e., if both $BidMinGen_{g,i} < 1.1 * AvgBidMinGen_{g,h,i}$ and $BidMinGen_{g,i} > 0.9 * AvgBidMinGen_{g,h,i}$),

Where:

$AvgBidMinGen_{g,h,i}$ = The average minimum operating level submitted in the Day-Ahead Market for hour h on the seven days preceding the day containing hour i, in MW, excluding any days for which a minimum operating level was not submitted in the Day-Ahead Market for Generator g, for hour h; and

$BidMinGen_{g,i}$ = The minimum operating level submitted in the Day-Ahead Market for Generator g for hour i, in MW

and in all cases in which $AvgBidMinGen_{g,h,i}$ cannot be calculated because minimum operating levels were not submitted for Generator g in the Day-Ahead Market for hour h on any of the seven days preceding the day containing hour i, the $SR_{g,h,i}$ value will be calculated using the primary method. Otherwise, the $SR_{g,h,i}$ value will be calculated using the alternative method.

Primary Method of Calculating the Shortfall Ratio

$$SR_{g,h,i} = 1 - \frac{1}{7} * \sum_{d=1}^7 \frac{LBMP_{g,h,i,d}}{MinGenRef_{g,h,i,d}}$$

Where:

$LBMP_{g,h,i,d}$ = Day ahead LBMP at the location of Generator g in hour h of the Day-Ahead Market for the Dispatch Day that precedes the day containing hour i by d days, and

$MinGenRef_{g,h,i,d}$ = minimum generation cost reference level for Generator g in hour h of the Day-Ahead Market for the Dispatch Day that precedes the day containing hour i by d days

Alternative Method of Calculating the Shortfall Ratio

$$SR_{g,h,i} = 1 - \frac{AvgLBMP_{g,h,i}}{\left(AvgRefRate_{g,h,i} * \frac{RefRate2_{g,i}}{RefRate1_{g,h,i}} \right)}$$

Where:

$AvgLBMP_{g,h,i}$ = The average of the Day-Ahead LBMPs at the location of Generator g for hour h on the seven days preceding the day containing hour i , in \$/MWh, excluding any days for which a minimum operating level was not submitted in the Day-Ahead Market for Generator g for hour h

$AvgRefRate_{g,h,i}$ = The average of the minimum generation reference levels for Generator g in hour h on the seven days preceding the day containing hour i , in \$/MWh, excluding any days for which a minimum operating level was not submitted in the Day-Ahead Market for Generator g for hour h

$RefRate1_{g,h,i}$ = The minimum generation cost reference level in \$/MWh for Generator g for hour i , calculated using the most current reference data, and assuming that the minimum operating level submitted in the Day-Ahead Market for Generator g in hour i corresponds to the MWs reflected in the $AvgBidMinGen_{g,h,i}$

$RefRate2_{g,i}$ = The minimum generation cost reference level in \$/MWh for Generator g for hour i , calculated using the most current reference data, and incorporating the minimum operating level submitted in the Day-Ahead Market for Generator g in hour i that corresponds to the MWs reflected in the $BidMinGen_{g,i}$

Notwithstanding the above, in all cases where the denominator of the equation for calculating $SR_{g,h,i}$ is not greater than zero, $SR_{g,h,i}$ shall be set to zero, under both the primary and alternative methods.

23.3.1.4.4.4 The methods specified in Section 23.3.1.4.2.

23.3.1.4.5 The ISO is not required to calculate real-time reference levels for the three Operating Reserve products (Spinning Reserve, 10-Minute Non-Synchronized Reserves and 30-Minute Reserves) because Generators that are capable of providing these products and that are submitting Bids into the Real-Time Market

are automatically assigned a real-time Operating Reserves Availability Bid of zero for the amount of Operating Reserves they are capable of providing.

The ISO shall calculate real-time reference levels for Regulation Capacity in accordance with Sections 23.3.1.4.1.1, 23.3.1.4.1.3 or 23.3.1.4.2 of these Mitigation Measures. The ISO shall calculate real-time reference levels for Regulation Movement in accordance with Sections 23.3.1.4.1.3 or 23.3.1.4.2.1 of these Mitigation Measures and shall not calculate real-time Reference levels for Regulation Movement in accordance with Section 23.3.1.4.1.1.

The ISO shall calculate Day-Ahead reference levels for the three Operating Reserves products in accordance with Sections 23.3.1.4.1.1, 23.3.1.4.1.3 or 23.3.1.4.2 of these Mitigation Measures. The ISO shall calculate Day-Ahead reference levels for Regulation Capacity in accordance with Sections 23.3.1.4.1.1, 23.3.1.4.1.3 or 23.3.1.4.2 of these Mitigation Measures. The ISO shall calculate Day-Ahead reference levels for Regulation Movement in accordance with Sections 23.3.1.4.1.3 or 23.3.1.4.2.1 of these Mitigation Measures and shall not calculate Day-Ahead Reference levels for Regulation Movement in accordance with Section 23.3.1.4.1.1.

23.3.1.4.6 Reflecting Fuel Costs in Reference Levels. The ISO shall use the best fuel cost information available to it to adjust reference levels to reflect appropriate fuel costs.

23.3.1.4.6.1 ISO Reporting Obligation. If the ISO did not utilize the best fuel cost information available to it when it adjusted reference levels to reflect appropriate fuel costs, and the ISO's failure to utilize the best fuel cost information available

to it affected market clearing prices or had an impact on guarantee payments that cannot be corrected, then the ISO shall report any market clearing price and uncorrected guarantee payment impacts to FERC staff and to its Market Participants. The ISO is not required to report, or to otherwise act, if no market impact is identified.

23.3.1.4.6.2 Market Parties shall monitor Generator reference levels and shall endeavor to timely (as that term is defined in Section 23.3.1.4.6.8 below) contact the ISO to request an adjustment to a Generator's reference level(s) when the Generator's fuel type or fuel price change.

23.3.1.4.6.2.1 Subject to the exceptions set forth in Section 23.3.1.4.6.2.1.2 below, the ISO shall not permit charges for unauthorized natural gas use to be included as a component in the development of a Generator's reference levels and Market Parties shall not be eligible to recover costs associated with unauthorized natural gas use.

23.3.1.4.6.2.1.1 What constitutes "unauthorized" natural gas use is specified in each natural gas pipeline's or local distribution company's ("LDC's") applicable tariff, rate schedule or customer contract. Unauthorized natural gas use may result from, but is not limited to, the following circumstances: (i) consumption of natural gas in violation of the terms of an Operational Flow Order ("OFO") issued by the relevant natural gas LDC or pipeline; (ii) violation of instructions issued by the relevant natural gas LDC or pipeline restricting consumption of natural gas or use of natural gas imbalance service, when such instructions are issued consistent with the LDC's or pipeline's authority under a tariff, rate schedule or contract;

(iii) consumption of natural gas during a period of authorized interruption of service by the relevant natural gas LDC or pipeline, determined in accordance with the terms of the applicable tariff, rate schedule or contract; or (iv) use of natural gas balancing services that are explicitly identified in the relevant natural gas LDC's or pipeline's applicable tariff, rate schedule or contract as unauthorized use or penalty gas.

23.3.1.4.6.2.1.2 If and to the extent a Market Party has obtained specific authorization from the relevant natural gas LDC or pipeline to use gas that would otherwise be unauthorized, such use shall not be considered unauthorized use by the ISO. Market Parties shall make every effort to clearly document authorization they obtain from the LDC or pipeline. Documentation obtained after the fact will be considered.

23.3.1.4.6.3 Screening of fuel type and fuel price information. The ISO may use automated processes and/or require manual review of fuel type and fuel price information submitted by Market Parties to test the accuracy of the information submitted in order to prevent market clearing prices and guarantee payments from being incorrectly calculated.

23.3.1.4.6.4 Consistent with the rules specified in this Section 23.3.1.4.6 of the Mitigation Measures and the procedures that the ISO develops to implement these rules, Market Parties shall notify the ISO of changes in fuel type or fuel price by (i) submitting revised fuel type or fuel price information to the ISO's Market Information System along with the Generator's Bid(s), or (ii) by directly contacting the ISO to request a reference level update consistent with ISO

procedures, or (iii) by utilizing both of the available notification methods.

Revised fuel type or fuel price information that exceeds, or is rejected based upon, the thresholds that the ISO uses to automatically screen fuel type or fuel price information that is submitted to the ISO's Market Information System along with a Generator's Bid(s) shall be submitted by directly contacting the ISO to request a reference level update, consistent with ISO procedures.

23.3.1.4.6.4.1 Exception—changes in fuel price or fuel type that are offered to support Incremental Energy or Minimum Generation Bids that exceed \$1,000/MWh must be submitted in accordance with Section 23.7.3 (for a Generator) or Section 23.7.4 (for a Demand Side Resource) of these Mitigation Measures.

23.3.1.4.6.5 Following the completion of the ISO's automated and/or manual screening processes, the ISO shall use fuel type and fuel price information that Market Parties or their representatives submit to develop Generator reference levels unless (i) the information submitted is inaccurate, or (ii) the information was not timely submitted, and the Market Party's failure to timely submit the information is not excused by the ISO in accordance with Section 23.3.1.4.6.8 below, or (iii) consistent with Section 23.3.1.4.6.9 below.

23.3.1.4.6.6 The ISO may not always have sufficient time to complete its screening of proposed fuel type or fuel price changes prior to the relevant Day-Ahead Market day or Real-Time Market hour. *If* fuel type or fuel price information (i) is timely submitted or, where untimely, the submission of fuel type or fuel price information is excused in accordance with Section 23.3.1.4.6.8 below, and (ii) the fuel type or fuel price information that the Market Party submitted is proven to

have been accurate or to have understated the actual cost incurred for that component, and (iii) the Bid(s) were tested using reference levels that reflected outdated fuel type and/or fuel price information and the Bid(s) were mitigated or a sanction was imposed pursuant to Section 23.4.3 of these Mitigation Measures, *then* the ISO shall (a) re-perform any test(s) that resulted in a sanction being imposed pursuant to Section 23.4.3 of these Mitigation Measures, using the accurate fuel type and/or fuel price information and use the revised results to calculate the appropriate sanction (if any), and (b) determine if the Bids for the Generator would have failed the relevant conduct test(s) if accurate fuel type and/or fuel price information had been used to develop reference levels. The ISO shall then restore any original (as-submitted) Bid(s) that would not have failed the relevant conduct test(s) if accurate fuel type and/or fuel price information had been used to develop the Generator's reference levels, and use the restored Bid(s) to determine a settlement. Otherwise the ISO shall use the Generator's correct or corrected reference level(s) to determine a settlement.

23.3.1.4.6.7 The ISO shall publicly post the thresholds it employs to automatically screen fuel type and fuel price information that is submitted to the ISO's Market Information System for potentially inaccurate fuel type and fuel price data inputs.

23.3.1.4.6.8 For purposes of this Section 23.3.1.4.6, "timely" notice or submission to the Real-Time Market shall mean the submission of fuel type and/or fuel price information using the methods specified in Section 23.3.1.4.6.4 of these Mitigation Measures prior to market close for the relevant Real-Time Market hour. For purposes of this Section 23.3.1.4.6, "timely" notice or submission to

the Day-Ahead Market shall mean the submission of fuel type and/or fuel price information using the methods specified in Section 23.3.1.4.6.4 of these Mitigation Measures at least 15 minutes prior to the close of the Day-Ahead Market (*i.e.*, by 4:45 a.m.). Market Parties are not expected to submit invoices or other supporting data with their Day-Ahead Market or Real-Time Market fuel type and fuel price information, but are expected to retain invoices and other supporting data consistent with the data retention requirements set forth in the Plan, and to be able to produce such information within a reasonable timeframe when asked to do so by the ISO or by its Market Monitoring Unit.

It may not always be possible for a Market Party to timely update a Generator's fuel type or fuel price to reflect unexpected real-time changes or events in advance of the first affected market-hour. Upon a showing of extraordinary circumstances, the ISO may retroactively reflect in Real-Time Market reference levels fuel type or fuel price information that was not timely submitted by a Market Party. While it should ordinarily be possible for a Market Party to timely submit updated fuel type and fuel price information for use in developing a Generator's Day-Ahead Market reference levels, the ISO may retroactively accept and utilize late-submitted Day-Ahead Market fuel type or fuel price information upon a showing of extraordinary circumstances.

23.3.1.4.6.8.1 Exception—changes in fuel price or fuel type that are offered to support Incremental Energy or Minimum Generation Bids that exceed \$1,000/MWh must be submitted in accordance with the submission deadlines specified in Section

23.7.3 (for a Generator) or Section 23.7.4 (for a Demand Side Resource) of these Mitigation Measures.

23.3.1.4.6.9 If (i) the ISO determines, following consultation with the Market Party and review by the Market Monitoring Unit, that the Market Party or its representative has submitted inaccurate fuel type or fuel price information that was biased in the Market Party's favor, or (ii) if a Market Party is subject to a penalty or sanction under Section 23.4.3.3.3 of these Mitigation Measures for submitting inaccurate fuel price or fuel type information, *then* the ISO shall cease using the fuel type and fuel price information submitted to the ISO's Market Information System along with the Generator's Bid(s) to develop reference levels for the affected Generator(s) in the relevant (Day-Ahead or real-time) market for the duration(s) set forth below, unless the Market Party demonstrates to the ISO that the questioned conduct is consistent with competitive behavior.

23.3.1.4.6.9.1 The first time the ISO ceases using the fuel type and fuel price information submitted to the ISO's Market Information System along with the Bid(s) for a Generator to develop Day-Ahead or real-time reference levels for that Generator, it shall do so for 30 days. The 30-day period shall start two business days after the date that the ISO provides written notice of its determination that the application of mitigation is required.

23.3.1.4.6.9.2 Subject to Section 23.3.1.4.6.9.3 below, the second time the ISO ceases using the fuel type and fuel price information submitted to the ISO's Market Information System along with the Bid(s) for a Generator to develop Day-Ahead or real-time reference levels for that Generator, it shall do so for 60 days. The 60-

day period shall start two business days after the date that the ISO provides written notice of its determination that the application of mitigation is required. Subject to Section 23.3.1.4.6.9.3 below, any subsequent time the ISO ceases using the fuel type and fuel price information submitted to the ISO's Market Information System along with the Bid(s) for a Generator to develop Day-Ahead or real-time reference levels for that Generator, it shall do so for 120 days. The 120-day period shall start two business days after the date that the ISO provides written notice of its determination that the application of mitigation is required.

23.3.1.4.6.9.3 If the bidders of a Generator that has previously been mitigated under this Section 23.3.1.4.6.9 becomes and remains continuously eligible to submit fuel type and fuel price information in the Day-Ahead or Real-Time Market (as appropriate) for a period of one year or more, then the ISO shall apply the mitigation measure set forth in Section 23.3.1.4.6.9 of the Mitigation Measures as if the Generator had not previously been subject to the mitigation measure.

23.3.1.4.6.9.4 Market Parties that transfer, sell, assign, or grant to another Market Party the right or ability to Bid a Generator that is subject to the mitigation measure described in this Section 23.3.1.4.6.9 are required to inform the new Market Party that the Generator has been mitigated under this measure, and to inform the new Market Party of the expected duration of such mitigation.

23.3.1.4.6.9.5 For purposes of this Section 23.3.1.4.6.9, submitted fuel type information shall be considered biased in a Market Party's favor if (a) the Market Party submitted revised fuel type information for a Generator for at least 100 hours during the previous 90 days, and (b) for at least one hour the fuel type that a

Market Party submits for the Generator is not the most economic fuel type available to the Generator, taking into consideration fuel availability, operating conditions, and relevant regulatory or reliability requirements, and (c) as a result of the change(s) in fuel type, the fuel prices that the ISO uses to develop reference levels for a Generator exceeded the fuel price that the ISO would have used to develop reference levels for that Generator by greater than the higher of 10% or \$0.50/MMBtu, on average, over the previous 90 days. For purposes of calculating the average, only hours in which the Market Party changed the Generator's fuel type to a more expensive fuel type will be considered. The Day-Ahead and Real-Time Markets shall be considered separately for purposes of this analysis.

23.3.1.4.6.9.6 For purposes of this Section 23.3.1.4.6.9, submitted fuel price information shall be considered biased in a Market Party's favor if (a) the Market Party submitted revised fuel price information for a Generator for at least 100 hours during the previous 90 days, and (b) the fuel price that the Market Party submitted to the ISO's Market Information System for use in developing reference levels for a Generator exceeded the greater of the actual fuel price (as substantiated by supplier quotes or invoices) or the ISO's indexed fuel price, by greater than the higher of 10% or \$0.50/MMBtu, on average, over the previous 90 days. For purposes of calculating the average, only hours in which the fuel price submitted exceeds the ISO's indexed fuel price will be considered. The Day-Ahead and Real-Time Markets shall be considered separately for purposes of this analysis.

23.3.1.4.6.9.7 The responsibilities of the Market Monitoring Unit that are addressed in Section 23.3.1.4.6.9 of the Mitigation Measures are also addressed in Section 30.4.6.2.3 of the Plan.

23.3.1.4.6.10 In order to adjust (i) Bid-based incremental energy, minimum generation and start-up reference levels, and (ii) LBMP-based incremental energy and minimum generation reference levels to more accurately reflect fuel costs, the ISO may calculate distinct Bid- and LBMP-based reference levels for each fuel type or blend of fuel types that a Generator is capable of burning, and shall fuel index each of the distinct Bid- or LBMP-based reference levels that it calculates for fuel types that are amenable to fuel indexing. Where a Generator can draw on multiple natural gas sources that each have distinct, posted, market clearing prices, the ISO may calculate distinct Bid-Based or LBMP-based reference levels for each such available supply source.

23.3.1.4.7 Except as otherwise authorized in accordance with Section 23.3.1.4.6.8 above, Market Parties shall timely report significant changes to the cost components used to develop their Generator's reference levels to the ISO in order to permit the revised costs to be timely reflected in the Generator reference levels. However, if the ISO uses published index prices to fuel index a Generator's reference level when that Generator is burning a fuel type that is amenable to fuel indexing (which may include a blend of two indexed fuel types), the Market Party is not required to report fuel prices that are less than the published index price that the ISO relies on.

23.3.1.4.8 Reflecting opportunity costs in Reference Levels. The ISO shall use the information available to it to adjust reference levels to reflect appropriate opportunity costs.

23.3.1.4.8.1 Prohibition of duplicative and evasive cost submissions and Bids. Costs that are submitted or Bid as fuel costs shall not also be submitted or Bid as opportunity costs. A cost shall not be submitted or Bid in two parts, as both a fuel costs and an opportunity cost, in order to evade applicable screening thresholds. Fossil generators shall not submit or Bid fuel costs, including but not limited to balancing costs, as opportunity costs. Energy Storage Resources shall not submit or Bid the cost they expect to incur to withdraw Energy as a fuel cost.

If the ISO identifies a potentially duplicative or evasive Bid or cost submission that appears to violate this prohibition, it shall inform the Market Monitoring Unit of the potential Market Violation.

23.3.1.4.8.2 ISO Reporting Obligation. If the ISO did not adjust reference levels to reflect timely (as that term is defined in Section 23.3.1.4.8.9 below) submitted, appropriate opportunity costs, and the ISO's failure to adjust reference levels to reflect such opportunity costs affected market clearing prices or had an impact on guarantee payments that cannot be corrected, then the ISO shall report any market clearing price and uncorrected guarantee payment impacts to FERC staff and to its Market Participants. The ISO is not required to report, or to otherwise act, if no market impact is identified.

23.3.1.4.8.3 Market Parties shall monitor Generator reference levels and shall endeavor to timely (as that term is defined in Section 23.3.1.4.8.9 below) contact the ISO to

request an adjustment to a Generator's reference level(s) when changes in opportunity costs are expected to impact the Generator's reference levels.

23.3.1.4.8.4 Screening of opportunity cost submissions. The ISO may use automated processes and/or require manual review of opportunity cost submissions by Market Parties in order to prevent market clearing prices and guarantee payments from being incorrectly calculated.

23.3.1.4.8.5 Consistent with the rules specified in this Section 23.3.1.4.8 of the Mitigation Measures and the procedures that the ISO develops to implement these rules, Market Parties shall notify the ISO of changes in opportunity costs by (i) submitting revised opportunity cost information to the ISO's Market Information System along with the Generator's Bid(s), or (ii) by directly contacting the ISO to request a reference level update consistent with ISO procedures, or (iii) by utilizing both of the available notification methods. Revised opportunity cost information that exceeds, or is rejected based upon, the thresholds that the ISO uses to automatically screen opportunity cost information that is submitted to the ISO's Market Information System along with a Generator's Bid(s) shall be submitted by directly contacting the ISO to request a reference level update, consistent with ISO procedures.

23.3.1.4.8.6 Following the completion of the ISO's automated and/or manual screening processes, the ISO shall use opportunity cost information that Market Parties or their representatives submit to develop Generator reference levels unless (i) the information submitted is inaccurate, or (ii) the information was not timely

submitted, and the Market Party's failure to timely submit the information is not excused by the ISO in accordance with Section 23.3.1.4.8.9 below.

23.3.1.4.8.7 The ISO may not always have sufficient time to complete its screening of proposed opportunity cost changes prior to the relevant Day-Ahead Market day or Real-Time Market hour. *If* opportunity cost information (i) is timely submitted or, where untimely, the submission is excused in accordance with Section 23.3.1.4.8.9 below, and (ii) the opportunity cost information that the Market Party submitted is proven to have been accurate or to have understated the actual cost incurred for that component, and (iii) the Bid(s) were tested using reference levels that reflected outdated opportunity cost information and the Bid(s) were mitigated or a sanction was imposed pursuant to Section 23.4.3 of these Mitigation Measures, *then* the ISO shall (a) re-perform any test(s) that resulted in a sanction being imposed pursuant to Section 23.4.3 of these Mitigation Measures, using the accurate opportunity cost information and use the revised results to calculate the appropriate sanction (if any), and (b) determine if the Bids for the Generator would have failed the relevant conduct test(s) if accurate opportunity cost information had been used to develop reference levels. The ISO shall then restore any original (as-submitted) Bid(s) that would not have failed the relevant conduct test(s) if accurate opportunity cost information had been used to develop the Generator's reference levels, and use the restored Bid(s) to determine a settlement. Otherwise the ISO shall use the Generator's correct or corrected reference level(s) to determine a settlement.

23.3.1.4.8.8 The ISO shall publicly post the thresholds it employs to automatically screen opportunity cost information that is submitted to the ISO's Market Information System for inputs that require manual review before they can be permitted to take effect.

23.3.1.4.8.9 For purposes of this Section 23.3.1.4.8, "timely" notice or submission to the Real-Time Market shall mean the submission of opportunity cost information using the methods specified in Section 23.3.1.4.8.5 of these Mitigation Measures prior to market close for the relevant Real-Time Market hour. For purposes of this Section 23.3.1.4.8, "timely" notice or submission to the Day-Ahead Market shall mean the submission of opportunity cost information using the methods specified in Section 23.3.1.4.8.5 of these Mitigation Measures prior to the close of the Day-Ahead Market. Market Parties are not expected to submit supporting data with their Bids that include revised opportunity cost information, but are expected to retain a record of how the submitted opportunity cost was determined and other supporting data consistent with the data retention requirements set forth in the Plan, and to be able to produce such information within a reasonable timeframe when asked to do so by the ISO or by its Market Monitoring Unit.

It may not always be possible for a Market Party to timely update a Generator's opportunity cost to reflect unexpected real-time changes or events in advance of the first affected market-hour. Upon a showing of extraordinary circumstances, the ISO may retroactively reflect in Real-Time Market reference levels opportunity cost information that was not timely submitted by a Market Party. While it should ordinarily be possible for a Market Party to timely submit

updated opportunity cost information for use in developing a Generator's Day-Ahead Market reference levels, the ISO may retroactively accept and utilize late-submitted Day-Ahead Market opportunity cost information upon a showing of extraordinary circumstances.

23.3.2 Material Price Effects or Changes in Guarantee Payments

23.3.2.1 Market Impact Thresholds

In order to avoid unnecessary intervention in the ISO Administered Markets, Mitigation Measures shall not be imposed unless conduct identified as specified above (i) causes or contributes to a material change in one or more prices in an ISO Administered Market, or (ii) substantially increases guarantee payments to participants in the New York Electric Market. Initially, the thresholds to be used by the ISO to determine a material price effect or change in guarantee payments shall be:

23.3.2.1.1 an increase of 200 percent or \$100 per MWh, whichever is lower, in the hourly Day-Ahead or Real-Time Energy LBMP at any location, or of any other price in an ISO Administered Market; or

23.3.2.1.2 an increase of 200 percent, or 50 percent for Generators in a Constrained Area in Bid Production Cost guarantee payments to a Market Party for a Generator for a day; or

23.3.2.1.3 for a Constrained Area Generator subject to either a Real-Time Market or Day-Ahead Market conduct threshold, as specified above in Sections 23.3.1.1.1, 23.3.1.2.2.1, or 23.3.1.2.2.3: for all Constrained Hours (as defined in Section 23.3.1.2.2.1 for the Real-Time Market and in Section 23.3.1.2.2.3 for the Day-Ahead Market) for the unit being Bid, a threshold determined in accordance

with the formula specified in Section 23.3.1.2.2.1 for the Real-Time Market or Section 23.3.1.2.2.3 for the Day-Ahead Market.

23.3.2.2 Price Impact Analysis

23.3.2.2.1 When it has the capability to do so, the ISO shall determine the effect on prices or guarantee payments of questioned conduct through the use of sensitivity analyses performed using the ISO's SCUC, RTC and RTD computer models, and such other computer modeling or analytic methods as the ISO shall deem appropriate following consultation with its Market Monitoring Unit. The responsibilities of the Market Monitoring Unit that are addressed in this section of the Mitigation Measures are also addressed in Section 30.4.6.2.4 of Attachment O.

23.3.2.2.2 Pending development of the capability to use automated market models, the ISO, following consultation with its Market Monitoring Unit, shall determine the effect on prices or guarantee payments of questioned conduct using the best available data and such models and methods as they shall deem appropriate. The responsibilities of the Market Monitoring Unit that are addressed in this section of the Mitigation Measures are also addressed in Section 30.4.6.2.5 of Attachment O.

23.3.2.2.3 The ISO shall implement automated procedures within the SCUC for Constrained Areas, and within RTC for Constrained Areas. Such automated procedures will: (i) determine whether any Day-Ahead or Real-Time Energy Bids, including start-up costs Bids and Minimum Generation Bids but excluding Ancillary Services Bids and Bids that only violate the conduct thresholds

specified in Sections 23.3.1.2.1.1.2(b) or 23.3.1.2.2.6(b) of these Mitigation Measures, that have not been adequately justified to the ISO exceed the thresholds for economic withholding specified in Section 23.3.1.2 above; and, if so, (ii) determine whether such Bids would cause material price effects or changes in guarantee payments as specified in Section 23.3.2.1.

23.3.2.2.4 The ISO shall forgo performance of the additional SCUC and RTC passes necessary for automated mitigation of Bids in a given Day-Ahead Market or Real-Time Market if evaluation of unmitigated Bids results in prices at levels at which it is unlikely that the thresholds for Bid mitigation will be triggered.

23.3.2.3 Section 205 Filings

The ISO shall make a filing under § 205 with the Commission seeking authorization to apply an appropriate mitigation measure to conduct that departs significantly from the conduct that would be expected under competitive market conditions but does not rise to the thresholds specified in Sections 23.3.1.1 through 23.3.1.3 above if that conduct has a significant effect on market prices or guarantee payments as specified below, unless the ISO determines, from information provided by the Market Party or Parties (which may include a Demand Side Resource participating in the Operating Reserves or Regulation Service Markets) that would be subject to mitigation, or from other information available to the ISO that the conduct and associated price or guarantee payment effect(s) are attributable to legitimate competitive market forces or incentives. For purposes of this section, conduct shall be deemed to have an effect on market prices or guarantee payments that is significant if it exceeds one of the following thresholds:

23.3.2.3.1 an increase of 100 percent in the hourly day-ahead or real-time energy LBMP at any location, or of any other price in an ISO Administered Market; or

23.3.2.3.2 an increase of 100 percent in Bid Production Cost guarantee payments to a Market Party for a Generator for a day, or an increase of 100 percent in any other guarantee payment over the time period used by the ISO to calculate the guarantee payment.

23.3.3 Consultation with a Market Party

23.3.3.1 Consultation Process

23.3.3.1.1 *Consultation initiated by the ISO to determine if mitigation is appropriate:*

Applies to Market-Party-specific and/or Generator-specific mitigation, but not to mitigation that is applied pursuant to Sections 23.3.1.2.3, 23.3.2.2.3, or 23.5.2 of these mitigation measures. If through the application of an appropriate index or screen or other monitoring of market conditions, conduct is identified that (i) exceeds an applicable threshold, and (ii) has a material effect, as specified above, on one or more prices or guarantee payments in an ISO Administered Market, the ISO shall, as and to the extent specified in Attachment O or in Section 23.3.3.2 of these Mitigation Measures, contact the Market Party engaging in the identified conduct to request an explanation of the conduct.

23.3.3.1.2 *Consultation initiated by a Market Party when it anticipates that its Generator's marginal costs or other Bid parameters may exceed the Generator's reference level(s) by more than the relevant threshold(s).* If a Market Party anticipates submitting Bids in a market administered by the ISO that will exceed the thresholds specified in Section 23.3.1 above for identifying conduct inconsistent with competition, the Market Party may contact the

ISO to provide an explanation of any legitimate basis for any such changes in the Market Party's Bids.

23.3.3.1.3 *Results of consultation process addressing Bids.* If a Market Party's explanation of the reasons for its bidding indicates to the satisfaction of the ISO that the questioned conduct is consistent with competitive behavior, no further action will be taken. A preliminary determination by the ISO shall be provided to the Market Monitoring Unit for its review and comment.

23.3.3.1.4 *Consultation initiated by a Market Party regarding reference levels.* Upon request, the ISO shall consult with a Market Party or its representative with respect to the information and analysis used to determine reference levels under Section 23.3.1.4 for that Market Party's Generator(s). If cost data or other information submitted by a Market Party's Generator(s) indicates to the satisfaction of the ISO that the reference levels for that Market Party should be changed, revised reference levels shall be proposed by the ISO, communicated to the Market Monitoring Unit for its review and comment and, following the ISO's consideration of any recommendations that the Market Monitoring Unit is able to timely provide, communicated to the Market Party, and implemented by the ISO as soon as practicable. Changes to the reference levels addressed pursuant to the terms of this Section 23.3.3.1.4 shall be implemented on a going-forward basis commencing no earlier than the date that the Market Party's consultation request is received. The responsibilities of the Market Monitoring Unit that are addressed in this section of the Mitigation Measures are also addressed in Section 30.4.6.2.6 of Attachment O.

23.3.3.1.5 *Information required to support consultation regarding Bids and reference levels.* Market Parties shall ensure that the information they submit to the ISO,

including but not limited to fuel price and fuel type information, is accurate. Except as set forth in Section 23.3.1.4.6.8, the ISO may not retroactively revise a reference level to reflect additional fuel costs if a Market Party or its representative did not timely submit accurate fuel cost information. Unsupported speculation by a Market Party does not present a valid basis for the ISO to determine that Bids that a Market Party submitted are consistent with competitive behavior, or to determine that submitted costs are appropriate for inclusion in the ISO's development of reference levels. Consistent with Sections 30.6.2.2 and 30.6.3.2 of the Plan, the Market Party shall retain the documents and information supporting its Bids and the costs it proposes to include in reference levels.

23.3.3.2 Consultation Requirements

23.3.3.2.1 The ISO shall make a reasonable attempt to contact and consult with the relevant Market Party about the Market Party's reference level(s) before imposing conduct and impact mitigation, other than conduct and impact mitigation imposed through the automated procedures described in Section 23.3.2.2.3 of these Mitigation Measures. The ISO shall keep records documenting its efforts to contact and consult with the Market Party.

23.3.3.2.2 Consultation regarding both real-time guarantee payment mitigation and mitigation of Generators committed outside the economic evaluation process in the Day-Ahead or Real-Time Markets to protect or preserve system reliability in accordance with Section 23.3.1.2.3 of these Mitigation Measures is addressed in Section 23.3.3.3, below. Consultation regarding Day-Ahead guarantee payment mitigation of Generators, other than mitigation imposed through the automated procedures described in Section 23.3.2.2.3 of these Mitigation Measures, shall be

conducted in accordance with Sections 23.3.3.1 and 23.3.3.2 of these Mitigation Measures.

23.3.3.3 Consultation Rules for Real-Time Guarantee Payment Mitigation

23.3.3.3.1 Real-Time Guarantee Payment Consultation Process

23.3.3.3.1.1 For real-time guarantee payment mitigation determined pursuant to Sections 23.3.1.2.1 or 23.3.1.2.2, and 23.3.2.1.2 of these Mitigation Measures, the ISO shall electronically post settlement results informing Market Parties of Bid(s) that failed the real-time guarantee payment impact test. The settlement results posting shall include the adjustment to the guarantee payment and the mitigated Bid(s). The initial posting of settlement results ordinarily occurs two days after the relevant real-time market day.

23.3.3.3.1.2 For real-time guarantee payment mitigation determined pursuant to Sections 23.3.1.2.1 or 23.3.1.2.2, and 23.3.2.1.2 of these Mitigation Measures, no more than two business days after new or revised real-time guarantee payment impact test settlement results are posted, the ISO will send an e-mail or other notification to all potentially impacted Market Parties that comply with Section 23.3.3.3.1.2.2 of these Mitigation Measures.

23.3.3.3.1.2.1 Although the ISO is authorized to take up to two business days to provide notification to all potentially impacted Market Parties that comply with Section 23.3.3.3.1.2.2 of these Mitigation Measures, the ISO shall undertake reasonable efforts to provide notification to such Market Parties within one business day after new or revised real-time guarantee payment impact test settlement results are posted.

23.3.3.3.1.2.2 A Market Party that desires to receive notification from the ISO must provide one e-mail address to the ISO for real-time guarantee payment mitigation notices. Each Market Party is responsible for maintaining and monitoring the e-mail address it provides, and informing the ISO of any change(s) to that e-mail address in order to continue to receive e-mail notification. E-mail will be the ISOs primary method of providing notice to Market Parties.

23.3.3.3.1.2.3 Regardless of whether a Market Party chooses to receive notification from the ISO, each Market Party is responsible for reviewing its posted real-time guarantee payment impact test settlement results and for contacting the ISO to request a consultation if and when appropriate.

23.3.3.3.1.3 The following notice rules apply to guarantee payment mitigation determined pursuant to Section 23.3.1.2.3 of these Mitigation Measures.

23.3.3.3.1.3.1 For mitigation of a Generator's Minimum Generation Bid, Start-Up Bid or Incremental Energy Bid resulting from its DARU or SRE commitment, the ISO shall send an e-mail or other notification to potentially impacted Market Parties that comply with Section 23.3.3.3.1.2.2 of these Mitigation Measures within ten business days after the relevant market day, and shall undertake reasonable efforts to provide notification to such Market Parties within two business days after the relevant market day. The e-mail shall identify the date of the proposed mitigation and the Bid(s) or Bid components that the NYISO proposes to mitigate for all or part of the relevant market day.

As soon as it is able to do so, the NYISO will commence electronically posting settlement results informing Market Parties of Bid(s) that failed the Section

23.3.1.2.3 test and sending an e-mail or other notification to potentially impacted Market Parties that comply with Section 23.3.3.1.2.2 of these Mitigation Measures. The settlement results posting shall include the mitigated bid(s). The posting of settlement results ordinarily occurs two days after the relevant real-time market day.

23.3.3.1.3.2 For mitigation of a Generator's Minimum Generation Bid, Start-Up Bid or Incremental Energy Bid resulting from an Out-of-Merit dispatch above the Generator's DARU or SRE commitment, the ISO shall send an e-mail or other notification to potentially impacted Market Parties that comply with Section 23.3.3.1.2.2 of these Mitigation Measures within 10 business days after the relevant market day. The e-mail shall identify the date of the proposed mitigation and the bid(s) or bid components that the NYISO proposes to mitigate for all or part of the relevant market day.

23.3.3.1.3.3 For mitigation based on a Generator's minimum run time, start-up time, minimum down time, minimum generation MWs, or maximum number of stops per day, or for mitigation based on temporal or operating parameters related to the withdrawal and injection of Energy by Withdrawal-Eligible Generators, the ISO shall send an e-mail or other notification to potentially impacted Market Parties that comply with Section 23.3.3.1.2.2 of these Mitigation Measures within 10 business days after the relevant market day. The e-mail shall identify the date of the proposed mitigation and the conduct failing Bid(s) or Bid components.

23.3.3.3.1.4 Market Parties that want to consult with the ISO regarding real-time guarantee payment impact test results, or regarding mitigation applied in accordance with Section 23.3.1.2.3 of these Mitigation Measures, for a particular market day must submit a written request to initiate the consultation process that specifies the market day and Bid(s) for which consultation is being requested (for purposes of this Section 23.3.3.3.1, a “Consultation Request”).

23.3.3.3.1.4.1 Consultation Requests must be received by the ISO’s customer relations department within 15 business days after the ISO (i) posts new or revised real-time guarantee payment impact test settlement results, or (ii) either posts new or revised real-time guarantee payment impact test settlement results or sends an e-mail informing a Market Party of the results of a test performed pursuant to Section 23.3.1.2.3 of these Mitigation Measures for the relevant market day. Consultation Requests received outside the 15 business day period shall be rejected by the ISO.

23.3.3.3.1.4.2 The ISO may send more than one notice informing a Market Party of the same instance of mitigation. Notices that identify real-time guarantee payment impact test or Section 23.3.1.2.3 mitigation settlement results that are not new (for which the Market Party has already received a notice from the ISO) and that do not reflect revised mitigation (for which the dollar impact of the real-time guarantee payment mitigation has not changed) shall not present an additional opportunity, or temporally extend the opportunity, for the Market Party to initiate consultation.

23.3.3.3.1.4.3 If consultation was timely requested and completed addressing a particular set of real-time guarantee payment impact test results, or addressing a particular instance of mitigation applied in accordance with Section 23.3.1.2.3 of these Mitigation Measures, a Market Party may not again request consultation regarding the same real-time guarantee payment impact test results, or the same application of Section 23.3.1.2.3 mitigation, unless revised settlement results, that are not due to the previously completed consultation and that change the dollar impact of the relevant instance of mitigation, are posted.

23.3.3.3.1.5 The Consultation Request may include: (i) an explanation of the reason(s) why the Market Party believes some or all of the reference levels used by the ISO for the market day(s) in question are inappropriate, or why some or all of the Market Party's Bids on the market day(s) in question were otherwise consistent with competitive behavior; and (ii) supporting documents, data and other relevant information (collectively, for purposes of this Section 23.3.3.3.1, "Data"), including proof of any cost(s) claimed.

23.3.3.3.1.5.1 Market Parties shall ensure that the information they submit to the ISO, including but not limited to fuel price and fuel type information, is accurate. Except as set forth in Section 23.3.1.4.6.8, the ISO may not retroactively revise a reference level to reflect additional fuel costs if a Market Party or its representative did not timely submit accurate fuel cost information. Except as set forth in Section 23.3.1.4.8.9, the ISO may not retroactively revise a reference level to reflect additional opportunity costs if a Market Party or its representative did not timely submit accurate opportunity cost information.

23.3.3.3.1.6 If the Market Party is not able to provide (i) an explanation of the reason(s) why the Market Party believes some or all of the reference levels used by the ISO for the market day(s) in question are inappropriate, or why some or all of the Market Party's Bids on the market day(s) in question were otherwise consistent with competitive behavior, or (ii) all supporting Data, at the time a Consultation Request is submitted, the Market Party should specifically identify any additional explanation or Data it intends to submit in support of its Consultation Request and provide an estimate of the date by which it will provide the additional explanation or Data to the ISO.

23.3.3.3.1.7 Following the submission of a Consultation Request that satisfies the timing and Bid identification requirements of Section 23.3.3.3.1.4, above, consultation shall be performed in accordance with Section 23.3.3.1 of these Mitigation Measures, as supplemented by the following rules:

23.3.3.3.1.7.1 The ISO shall consult with the Market Party to determine whether the information available to the ISO presents an appropriate basis for (i) modifying the reference levels used to perform real-time guarantee payment mitigation for the market day in question, or (ii) determining that the Market Party's Bid(s) on the market day in question were consistent with competitive behavior. The ISO shall only modify the reference levels used to perform mitigation, or determine that the Market Party's Bid(s) on the market day that is the subject of the Consultation Request were consistent with competitive behavior, if the ISO has in its possession Data that is sufficient to support such a decision.

23.3.3.3.1.7.2 A preliminary determination by the ISO shall be provided to the Market Monitoring Unit for its review and comment, and the ISO shall consider the Market Monitoring Unit's recommendations in reaching its decision. The ISO shall inform the Market Party of its decision, in writing, as soon as reasonably practicable, but in no event later than (i) 50 business days after the new or revised real-time guarantee payment impact test settlement results for the relevant market day were posted, or (ii) 50 business days after the earlier of the posting of new or revised Section 23.3.1.2.3 mitigation settlement results for the relevant market day, or the issuance of an e-mail in accordance with Section 23.3.3.3.1.3, above. If the ISO does not affirmatively determine that it is appropriate to modify the Bid(s) that are the subject of the Consultation Request within 50 business days, the Bid(s) shall remain mitigated. The responsibilities of the Market Monitoring Unit that are addressed in this section of the Mitigation Measures are also addressed in Section 30.4.6.2.7 of Attachment O.

23.3.3.3.1.7.3 The ISO may, as soon as practicable, but at any time within the consultation period, request Data from the Market Party. The Market Party is expected to undertake all reasonable efforts to provide the requested Data as promptly as possible, to inform the ISO of the date by which it expects to provide requested Data, and to promptly inform the ISO if the Market Party does not intend to, or cannot, provide Data that has been requested by the ISO.

23.3.3.3.1.8 This Section 23.3.3.3.1 addresses Consultation Requests. It is not intended to limit, alter or modify a Market Party's ability to submit or proceed

with a billing dispute pursuant to Section 7.4 of the ISO Services Tariff or Section 2.7.4.1 of the ISO OATT.

23.3.3.3.2 Revising Reference Levels of Certain Generators Committed Out-of-Merit or via Supplemental Resource Evaluation for Conducting Real-Time Guarantee Payment Conduct and Impact Tests and Applying Mitigation in Accordance with Section 23.3.1.2.3 of these Mitigation Measures

23.3.3.3.2.1 Consistent with and subject to all of the requirements of Section 23.3.3.3.1 of these Mitigation Measures, Generators that (i) are committed Out-of-Merit or via a Supplemental Resource Evaluation after the DAM has posted, and (ii) for which the NYISO has posted real-time guarantee payment impact test settlement results, or identified possible mitigation under Section 23.3.1.2.3 of these Mitigation Measures may contact the ISO within 15 business days after new or revised impact test settlement results are posted, or possible mitigation under Section 23.3.1.2.3 of these Mitigation Measures is identified, to request that the reference levels used to perform the testing and mitigation be adjusted to include any of the following verifiable costs:

23.3.3.3.2.1.1 procuring fuel at prices that exceed the index prices used to calculate the Generator's reference level;

23.3.3.3.2.1.2 burning a type of fuel or blend of fuels that is not reflected in the Generator's reference level;

23.3.3.3.2.1.3 permitted gas balancing charges;

23.3.3.3.2.1.4 compliance with operational flow orders;

23.3.3.3.2.1.5 purchasing additional emissions allowances that are necessary to satisfy the Generator's Supplemental Resource Evaluation or Out-of-Merit schedule; and

23.3.3.3.2.1.6 demonstrated opportunity costs that exceed the opportunity cost used in calculating the Generator's reference level.

23.3.3.3.2.2 The six categories of verifiable costs specified above shall be used to modify the requesting Generator's reference level(s) subject to the following prerequisites:

23.3.3.3.2.2.1 the Generator must specifically and accurately identify and document the extraordinary costs it has incurred to operate during the hours of its Supplemental Resource Evaluation or Out-of-Merit commitment; and

23.3.3.3.2.2.2 the costs must not already be reflected in the Generator's reference levels or be recovered from the ISO through other means.

As soon as practicable after the Market Party demonstrates to the ISO's reasonable satisfaction that one or more of the five categories of extraordinary costs have been incurred, but in no event later than the deadline set forth in Section 23.3.3.3.1.7.2 of these Mitigation Measures, the ISO shall adjust the affected Generator's reference levels and re-perform the real-time guarantee payment conduct and impact tests, or the Section 23.3.1.2.3 test, as appropriate, for the affected day. Only the reference levels used to perform real-time guarantee payment mitigation and/or mitigation pursuant to Section 23.3.1.2.3 of these Mitigation Measures, will be adjusted.

23.3.3.3.2.3 If, at some point prior to the issuance of a Close-Out Settlement for the relevant service month, the ISO or the Commission determine that some or all of the costs claimed by the Market Party during the consultation process described above were not, in fact, incurred over the course of the Out-of-Merit or Supplemental Resource Evaluation commitment, or were recovered from the ISO

through other means, the ISO shall re-perform the appropriate test(s) using reference levels that reflect the verifiable costs that the Generator incurred and shall apply mitigation if the Generator's Bids fail conduct and impact, or the Section 23.3.1.2.3 test, at the corrected reference levels.

23.3.3.3.2.4 Generators may contact the ISO to request the inclusion of costs other than the six types identified above in their reference levels. The ISO shall consider such requests in accordance with Sections 23.3.1.4, or 23.3.3.3.1 of these Mitigation Measures, as appropriate.

23.4 Mitigation Measures

23.4.1 Purpose and Terms

If conduct is detected that meets the criteria specified in Section 23.3, the appropriate mitigation measure described in this Section shall be applied by the ISO. The conduct specified in Sections 23.3.1.1 to 23.3.1.3 shall be remedied by (1) the prospective application of a default bid measure, or (2) the application of a default bid to correct guarantee payments, as further described in Section 23.4.2.2.4, below, or (3) the application of the sanction described in Section 23.4.3 of these Mitigation Measures if (x) a Withdrawal-Eligible Generator located outside the Constrained Area engages in conduct that violates Section 23.3.1.2.1.1.2(a) of these Mitigation Measures that has an LBMP impact that exceeds the applicable threshold, or (y) a Withdrawal-Eligible Generator engages in conduct that violates Sections 23.3.1.2.1.1.2(b) or 23.3.1.2.2.6(b) of these Mitigation Measures that has an LBMP impact that exceeds the applicable threshold in the Day-Ahead Market. If a Market Party or its Affiliates engage in physical withholding by providing the ISO false information regarding the derating or outage of an Electric Facility or does not operate a Generator in conformance with ISO dispatch instructions such that the prospective application of a default bid is not feasible, or if otherwise appropriate to deter either physical or economic withholding, the ISO shall apply the sanction described in Section 23.4.3.

Terms with initial capitalization not defined in Section 23.4 shall have the meaning set forth in the Open Access Transmission Tariff.

23.4.2 Default Bid

23.4.2.1 Purpose

A default bid shall be designed to cause a Market Party to Bid as if it faced workable competition during a period when (i) the Market Party does not face workable competition, and

(b) has responded to such condition by engaging in the physical or economic withholding of an Electric Facility. In designing and implementing default bids, the ISO shall seek to avoid causing an Electric Facility to Bid below its marginal cost.

23.4.2.2 Implementation

23.4.2.2.1 If the criteria contained in Section 23.3 are met, the ISO may substitute a default bid or bid parameter for a Bid or bid parameter submitted for an Electric Facility, or require the Market Party to use the default bid or bid parameter in the Bids it submits for an Electric Facility. The default bid or bid parameter shall establish a maximum or minimum value for one or more components of the submitted Bid or Bid parameters, equal to a reference level for that component determined as specified in Section 23.3.1.4.

23.4.2.2.1.1 If the substitution of a default bid or bid parameter(s) for any portion of the Incremental Energy Bid curve submitted for an Energy Storage Resource would result in a mitigated energy curve that is not consistent with the Energy Storage Resource's Roundtrip Efficiency, then the default bid or bid parameter(s) to inject Energy will be adjusted to the minimum extent necessary to ensure the difference between bids to withdraw Energy and bids to inject Energy incorporate the Energy Storage Resource's Roundtrip Efficiency.

23.4.2.2.2 An Electric Facility subject to a default bid shall be paid the LBMP or other market clearing price applicable to the output from the facility. Accordingly, a default bid shall not limit the price that a facility may receive unless the default bid determines the LBMP or other market clearing price applicable to that facility.

23.4.2.2.3 If an Electric Facility is mitigated using the automated mitigation procedures described in Section 23.3.2.2.3 of these mitigation measures to a default bid for an Incremental Energy Bid other than a default bid determined as specified in Section 23.3.1.4, the Electric Facility shall receive an additional payment for each interval in which such mitigation occurs equal to the product of: (i) the amount of Energy in that interval scheduled or dispatched to which the incorrect default bid was applied; (ii) the difference between (a) the lesser of the applicable unmitigated bid and a default bid determined in accordance with Section 23.3.1.4, and (b) the applicable LBMP or other relevant market price in each such interval, if (a) greater than (b), or zero otherwise; and (iii) the length of that interval.

If an Electric Facility is mitigated to a default bid for a Start-Up Bid or a Minimum Generation Bid other than a default bid determined as specified in Section 23.3.1.4 of these Mitigation Measures, or if an Electric Facility is mitigated to a default bid for an Incremental Energy Bid other than a default bid determined as specified in Section 23.3.1.4 of these Mitigation Measures based on mitigation procedures other than the automated mitigation procedures described in Section 23.3.2.2.3 of these Mitigation Measures, then the ISO shall determine if the Bids would have failed the relevant conduct test(s) if correctly determined default bids had been used. The ISO shall then restore any original (as-submitted) Bid(s) that would not have failed the relevant conduct test(s) if correctly determined default bids had been used, and use the restored Bid(s) to determine a

settlement. Otherwise, the ISO shall use the Generator's correct or corrected default bid(s) to determine a settlement.

23.4.2.2.4 Except as may be specifically authorized by the Commission:

23.4.2.2.4.1 The ISO shall not use a default bid to determine revised market clearing prices for periods prior to the imposition of the default bid.

23.4.2.2.4.2 The ISO shall only be permitted to apply default bids to determine revised real-time guarantee payments to a Market Party in accordance with the provisions of Section 23.3.3.3 of these Mitigation Measures.

23.4.2.2.5 Automated implementation of default bid mitigation measures shall be subject to the following requirements.

23.4.2.2.5.1 Automated mitigation measures shall not be applied if the price effects of the measures would cause the average day-ahead energy price in the mitigated locations or zones to rise over the entire day.

23.4.2.2.5.2 Automated mitigation measures as specified in Section 23.3.2.2.3 shall be applied to Minimum Generation Bids and start-up costs Bids meeting the applicable conduct and impact tests. When mitigation of Minimum Generation Bids is warranted, mitigation shall be imposed from the first hour in which the impact test is met to the last hour in which the impact test is met, or for the duration of the mitigated Generator's minimum run time, whichever is longer.

23.4.2.2.5.3 The posting of the Day-Ahead schedule may be delayed if necessary for the completion of automated mitigation procedures.

23.4.2.2.5.4 Bids not mitigated under automated procedures shall remain subject to mitigation by other procedures specified herein as may be appropriate.

23.4.2.2.5.5 The role of automated mitigation measures in the determination of Day-Ahead market clearing prices is described in Section 17.1.3 of Attachment B of the ISO Services Tariff.

23.4.2.2.6 A Real-Time automated mitigation measure shall remain in effect for the duration of any hour in which there is an RTC interval for which such mitigation is deemed warranted.

23.4.2.2.7 A default bid shall not be imposed on a Generator that is not in the New York Control Area and that is electrically interconnected with another Control Area.

23.4.3 Sanctions

23.4.3.1 Types of Sanctions

The ISO may impose financial penalties on a Market Party in amounts determined as specified below.

23.4.3.2 Imposition

The ISO shall impose financial penalties as provided in this Section 23.4.3, if the ISO determines in accordance with the thresholds and other standards specified in this Attachment H that: (i) a Market Party has engaged in physical withholding, including providing the ISO false information regarding the derating or outage of an Electric Facility; or (ii) a Market Party or its Affiliates have failed to follow the ISO's dispatch instructions in real-time, resulting in a different output level than would have been expected had the Market Party's or the Affiliate's generation followed the ISO's dispatch instructions, and such conduct has caused a material increase in one or more prices or guarantee payments in an ISO Administered Market; or (iii) a Market Party has made unjustifiable changes to one or more operating parameters of a Generator that reduce its

ability to provide Energy or Ancillary Services; or (iv) a Load Serving Entity has been subjected to a Penalty Level payment in accordance with Section 23.4.4 below; or (v) a Market Party has submitted inaccurate fuel type or fuel price or opportunity cost information that is used by the ISO in the development of a Resource's reference level, where the inaccurate reference level that is developed, in turn, directly or indirectly impacts guarantee payments or market clearing prices paid to the Market Party; or (vi) a Market Party has submitted inaccurate information other than fuel type or fuel price information that is used by the ISO in the development of a Resource's reference level, where the inaccurate reference level that is developed, in turn, directly or indirectly impacts guarantee payments or market clearing prices paid to the Market Party; or (vii) the opportunity to submit Incremental Energy Bids into the real-time market that exceed Incremental Energy Bids made in the Day-Ahead Market or mitigated Day-Ahead Incremental Energy Bids where appropriate, has been revoked for a Market Party's Generator pursuant to Sections 23.4.7.2 and 23.4.7.3 of these Mitigation Measures; or (viii) a Market Party has engaged in economic withholding in the Day-Ahead Market by submitting Incremental Energy Bids that violate the conduct thresholds specified in Sections 23.3.1.2.1.1.2(b) or 23.3.1.2.2.6(b) of these Mitigation Measures and cause an LBMP impact that exceeds the applicable threshold; or (ix) a Market Party has engaged in economic withholding of a Withdrawal-Eligible Generator located outside the Constrained Area by submitting Incremental Energy Bids that violate the conduct threshold specified in Section 23.3.1.2.1.1.2(a) of these Mitigation Measures and cause an LBMP impact that exceeds the applicable threshold.

23.4.3.3 Base Penalty Amount

23.4.3.3.1 Except for financial penalties determined pursuant to Sections 23.4.3.3.2, 23.4.3.3.3, and 23.4.3.3.4 below, financial penalties shall be determined by the

product of the Base Penalty Amount, as specified below, times the appropriate multiplier specified in Section 23.4.3.4:

MW meeting the standards for mitigation during Mitigated Hours * Penalty market-clearing price.

23.4.3.3.1.1 For purposes of determining a Base Penalty Amount, the term “Mitigated Hours” shall mean: (i) for a Day-Ahead Market, the hours in which MW were withheld; (ii) for a Real-Time Market, the hours in the calendar day in which MW were withheld; and (iii) for load Bids, the hours giving rise to Penalty Level payments.

23.4.3.3.1.1.1 For purposes of determining a Base Penalty Amount for economic withholding related to Bids that the ISO evaluates as a price spread for purposes of scheduling and dispatch, the term “Mitigated Hours” shall instead mean:

(i) for the Day-Ahead Market, for Withdrawal-Eligible Generators located outside the Constrained Area, all hours of the day in which an LBMP impact is determined after the NYISO replaces all Incremental Energy Bids that violate the conduct thresholds specified in Sections 23.3.1.2.1.1.2(a) or 23.3.1.2.1.1.2(b) of these Mitigation Measures with reference levels; or

(ii) for the Day-Ahead Market, for Withdrawal-Eligible Generators located in the Constrained Area, all hours of the day in which an LBMP impact is determined after the NYISO replaces all Incremental Energy Bids that violate the conduct thresholds specified in Section 23.3.1.2.2.6(b) of these Mitigation Measures with reference levels; or

(iii) for the Real-Time Market, for Withdrawal-Eligible Generators located outside the Constrained Area, all hours of the day in which an LBMP impact is determined after the NYISO replaces all Incremental Energy Bids that violate the conduct thresholds specified in Sections 23.3.1.2.1.1.2(a) of these Mitigation Measures with reference levels.

In each of the above cases, the “MW meeting the standards for mitigation during Mitigated Hours” shall be all scheduled MW.

23.4.3.3.1.2 For purposes of determining a Base Penalty Amount, the term “Penalty market-clearing price” shall mean: (i) for a withholding seller, the LBMP or other market-clearing price at the generator bus of the withheld resource (or in the relevant Load Zone, if a clearing price is not calculated at the generator bus); and (ii) for a Load Serving Entity, its zonal LBMP.

23.4.3.3.1.2.1 For purposes of determining a Base Penalty Amount for economic withholding related to Bids that the ISO evaluates as a price spread for purposes of scheduling and dispatch, the “Penalty market-clearing price” shall instead mean the difference between the market clearing price that was set and the market clearing price would instead be determined if reference levels are substituted for conduct-failing Incremental Energy Bids.

23.4.3.3.2 Failure to Follow ISO Dispatch Instructions

The financial penalty for failure to follow ISO’s dispatch instructions in real-time, resulting in real-time operation at a different output level than would have been expected had the Market Party’s or the Affiliate’s generation followed the ISO’s dispatch instructions, if the conduct violates the thresholds set forth in

Sections 23.3.1.1.1.2, or 23.3.1.3.1.2 of these Mitigation Measures, and if a Market Party or its Affiliates, or at least one Generator, is determined to have had impact in accordance with Section 23.3.2.1 of these Mitigation Measures, shall be:

One and a half times the estimated additional real time LBMP and Ancillary Services revenues earned by the Generator, or Market Party and its Affiliates, meeting the standards for impact during intervals in which MW were not provided or were overproduced.

23.4.3.3.3 Submission of Inaccurate Fuel Type, Fuel Price or Opportunity Cost Information

If inaccurate fuel type, fuel price or opportunity cost information was submitted by or for a Market Party, and the reference level that the ISO developed based on that inaccurate information impacted guarantee payments or market clearing prices paid to the Market Party in a manner that violates the thresholds specified in this Section 23.4.3.3.3, then, following consultation with the Market Party regarding the appropriate fuel type, fuel price or opportunity cost, the ISO shall apply the penalty set forth below, unless: (i) the Market Party shows that the information was submitted in compliance with the requirements of Section 4.1.9 of the ISO Services Tariff (Cost Recovery for Units Responding to Local Reliability Rules Addressing Loss of Generator Gas Supply), or (ii) the total penalty calculated for a particular Day-Ahead or Real-Time Market day is less than \$5,000, in which case the ISO will not apply a penalty.

23.4.3.3.3.1 Inaccurate Fuel Type and/or Fuel Price Information Conduct and Market Impact Tests

23.4.3.3.3.1.1 Inaccurate Fuel Type and/or Fuel Price Information Conduct Test and Inaccurate Opportunity Cost Conduct Test

Inaccurate Fuel Price/Type Conduct Test—using the higher of (a) a revised reference level calculated using the Generator’s actual fuel costs, or (b) the reference level that would have been in place for the Generator but for the submission of inaccurate fuel type and/or fuel price information, test the Bids to determine if they violate the relevant conduct threshold in accordance with the appropriate provision(s) of Section 23.3.1.2 of these Mitigation Measures.

Inaccurate Opportunity Cost Conduct Test—using the higher of (a) a revised reference level calculated using the Generator’s demonstrated opportunity cost, or (b) the reference level that would have been in place for the Generator but for the submission of inaccurate opportunity cost information, test the Bids to determine if they violate the relevant conduct threshold in accordance with the appropriate provision(s) of Section 23.3.1.2 of these Mitigation Measures.

23.4.3.3.3.1.2 Inaccurate Fuel Type and/or Fuel Price Information Impact Test and Inaccurate Opportunity Cost Conduct Test

Inaccurate Fuel Price/Type Impact Test—using the higher of (a) a revised reference level calculated using the Generator’s actual fuel costs, or (b) the reference level that would have been in place for the Generator but for the submission of inaccurate fuel type and/or fuel price information, test the Bids for both LBMP and guarantee payment impact in accordance with the appropriate provisions of Section 23.3.2.1 of these Mitigation measures.

Inaccurate Opportunity Cost Impact Test—using the higher of (a) a revised reference level calculated using the Generator’s demonstrated opportunity cost, or (b) the reference level that would have been in place for the Generator but for the submission of inaccurate opportunity cost information, test the Bids for both LBMP and guarantee payment impact in accordance with the appropriate provisions of Section 23.3.2.1 of these Mitigation measures.

23.4.3.3.3.1.2.1 The ISO shall perform the guarantee payment impact tests for Generators that are committed in the Day-Ahead Market for local reliability or in the Real-Time Market via an SRE, and that are not located in a Constrained Area, at the 50% increase Constrained Area threshold specified in Section 23.3.2.1.2 of these Mitigation Measures.

23.4.3.3.3.1.3 Day-Ahead Reliability Commitments in a Constrained Area

Consistent with Section 23.5.2 of these Mitigation Measures, the conduct and impact thresholds for In-City Generators committed in the Day-Ahead Market for local reliability shall each be zero.

23.4.3.3.3.2 Inaccurate Fuel Type and/or Fuel Price and/or Opportunity Cost Information Penalty Calculation

If the results of the impact test indicate that the Market Party’s Bid had either LBMP or guarantee payment impact then the ISO shall charge the Market Party a penalty, calculated separately for the Day-Ahead Market and the Real-Time Market for each penalized day, for each of its Generators, as follows:

Daily Penalty (for either the Day-Ahead Market or the Real-Time Market) =

$$\text{Multiplier} \times \max [\sum_g \blacktriangle \text{BPCG payment}_g +$$

$$\sum_h \sum_g (\text{Market Party } MWh_{gh} \times \blacktriangle \text{ LBMP}@PTID_{gh}) +$$

$$\max (\sum_h \text{TCC Revenue Calc for Market Party}_h, 0), 0]$$

Where:

g = each of the Market Party's Generators.

h = (a) for the purpose of calculating Day-Ahead Market penalties for a given day, h is each hour of that day in which inaccurate fuel type or fuel price or opportunity cost information was supplied in the Day-Ahead Market for any of the Market Party's Generators, provided that one of the Day-Ahead Bids in that hour "h" for at least one of the Market Party's Generators failed an LBMP or guarantee payment impact test described in Section 23.4.3.3.3.1.2 of these Mitigation Measures, or (b) for the purpose of calculating Real-Time Market penalties for a given day, h is each hour of that day in which inaccurate fuel type or fuel price or opportunity cost information was supplied in the Real-Time Market for any of the Market Party's Generators, provided that one of the Real-Time Bids in that hour "h" for at least one of the Market Party's Generators failed an LBMP or guarantee payment impact test described in Section 23.4.3.3.3.1.2 of these Mitigation Measures.

Multiplier = a factor of 1.0 or 1.5. Determined as specified below.

For violations related to fuel price and/or fuel type submissions, the ISO shall use a 1.0 Multiplier if the Market Party has not been penalized for inaccurately reporting fuel type or fuel price information over the 6 months prior to the market-day for which the penalty is being calculated. In all other cases the ISO shall use a 1.5 Multiplier.

For violations related to opportunity cost submissions, the ISO shall use a 1.0 Multiplier if the Market Party has not been penalized for inaccurately reporting opportunity cost information over the 6 months prior to the market-day for which the penalty is being calculated. In all other cases the ISO shall use a 1.5 Multiplier.

▲ $BPCG_{payment_g} = (a)$ for the purpose of calculating Day-Ahead Market penalties for a given day, the change in the Day-Ahead Market guarantee payment for that day for Generator g determined when the ISO performs the guarantee payment impact test in accordance with Section 23.3.2.1.2 of these Mitigation Measures, or (b) for the purpose of calculating Real-Time Market penalties for a given day, the change in the Real-Time guarantee payment for that day for Generator g determined when the ISO performs the guarantee payment impact test in accordance with Section 23.3.2.1.2 of these Mitigation Measures.

Market Party $MWh_{gh} = (a)$ for the purpose of calculating Day-Ahead Market penalties, the MWh of Energy scheduled in the Day-Ahead Market for Generator g in hour h ; or (b) for the purpose of calculating Real-Time Market penalties, the maximum of (1) the MWh of Energy that Generator g was scheduled to produce in the Day-Ahead Market in hour h , or (2) the MWh of Energy that Generator g was scheduled to produce in the Real-Time Market in hour h , or (3) the MWh of Energy produced by Generator g that was scheduled to produce energy in hour h in the Real-Time Market.

▲ $LBMP@PTID_{gh} = (a)$ for the purpose of calculating Day-Ahead Market penalties, the change in the Day-Ahead Market LBMP for hour h at the

location of Generator g, as determined when the ISO performs the relevant LBMP impact test in accordance with Section 23.3.2.1.1 or 23.3.2.1.3 of these Mitigation Measures, or (b) for the purpose of calculating Real-Time Market penalties, the change in the real-time LBMP for hour h at the location of Generator g, as determined when the ISO performs the relevant LBMP impact test in accordance with Section 23.3.2.1.1 or 23.3.2.1.3 of these Mitigation Measures.

TCC Revenue Calc for Market Party_h = (a) for the purpose of calculating Day-Ahead Market penalties, the change in TCC Revenues that the Market Party receives for hour h, determined when the ISO performs the relevant Day-Ahead Market LBMP impact test, or (b) for the purpose of calculating Real-Time Market penalties, zero.

23.4.3.3.4 Virtual Bidding Penalties

23.4.3.3.4.1 If the opportunity to submit Incremental Energy Bids into the Real-Time Market that exceed Incremental Energy Bids made in the Day-Ahead Market or mitigated Day-Ahead Incremental Energy Bids where appropriate, has been revoked on a Market Party's Generator pursuant to Sections 23.4.7.2 and 23.4.7.3 of these Mitigation Measures, then the following virtual market penalty may be imposed on the Market Party:

Virtual market penalty = (Virtual Load MWs) * (Amount by which the hourly integrated real-time LBMP exceeds the day-ahead LBMP applicable to the Virtual Load MWs)

WHERE:

Virtual Load MWs are the scheduled MWs of Virtual Load Bid by the Market Party in the hour for which an increased real-time Bid for the Market Party's Generator failed the test specified in Section 23.4.7.2 of these Mitigation Measures; and

LBMP is the LBMP at which the Virtual Load MWs settled in the Day-Ahead and real-time Markets.

23.4.3.3.4.2 If the opportunity to submit Incremental Energy Bids into the Real-Time Market that are less than the Incremental Energy Bids submitted in the Day-Ahead Market (or the mitigated Day-Ahead Incremental Energy Bids where appropriate), has been revoked on a Market Party's Generator pursuant to Sections 23.4.7.2 and 23.4.7.3 of these Mitigation Measures, then the following virtual market penalty may be imposed on the Market Party:

Virtual market penalty = (Virtual Supply MWs) * (Amount by which the hourly integrated real-time LBMP is less than the day-ahead LBMP applicable to the Virtual Supply MWs)

WHERE:

Virtual Supply MWs are the scheduled MWs of Virtual Supply Bid by the Market Party in the hour for which a reduced real-time Bid for the Market Party's Generator failed the test specified in Section 23.4.7.2 of these Mitigation Measures; and

LBMP is the LBMP at which the Virtual Supply MWs settled in the Day-Ahead and real-time Markets.

23.4.3.3.5 No Revisions to Real-Time LBMPs

Real-Time LBMPs shall not be revised as a result of the imposition of a financial obligation as specified in this Section 23.4.3.3, except as may be specifically authorized by the Commission.

23.4.3.4 Multipliers

The Base Penalty Amount specified in Section 23.4.3.3.1 shall be subject to the following multipliers:

23.4.3.4.1 For the first instance of a type of conduct by a Market Party meeting the standards for mitigation, the multiplier shall be one (1).

23.4.3.4.2 For the second instance within the current or the two immediately previous capability periods of substantially similar conduct in the same market by a Market Party or its Affiliates, the multiplier shall be one (1),

23.4.3.4.3 For the third instance within the current or the two immediately previous capability periods of substantially similar conduct in the same market by a Market Party or its Affiliates, the multiplier shall be two (2),

23.4.3.4.4 For the fourth or any additional instance within the current or immediately previous capability period of substantially similar conduct in the same market by a Market Party or its Affiliates, the multiplier shall be three (3).

23.4.3.5 Dispute Resolution

23.4.3.5.1 Parties with of disputes arising from or relating to the imposition of a sanction under this Section 23.4.3 may utilize the dispute resolution provisions of the ISO Services Tariff. The scope of any such proceeding shall include resolution of any dispute as to legitimate justifications, under applicable legal,

regulatory or policy standards, for any conduct that is asserted to warrant a penalty. Any or all of the issues in any such proceeding may be resolved by agreement of the parties.

23.4.3.5.2 Payment of a financial penalty may be withheld pending conclusion of any arbitration or other alternate dispute resolution proceeding instituted pursuant to the preceding paragraph and any petition to FERC for review under the Federal Power Act of the determination in such dispute resolution proceeding; provided, however, that interest at the ISO's average cost of borrowing shall be payable on any part of the penalty that is withheld, and that is determined to be payable at the conclusion of the dispute resolution/FERC review process from the date of the infraction giving rise to the penalty to the date of payment. The exclusive remedy for the inappropriate imposition of a financial penalty, to the exclusion of any claim for damages or any other form of relief, shall be a determination that a penalty should not have been imposed, and a refund with interest of paid amounts of a penalty determined to have been improperly imposed, as may be determined in the applicable dispute resolution proceedings.

23.4.3.5.3 This Section 23.4.3 shall not be deemed to provide any right to damages or any other form of relief that would otherwise be barred by Section 30.11 of Attachment O or Section 23.6 of this Attachment H.

23.4.3.5.4 This Section 23.4.3 shall not restrict the right of any party to make such filing with the Commission as may otherwise be appropriate under the Federal Power Act.

23.4.3.6 Disposition of Penalty Funds

Except as specified in Section 23.4.4.3.2, amounts collected as a result of the imposition of financial penalties shall be credited against costs collectable under Rate Schedule 1 of the ISO Services Tariff.

23.4.4 Load Bid Measure

23.4.4.1 Purpose

As initially implemented, the ISO market rules allow loads to choose to purchase power in either the Day-Ahead Market or in the Real-Time Market, but provide other Market Parties less flexibility in opting to sell their output in the Real-Time Market. As a result of this and other design features, certain bidding practices may cause Day-Ahead LBMPs not to achieve the degree of convergence with Real-Time LBMPs that would be expected in a workably competitive market. A temporary mitigation measure is specified below as an interim remedy if conditions warrant action by the ISO until such time as the ISO develops and implements an effective long-term remedy, if needed. These measures shall only be imposed if persistent unscheduled load causes operational problems, including but not limited to an inability to meet unscheduled load with available resources. The ISO shall post a description of any such operational problem on its web site.

23.4.4.2 Implementation

23.4.4.2.1 Day-Ahead LBMPs and Real-Time LBMPs in each load zone shall be monitored to determine whether there is a persistent hourly deviation between them in any zone that would not be expected in a workably competitive market. Monitoring of Day-Ahead and real-time LBMPs shall include examination of the following two metrics (along with any additional monitoring tools and procedures

that the ISO determines to be appropriate to achieve the purpose of this Section 23.4.4):

(1) The ISO shall compute a rolling average of the hourly deviation of real-time zonal LBMPs from Day-Ahead zonal LBMPs. The hourly deviation shall be measured as: $(\text{zonal LBMP}_{\text{real time}} - \text{zonal LBMP}_{\text{day ahead}})$. Each observation of the rolling-average time series shall be a simple average of all the hourly deviations over the previous four weeks, or such other averaging period determined by the ISO to be appropriate to achieve the purpose of this Section 23.4.4.

(2) The ISO shall also compute the rolling average *percentage* deviation of real-time zonal LBMPs from Day-Ahead zonal LBMPs. This percentage deviation shall be calculated by dividing the rolling-average hourly deviation (defined in Section 23.4.4.2.1 (1) above) by the rolling-average level of Day-Ahead zonal LBMP over the same time period, using the averaging period(s) described in Section 23.4.4.2.1 (1), above.

23.4.4.2.2 The ISO shall also estimate and monitor the average percentage of each Load Serving Entity's load scheduled in the Day-Ahead Market, using a methodology intended to identify a sustained pattern of under-bidding as accurately as the ISO deems practicable. The average percentage will be computed over a specified time period determined by the ISO to be appropriate to achieve the purpose of this mitigation measure.

23.4.4.2.3 If the ISO determines that (i) the relationship between zonal LBMPs in a zone in the Day-Ahead Market and the Real-Time Market is not what would be expected under conditions of workable competition, (ii) one or more Load

Serving Entities have been meeting a substantial portion of their loads with purchases in the Real-Time Market, and (iii) that this practice has contributed to an unwarranted divergence of LBMP between the two markets, then the following mitigation measure may be imposed. Any such measure shall be rescinded upon a determination by the ISO that any one or more of the foregoing conditions is not met.

23.4.4.3 Description of the Measure

23.4.4.3.1 The ISO may require a Load Serving Entity engaging in the purchasing practice described above to purchase or schedule all of its expected power requirements in the Day-Ahead Market. A Load Serving Entity subject to this requirement may purchase up to a specified portion of its actual load requirements (the “Allowance Level”) in the Real-Time Market without penalty, as determined by the ISO to be appropriate in recognition of the uncertainty of load forecasting.

23.4.4.3.2 Effective with the imposition of the foregoing requirement, all purchases in the Real-Time Market in excess of this Allowance Level (the “Penalty Level”) shall be settled at a specified premium over the applicable zone LBMP. Revenues from such premiums, if any, shall be rebated on a *pro rata* basis to the Market Parties that scheduled energy for delivery to load within New York in the Day-Ahead Market for the day in which the revenues were collected.

23.4.4.3.3 The Allowance Level and the Penalty Level shall be established by the ISO at levels deemed effective and appropriate to mitigate the market effects described in this Section 23.4.4. In addition, the Penalty Level payments shall be

waived in any hour in which the Allowance Level is exceeded because of unexpected system conditions.

23.7 Bid Restrictions for Incremental Energy Bids and Minimum Generation Bids for NYCA Resources

23.7.1

The rules set forth in this Section 23.7 are necessary to implement the Bid Restrictions set forth in Section 21 of the ISO Services Tariff. These rules apply to Day-Ahead and real-time Incremental Energy Bids and Minimum Generation Bids submitted for NYCA Resources that exceed \$1,000/MWh. The rules in Section 23.7 apply in addition to, *not* in lieu of, any other market power mitigation measure, requirement, obligation, penalty or sanction set forth in the ISO's Tariffs.

23.7.2 Cost Comparison

If an Incremental Energy Bid or Minimum Generation Bid submitted on behalf of a NYCA Resource exceeds \$1,000/MWh and complies with the requirements of Sections 23.7.3 (for Generators) or 23.7.4 (for Demand Side Resources) below, then the ISO shall compare the Bid to a cost-based reference level developed in accordance with Sections 23.3.1.4.1.3 and/or 23.3.1.4.2.1, and 23.3.1.4.6 of these Mitigation Measures for Generators, or in accordance with Section 23.7.4 for Demand Side Resources, to determine if it must apply a Bid Restriction.

23.7.2.1 If any component of an Incremental Energy Bid exceeds \$1,000/MWh or if a Minimum Generation Bid exceeds \$1,000/MWh, then the ISO shall use cost-based reference levels to determine if a Bid Restriction should be applied, and to test all components of the Incremental Energy Bid or the Minimum Generation Bid for possible mitigation in accordance with these Mitigation Measures.

23.7.2.1.1 The ISO does not ordinarily include adders above cost in cost-based reference levels. *See* Section 23.3.1.4.1.3 of these Mitigation Measures. If the

ISO ever decides to allow adders above cost to be included in the cost-based based reference levels it uses to determine if a Bid Restriction should be applied, then the combined impact of all of the adders above cost included in the reference level(s) shall be limited to no more than \$100/MWh.

23.7.2.2 If the cost-based reference level the ISO uses to perform the comparison is less than or equal to \$1,000/MWh, then the ISO shall restrict the Incremental Energy Bid or Minimum Generation Bid that exceeds \$1,000/MWh to \$1,000/MWh. Some components of an Incremental Energy Bid curve might exceed \$1,000/MWh while other components of the Bid curve might be less than \$1,000/MWh. If so, the Bid Restriction will apply to the components of the Incremental Energy Bid curve that exceed \$1,000/MWh, for which the associated cost-based reference level is less than or equal to \$1,000/MWh.

23.7.2.2.1 The NYISO shall test all Incremental Energy Bids and Minimum Generation Bids that have been restricted to \$1,000/MWh for possible mitigation in accordance with the rules set forth in these Mitigation Measures.

23.7.2.3 If the cost-based reference level the ISO uses to perform the comparison is greater than \$1,000/MWh but not more than \$2,000/MWh, then the ISO shall use the Incremental Energy Bids and Minimum Generation Bids that are less than or equal to that cost-based reference level in its Day-Ahead Market or Real-Time Market (as appropriate). Bids that exceed the cost-based reference level that the NYISO uses to perform the comparison shall be reduced to equal the cost-based reference level. This process may result in some components of an Incremental Energy Bid curve being reduced, but not others.

23.7.2.4 If the cost-based reference level the ISO uses to perform the comparison is greater than \$2,000/MWh, then the ISO shall use the Incremental Energy Bids and Minimum Generation Bids that are less than or equal to \$2,000/MWh in its Day-Ahead Market or Real-Time Market (as appropriate). Incremental Energy Bids and Minimum Generation Bids that exceed \$2,000/MWh shall be recorded by the ISO but the Bids shall be restricted to a maximum of \$2,000/MWh for use in the ISO's Day-Ahead Market or Real-Time Market (as appropriate).

23.7.2.4.1 Verified Bid costs that exceed \$2,000/MWh may be recovered through a Bid Production Cost Guarantee payment in accordance with Section 18 of the ISO Services Tariff.

23.7.2.5 An Energy Storage Resource that submits an Incremental Energy Bid that exceeds \$1,000/MWh may be subject to the alternative Bid Restriction specified below if its submitted Incremental Energy Bid curve extends from a Lower Operating Limit that is less than zero MW to an Upper Operating Limit that exceeds zero MW.

Under the circumstances specified above an Energy Storage Resource's Bid(s) to withdraw energy will be restricted to the lower of (a) a value calculated in accordance with the other provisions of this Sections 23.7.2, or (b) the maximum value that will ensure the difference between Bids to withdraw Energy and Bids to inject Energy incorporate the Energy Storage Resource's Roundtrip Efficiency.

23.7.2.6 Cost components of Incremental Energy Bids and Minimum Generation Bids above \$1,000/MWh that are not included in the reference level that the ISO

uses to perform the cost comparison in this Section 23.7.2 may be eligible for recovery through a Bid Production Cost Guarantee payment following an after-the-fact review, in accordance with Sections 23.7.3.3 and 23.7.4.6 below.

23.7.3 Submission and verification of Incremental Energy Bids and Minimum Generation Bids above \$1,000/MWh, and updates to Generators' cost-based reference levels.

23.7.3.1 All NYCA Generators that submit Incremental Energy or Minimum Generation Bids that exceed \$1,000/MWh are required to submit revised fuel type or fuel price information to the NYISO's Market Information System along with their Day-Ahead and real-time Bids in order to facilitate NYISO's review and validation of the Bids that exceed \$1,000/MWh. ISO Procedures shall specify the revised fuel type or fuel price information that must be submitted to the NYISO's Market Information System along with the Incremental Energy and Minimum Generation Bids. Failure to submit required fuel type or fuel price information to the NYISO's Market Information System along with an Incremental Energy and/or Minimum Generation Bid that exceeds \$1,000/MWh will result in the Bids being automatically rejected by the ISO.

Real-Time Market Bids that include revised fuel type or fuel price information must be submitted prior to market close for the relevant Real-Time Market hour in order to be evaluated. Day-Ahead Market Bids that include revised fuel type or fuel price information must be submitted at least 15 minutes prior to the close of the Day-Ahead Market (*i.e.*, by 4:45 a.m.) in order to be evaluated.

23.7.3.2 Submission of cost information to support Incremental Energy Bids and

Minimum Generation Bids that exceed \$1,000/MWh. In order for an Incremental Energy Bid or a Minimum Generation Bid that exceeds \$1,000/MWh to be considered verified, cost information sufficient to justify the Bids must be submitted to the ISO and included by the ISO in the Generator's cost-based reference level for the relevant Day-Ahead or Real-Time Market hour.

23.7.3.3 A Market Party shall only be eligible to recover risk adders that were included in the cost-based Incremental Energy or Minimum Generation reference levels that the ISO used to perform the cost comparison described in Section 23.7.2 above for the relevant Day-Ahead or Real-Time Market hour. Other costs that were Bid, but that were not included in the cost-based Incremental Energy or Minimum Generation reference levels that the ISO used to perform the cost comparison described in Section 23.7.2 above, are eligible for recovery through a Bid Production Cost Guarantee payment in accordance with Section 18 of the ISO Services Tariff if the Market Party demonstrates that they were incurred in an after-the-fact review.

23.7.4 Development of Cost Based Reference Levels and Submission of Incremental Energy and Minimum Generation Bids that Exceed \$1,000/MWh by eligible Demand Side Resources.

23.7.4.1 These rules apply to Incremental Energy Bids (including incremental Curtailment Bids) and Minimum Generation Bids (including minimum Curtailment initiation Bids) submitted for Demand Side Resources participating in the Day-Ahead Demand Response Program or the Demand Side Ancillary Service Program. No other Demand Side Resources are eligible to submit Incremental Energy Bids or Minimum Generation Bids that exceed \$1,000/MWh.

23.7.4.2 Reference Level Development. Market Parties that submit Incremental Energy Bids or Minimum Generation Bids on behalf of Demand Side Resources that want to be able to submit Incremental Energy Bids or Minimum Generation Bids that exceed \$1,000/MWh when such Bids are consistent with a Demand-Side Resource's costs must complete the following procedures to develop cost based Incremental Energy and Minimum Generation reference levels for their Demand Side Resource.

At least 30 days prior to the start of the Capability Period for which the Market Party wants to have cost based reference levels in place for an existing Demand Side Resource, or prior to the completion of the ISO's registration process for Demand Side Resources that are entering the NYISO markets for the first time, the Market Party must develop and provide to the ISO a detailed estimate of the Demand Side Resource's incremental costs of providing load reduction and participate in a reference level development consultation with the ISO. *See* Section 23.3.3.1.4 of these Mitigation Measures.

Once a reference level has been developed for a Demand Side Resource, the Market Party is responsible for informing the ISO of substantial changes to its Demand Side Resource's incremental costs of providing load reduction, and must submit updated cost information to the ISO at least annually.

If the ISO does not have an up-to-date cost based reference level in place for a Demand Side Resource, then the Market Party will not be permitted to submit Incremental Energy Bids or Minimum Generation Bids that exceed \$1000/MWh for that Demand Side Resource.

23.7.4.3 Process for Submitting Incremental Energy and Minimum Generation

Bids that exceed \$1,000/MWh. A Market Party that timely developed cost based Incremental Energy and/or Minimum Generation reference levels for its Demand Side Resource in accordance with Section 23.7.4.2 and that determines its Demand Side Resource's incremental cost of providing load reduction is expected to exceed \$1,000/MWh for an upcoming Day-Ahead or Real-Time Market day must develop and submit to the ISO an updated, detailed estimate of the Demand Side Resource's incremental costs of providing load reduction and contact the ISO to schedule a reference level consultation by no later than 9:00 a.m. on the day before the close of the relevant Day-Ahead Market or Real-Time Market hour.

23.7.4.4 If the Market Party does not timely submit the information required in Section 23.7.4.3, then the ISO shall restrict an Incremental Energy Bid or Minimum Generation Bid that exceeds \$1,000/MWh to \$1,000/MWh.

23.7.4.5 Demand Side Resources participating in the Demand Side Ancillary Service Program are not eligible to recover costs associated with providing Incremental Energy or Minimum Generation.

23.7.4.6 Demand Side Resources participating in the Day-Ahead Demand Response Program that complied with the requirements of Section 23.7.4.3 shall only be eligible to recover risk adders that were included in the cost-based Incremental Energy or Minimum Generation reference levels that the ISO used to perform the cost comparison described in Section 23.7.2 above for the relevant Day-Ahead Market hour. Other costs that were Bid, but that were not included in

the cost-based Incremental Energy or Minimum Generation reference levels that the ISO used to perform the cost comparison described in Section 23.7.2 above, are eligible for recovery through a Bid Production Cost Guarantee payment in accordance with Section 18 of the ISO Services Tariff if the Market Party demonstrates that they were incurred in an after-the-fact review.

23.7.5 Information Requests

If the ISO requests additional information about an Incremental Energy Bid or Minimum Generation Bid that exceed \$1,000/MWh or about information supporting such a Bid or supporting a proposed change to the associated reference level, the Market Party shall respond promptly to the ISO's request. Failure to promptly respond may prevent the ISO from verifying a cost and including it in a Generator's or a Demand Response Resource's cost based Incremental Energy or Minimum Generation reference level.

23.7.6 Penalties for Submitting Inaccurate Cost Information

Submission of inaccurate cost information to the ISO in support of Incremental Energy or Minimum Generation Bids that exceed \$1,000/MWh. A Market Party that submits inaccurate cost information to the ISO for a Generator or Demand Side Resource that causes a market clearing price impact or a guarantee payment impact shall be subject to financial penalties in accordance with Section 23.4.3 of these Mitigation Measures. Submission of inaccurate information that causes a market clearing price or a guarantee payment impact shall be penalized for withholding in accordance with Sections 23.4.3.3.1, 23.4.3.3.1.1 and 23.4.3.3.1.2 of these Mitigation Measures, unless a different method of calculating a penalty applies to the behavior.

**25 Attachment J – Determination of Day-Ahead Margin Assurance Payments and
Import Curtailment Guarantee Payments**

25.1 Introduction

If a Supplier that is eligible pursuant to Section 25.2 of this Attachment J buys out of a Day-Ahead Energy, Regulation Service or Operating Reserve schedule in a manner that reduces its Day-Ahead Margin it shall receive a Day-Ahead Margin Assurance Payment, except as noted in Sections 25.2, 25.3, 25.4, and 25.5 of this Attachment J. The purpose of such payments is to protect Suppliers' Day-Ahead Margins associated with real-time reductions after accounting for: (i) any real-time profits associated with offsetting increases in real-time Energy, Regulation Service, or Operating Reserve schedules; and (ii) any Supplier-requested real-time de-rate granted by the ISO.

In addition, a Supplier may be eligible to receive an Import Curtailment Guarantee Payment if its Import is curtailed at the request of the ISO as determined pursuant to Section 25.6 of this Attachment J.

25.2 Eligibility for Receiving Day-Ahead Margin Assurance Payments

25.2.1 General Eligibility Requirements for Suppliers to Receive Day-Ahead Margin Assurance Payments

Subject to Section 25.2.2 of this Attachment J, the following categories of Resources bid by Suppliers shall be eligible to receive Day-Ahead Margin Assurance Payments: (i) all Self-Committed Flexible and ISO-Committed Flexible Generators, other than Energy Storage Resources, that are either online and dispatched by RTD or available for commitment by RTC; (ii) Demand Side Resources committed to provide Operating Reserves or Regulation Service; (iii) any Resource, including an Energy Storage Resource, that is scheduled out of economic merit order by the ISO in response to an ISO or Transmission Owner system security need or to permit the ISO to procure additional Operating Reserves; (iv) any Resource, including Energy Storage Resources, internal to the NYCA that is derated or decommitted by the ISO in response to an ISO or Transmission Owner system security need or to permit the ISO to procure additional Operating Reserves; and (v) Energy Limited Resources with an ISO-approved real-time reduction in scheduled output from its Day-Ahead schedule.

25.2.2 Exceptions

Notwithstanding Section 25.2.1 of this Attachment J, no Day-Ahead Margin Assurance Payment shall be paid to:

- 25.2.2.1 a Resource, otherwise eligible for a Day-Ahead Margin Assurance Payment, in hours in which the NYISO has increased the Resource's real-time minimum operating level above the Resource's Day-Ahead Market Energy schedule either: (i) at the Resource's request including through an adjustment to the Resource's self-commitment schedule; or (ii) in order to reconcile the ISO's dispatch with the Resource's actual output or to address reliability concerns that

arise because the Resource is not following Base Point Signals; or (iii) an Intermittent Power Resource that depends on wind as its fuel.

25.2.2.2 a Resource, otherwise eligible for Day-Ahead Margin Assurance Payments, in hours in which the NYISO has increased the Resource's real-time minimum operating level at the Resource's request, including through an adjustment to the Resource's self-commitment schedule, above the MW level determined by subtracting the Resource's Day-Ahead Market Regulation Service schedule from its Day-Ahead Market Energy schedule.

25.2.2.3 a Resource, otherwise eligible for Day-Ahead Margin Assurance Payments, in hours in which the Resource reduces the MW quantity specified in its real-time Regulation Capacity Bid below its Day-Ahead Market Regulation Service schedule.

25.2.2.4 a Generator, otherwise eligible for Day-Ahead Margin Assurance Payments, for (i) any hour in which the Incremental Energy Bids submitted in the Real-Time Market for that Generator exceed the Incremental Energy Bids submitted in the Day-Ahead Market, or the mitigated Day-Ahead Incremental Energy Bids where appropriate, for the portion of that Generator's Capacity that was scheduled in the Day-Ahead Market; and (ii) the two hours immediately preceding and the two hours immediately following the hour(s) in which the Incremental Energy Bids submitted in the Real-Time Market for that Generator exceed the Incremental Energy Bids submitted in the Day-Ahead Market, or the mitigated Day-Ahead Incremental Energy Bids where appropriate, for the portion of that Generator's Capacity that was scheduled in the Day-Ahead Market.

25.2.2.5 A Generator that is available for commitment by RTC and otherwise eligible for Day-Ahead Margin Assurance Payments, for (i) any hour in which the Start-Up Bids submitted in the Real-Time Market for that Generator exceed the Start-Up Bids submitted in the Day-Ahead Market, or the mitigated Day-Ahead Start-Up Bids where appropriate, and that Generator was scheduled for Energy in that hour in the Day-Ahead Market; and (ii) the two hours immediately preceding and the two hours immediately following the hour(s) in which the Start-Up Bids submitted in the Real-Time Market for that Generator exceed the Start-Up Bids submitted in the Day-Ahead Market, or the mitigated Day-Ahead Start-Up Bids where appropriate, and that Generator was scheduled for Energy or Regulation Service in that hour in the Day-Ahead Market.

25.2.2.6 A Generator that is available for commitment by RTC and otherwise eligible for Day-Ahead Margin Assurance Payments, for (i) any hour in which the dollar component of the Minimum Generation Bids submitted in the Real-Time Market for that Generator exceed the dollar component of the Minimum Generation Bids submitted in the Day-Ahead Market, or the dollar component of the mitigated Day-Ahead Minimum Generation Bids where appropriate, and that Generator was scheduled for Energy in that hour in the Day-Ahead Market; and (ii) the two hours immediately preceding and the two hours immediately following the hour(s) in which the dollar component of the Minimum Generation Bids submitted in the Real-Time Market for that Generator exceed the dollar component of the Minimum Generation Bids submitted in the Day-Ahead Market, or the dollar component of the mitigated Day-Ahead Minimum Generation Bids

where appropriate, and that Generator was scheduled for Energy in that hour in the Day-Ahead Market.

25.3 Calculation of Day-Ahead Margin Assurance Payments

25.3.1 Formula for Day-Ahead Margin Assurance Payments for Generators, Except for Limited Energy Storage Resources

Subject to Sections 25.4 and 25.5 of this Attachment J, Day-Ahead Margin Assurance Payments for Generators, except for Limited Energy Storage Resources, shall be determined by applying the following equations to each individual Generator using the terms as defined in Section 25.3.4:

$$DMAP_{hu} = \max\left(0, \sum_{i \in h} CDMAP_{iu}\right)$$

where:

$$CDMAP_{iu} = CDMAPen_{iu} + \sum_P CDMAPres_{iup} + CDMAPreg_{iu}$$

25.3.1.1 Energy Contribution for Day-Ahead Margin Assurance Payments

If the Generator's (i) Day-Ahead schedule is to inject Energy (*i.e.*, greater than zero MW) and its real-time Energy schedule is lower than its Day-Ahead Energy schedule; or (ii) Day-Ahead schedule is to withdraw Energy (*i.e.*, less than zero MW) and its real-time Energy schedule is greater than its Day-Ahead Energy schedule, then:

$$CDMAPen_{iu} = \left((DASen_{hu} - LL_{iu}) * RTPen_{iu} - \int_{LL_{iu}}^{DASen_{hu}} DABen_{hu} \right) * \frac{Seconds_i}{3600}$$

If the Generator's (i) Day-Ahead Energy schedule is to inject Energy (*i.e.*, greater than zero MW) and its real-time Energy schedule is greater than or equal to its Day-Ahead Energy schedule; or (ii) Day-Ahead Energy schedule is to withdraw Energy (*i.e.*, less than zero MW),

and its real-time Energy schedule is less than or equal to its Day-Ahead Energy schedule; or

(iii) Day-Ahead Energy schedule is for zero MW, then:

$$CDMAPen_{iu} = \min \left[\left((DASen_{hu} - UL_{iu}) * RTPen_{iu} + \int_{DASen_{hu}}^{UL_{iu}} RTBen_{iu} \right) * \frac{Seconds_i}{3600}, 0 \right]$$

25.3.1.2 Operating Reserve Contribution for Day-Ahead Margin Assurance Payments

If the Generator's real-time schedule for a given Operating Reserve product, p, is lower than its Day-Ahead Operating Reserve schedule for that product then:

$$CDMAPres_{iup} = [(DASres_{hup} - RTSres_{iup}) * (RTPres_{iup} - DABres_{hup})] * \frac{Seconds_i}{3600}$$

If the Generator's real-time schedule for a given Operating Reserve product, p, is greater than or equal to its Day-Ahead Operating Reserve schedule for that product then:

$$CDMAPres_{iup} = [(DASres_{hup} - RTSres_{iup}) * (RTPres_{iup})] * \frac{Seconds_i}{3600}$$

25.3.1.3 Regulation Service Contribution for Day-Ahead Margin Assurance Payments

If the Generator's real-time Regulation Service schedule is less than its Day-Ahead Regulation Service schedule then:

$$CDMAPreg_{iu} = [(DASreg_{hu} - RTSreg_{iu}) * (RTPreg_{iu} - DABreg_{hu})] * \frac{Seconds_i}{3600} + [(-1 * RTMreg_{iu}) * \max(0, RTPreg_{iu} - RTBreg_{iu})]$$

If the Generator's real-time Regulation Schedule is greater than or equal to the Day-Ahead Regulation Service schedule then:

$$CDMAPreg_{iu} = [(DASreg_{hu} - RTSreg_{iu}) * \max((RTPreg_{iu} - RTBreg_{iu}), 0)] * \frac{Seconds_i}{3600} + [(-1 * RTMreg_{iu}) * \max(0, RTPreg_{iu} - RTBreg_{iu})]$$

25.3.2 Formula for Day-Ahead Margin Assurance Payments for Demand Side Resources

25.3.2.1 Formula for Day-Ahead Margin Assurance Payment for Demand Side Resources

Subject to Section 25.5 of this Attachment J, Day-Ahead Margin Assurance Payments for Demand Side resources scheduled to provide Operating Reserves or Regulation Service shall be determined by applying the following equations to each individual Demand Side Resource using the terms as defined in Section 25.3.4, except for RPI_{iu}, which is defined in Section 25.3.2.2:

$$DMAP_{hu} = \max\left(0, \sum_{i \in h} CDMAP_{iu}\right)$$

where:

$$CDMAP_{iu} = \sum_p CDMAPres_{iup} + CDMAPreg_{iu}$$

If the Demand Side Resource's real-time schedule for a given Operating Reserve product, p, is lower than its Day-Ahead Operating Reserve schedule for that product then:

$$CDMAPres_{iup} = [(DASres_{hup} - RTSres_{iup}) * (RTPres_{iup} - DABres_{hup})] * RPI_{iu} * \frac{Seconds_i}{3600}$$

If the Demand Side Resource's real-time schedule for a given Operating Reserve product, p, is greater than or equal to its Day-Ahead Operating Reserve schedule for that product then:

$$CDMAPres_{iup} = [(DASres_{hup} - RTSres_{iup}) * (RTSPres_{iup})] * RPI_{iu} * \frac{Seconds_i}{3600}$$

If the Demand Side Resource's real-time Regulation Service schedule is less than its Day-Ahead Regulation Service schedule then:

$$CDMAPreg_{iu} = [(DASreg_{hu} - RTSreg_{iu}) * (RTPreg_{iu} - DABreg_{hu})] * \frac{Seconds_i}{3600} + [(-1 * RTMreg_{iu}) * \max(0, RTPreg_{iu} - RTBreg_{iu})]$$

If the Demand Side Resource's real-time Regulation Schedule is greater than or equal to the Day-Ahead Regulation Service schedule then:

$$CDMAPreg_{iu} = [(DASreg_{hu} - RTSreg_{iu}) * \max((RTPreg_{iu} - RTBreg_{iu}), 0)] * \frac{Seconds_i}{3600} + [(-1 * RTMreg_{iu}) * \max(0, RTPreg_{iu} - RTBreg_{iu})]$$

25.3.2.2 Reserve Performance Index for Demand Side Resource Suppliers of Operating Reserves

The ISO shall produce a Reserve Performance Index for purposes of calculating a Day Ahead Margin Assurance Payment for a Demand Side Resource providing Operating Reserves. The Reserve Performance Index shall take account of the actual Demand Reduction achieved by the Supplier of Operating Reserves following the ISO's instruction to convert Operating Reserves to Demand Reduction.

The Reserve Performance Index shall be a factor with a value between 0.0 and 1.0 inclusive. For each interval in which the ISO has not instructed the Demand Side Resource to convert its Operating Reserves to Demand Reduction, the Reserve Performance Index shall have a value of one. For each interval in which the ISO has instructed the Demand Side Resource to convert its Operating Reserves to Demand Reduction the Reserve Performance Index shall be calculated pursuant to the following formula, provided however when UAG_i is zero or less, the Reserve Performance Index shall be set to zero:

$$RPI_{iu} = \min[(UAG_i / ADG_i + .1), 1]$$

Where:

RPI_{iu} = Reserve Performance Index in interval i for Demand Side Resource u ;

UAG_i = average actual Demand Reduction for interval i , represented as a positive generation value; and

ADG_i = average scheduled Demand Reduction for interval i , represented as a positive generation base point.

25.3.3 Formula for Day-Ahead Margin Assurance Payments for Limited Energy Storage Resources

Day-Ahead Margin Assurance Payments for Limited Energy Storage Resources scheduled to provide Regulation Service shall be determined by applying the following equations to each Resource using the terms as defined in Section 25.3.4; *provided, however*, that a Day-Ahead Margin Assurance Payment is payable only for intervals in which the NYISO has reduced the real-time Regulation Service offer (in MWs) of a Limited Energy Storage Resource and the NYISO is not pursuing LESR Energy Management for such Resource for such interval, pursuant to ISO Procedures:

If the LESR's real-time Regulation Service schedule is less than its Day-Ahead Regulation Service schedule and the real-time Regulation Capacity Market Price is greater than the Day-Ahead Regulation Capacity Bid price then:

$$CDMAPreg_{iu} = [(DASreg_{hu} - RTSreg_{iu}) * (RTPreg_{iu} - DABreg_{hu})] * K_p * \frac{Seconds_i}{3600} + [(-1 * RTMreg_{iu}) * \max(0, RTPreg_{iu} - RTBreg_{iu})]$$

If the LESR's real-time Regulation Service schedule is less than its Day-Ahead Regulation Service schedule and the real-time Regulation Capacity Market price is less than or equal to the Day-Ahead Regulation Capacity Bid price then:

$$CDMAPreg_{iu} = [(DASreg_{hu} - RTSreg_{iu}) * (RTPreg_{iu} - DABreg_{hu})] * \frac{Seconds_i}{3600} + [(-1 * RTMreg_{iu}) * \max(0, RTPreg_{iu} - RTBreg_{iu})]$$

If the LESR's real-time Regulation Service schedule is greater than or equal to the Day-Ahead Regulation Service schedule then:

$$CDMAPreg_{iu} = [(DASreg_{hu} - RTSreg_{iu}) * \max((RTPreg_{iu} - RTBreg_{iu}), 0)] * \frac{Seconds_i}{3600} + [(-1 * RTMreg_{iu}) * \max(0, RTPreg_{iu} - RTBreg_{iu})]$$

25.3.4 Terms Used in this Attachment J

The terms used in the formulas in this Attachment J shall be defined as follows:

h is the hour that includes interval *i*;

- DMAP_{hu}* = the Day-Ahead Margin Assurance Payment attributable in any hour *h* to any Supplier *u*;
- CDMAP_{iu}* = the contribution of RTD interval *i* to the Day-Ahead Margin Assurance Payment for Supplier *u*;
- CDMAPen_{iu}* = the Energy contribution of RTD interval *i* to the Day-Ahead Margin Assurance Payment for Supplier *u*;
- CDMAPreg_{iu}* = the Regulation Service contribution of RTD interval *i* to the Day-Ahead Margin Assurance Payment for Supplier *u*;
- CDMAPres_{iup}* = the Operating Reserve contribution of RTD interval *i* to the Day-Ahead Margin Assurance Payment for Supplier *u* determined separately for each Operating Reserve product *p*;
- DASen_{hu}* = Day-Ahead Energy schedule for Supplier *u* in hour *h*;
- DASreg_{hu}* = Day-Ahead schedule for Regulation Service for Supplier *u* in hour *h*;
- DASres_{hup}* = Day-Ahead schedule for Operating Reserve product *p*, for Supplier *u* in hour *h*;
- DABen_{hu}* = Day-Ahead Energy Bid cost for Supplier *u* in hour *h*, including the Minimum Generation Bid and Incremental Energy Bids;

- $DABreg_{hu}$ = Day-Ahead Regulation Capacity Bid price for Supplier u in hour h ;
- $DABres_{hup}$ = Day-Ahead Availability Bid for Operating Reserve product p for Supplier u in hour h ;
- $RTSen_{iu}$ = real-time Energy scheduled for Supplier u in interval i , and calculated as the arithmetic average of the 6-second AGC Base Point Signals sent to Supplier u during the course of interval i ;
- $RTSreg_{iu}$ = real-time schedule for Regulation Service for Supplier u in interval i .
- $RTSres_{iup}$ = real-time schedule for Operating Reserve product p for Supplier u in interval i .
- $RTBreg_{iu}$ = real-time Regulation Capacity Bid price for Supplier u in interval i .
- $RTBen_{iu}$ = real-time Energy Bid cost for Supplier u in interval i , including the Minimum Generation Bid and Incremental Energy Bids.
- $RTBregm_{iu}$ = real-time Regulation Movement Bid price for Supplier u in interval i .
- $RTMreg_{iu}$ = real-time Regulation Movement MWs for Supplier u in interval i ;
- AE_{iu} = either, (1) when $RTSen_{iu}$ is greater than zero MW, average actual Energy injections or withdrawals by Supplier u in interval i but not more than $RTSen_{iu}$ plus Compensable Overgeneration; or (2) when $RTSen_{iu}$ is less than or equal to zero MW, average actual Energy injections or withdrawal by Supplier u in interval i ;
- $RTPen_{iu}$ = real-time price of Energy at the location of Supplier u in interval i ;
- $RTPreg_{iu}$ = real-time price of Regulation Capacity at the location of Supplier u in interval i ;
- $RTPres_{iup}$ = real-time price of Operating Reserve product p at the location of Supplier u in interval i ;
- $RTPregm_{iu}$ = real-time Regulation Movement Market Price at the location of Supplier u in interval i ;
- LL_{iu} = When the Day-Ahead Energy schedule is to inject, given that $RTSen_{iu} < DASen_{hu}$, either:
- (a) if $RTSen_{iu} < EOP_{iu}$, then $LL_{iu} = \max(\min(\max(RTSen_{iu}, \min(AE_{iu}, EOP_{iu})), DASen_{hu}), 0)$; or
- (b) if $RTSen_{iu} \geq EOP_{iu}$, then $LL_{iu} = \max(\min(RTSen_{iu}, \max(AE_{iu}, EOP_{iu}), DASen_{hu}), 0)$
- When the Day-Ahead Energy schedule is to withdraw, given that $RTSen_{iu} > DASen_{hu}$:
- $$LL_{iu} = \min(\max(DASen_{hu}, AE_{iu}, EOP_{iu}), RTSen_{iu}, 0)$$
- UL_{iu} = When the Day-Ahead Energy schedule is to inject, or the Day-Ahead Energy schedule is zero MW and the real-time Energy schedule is to inject, given that $RTSen_{iu} \geq DASen_{hu}$, either:
- (a) if $RTSen_{iu} \geq EOP_{iu} \geq DASen_{hu}$, then $UL_{iu} = \min(RTSen_{iu}, \max(AE_{iu}, EOP_{iu}))$; or
- (b) otherwise, then $UL_{iu} = \max(RTSen_{iu}, \min(AE_{iu}, EOP_{iu}))$

When the Day-Ahead Energy schedule is to withdraw, or the Day-Ahead Energy schedule is zero MW and the real-time Energy schedule is to withdraw, given that $RTSen_{iu} \leq DASen_{hu}$:

$$UL_{iu} = \min (RTSen_{iu}, \max (AE_{iu}, EOP_{iu}))$$

EOP_{iu} = the Economic Operating Point of Supplier u in interval i calculated without regard to ramp rates;

$Seconds_i$ = number of seconds in interval i

KPI_{pi} = the factor derived from the Regulation Service Performance index for Resource u for interval i as defined in Rate Schedule 3 of this Services Tariff.

25.4 Exception for Generators Lagging Behind RTD Base Point Signals

If an otherwise eligible Generator's average Actual Energy Injection in an RTD interval (*i.e.*, its Actual Energy Injections averaged over the RTD interval) is less than or equal to its penalty limit for under-generation value for that interval, as computed below, it shall not be eligible for Day-Ahead Margin Assurance Payments for that interval.

The penalty limit for under-generation value is the tolerance described in Section 15.3A.1 of Rate Schedule 3-A of this ISO Services Tariff, which is used in the calculation of the persistent under-generation charge applicable to Generators that are not providing Regulation Service.

25.5 Rules Applicable to Supplier Derates

Suppliers that request and are granted a derate of their real-time Operating Capacity, but that are otherwise eligible to receive Day-Ahead Margin Assurance Payments may receive a payment up to a Capacity level consistent with their revised Emergency Upper Operating Limit or Normal Upper Operating Limit, whichever is applicable. The foregoing rule shall also apply to a Generator otherwise eligible for a Day-Ahead Margin Assurance Payment in hours in which the ISO has derated the Generator's Operating Capacity in order to reconcile the ISO's dispatch with the Generator's actual output, or to address reliability concerns that arise because the Generator is not following Base Point Signals. If a Supplier's derated real-time Operating Capacity is lower than the sum of its Day-Ahead Energy, Regulation Services, and Operating Reserve schedules then when the ISO conducts the calculations described in Section 25.3 above, the $DASen$, $DASeg$ and $DASres_p$ variables will be reduced by $REDen$, $REDreg$ and $REDres_p$ respectively. $REDen$, $REDreg$ and $REDres_p$ shall be calculated using the formulas below:

$$REDtot_{iu} = \max\left(DASen_{hu} + DASreg_{hu} + \sum_p DASres_{hup} - RTUOL_{iu}, 0\right)$$

$$POTREDen_{iu} = \max(DASen_{hu} - RTSen_{iu}, 0)$$

$$POTREDreg_{iu} = \max(DASreg_{hu} - RTSreg_{iu}, 0)$$

$$POTREDres_{iup} = \max(DASres_{hup} - RTSres_{iup}, 0)$$

$$REDen_{iu} = \left(POTREDen_{iu} / \left(POTREDen_{iu} + POTREDreg_{iu} + \sum_p POTREDres_{iup} \right) \right) * REDtot_{iu}$$

$$REDreg_{iu} = \left(POTREDreg_{iu} / \left(POTREDen_{iu} + POTREDreg_{iu} + \sum_p POTREDres_{iup} \right) \right) * REDtot_{iu}$$

$$REDres_{iup} = \left(POTREDres_{iup} / \left(POTREDen_{iu} + POTREDreg_{iu} + \sum_p POTREDres_{iup} \right) \right) * REDtot_{iu}$$

where:

- $RTUOL_{iu}$ = The real-time Emergency Upper Operating Limit or Normal Upper Operating Limit whichever is applicable of Supplier u in interval i
- $REDtot_{iu}$ = The total amount in MW that Day-Ahead schedules need to be reduced to account for the derate of Supplier u in interval i
- $REDen_{iu}$ = The amount in MW that the Day-Ahead Energy schedule is reduced for the purposes of calculating the Day-Ahead Margin Assurance Payment for Supplier u in interval i
- $REDreg_{iu}$ = The amount in MW that Supplier u 's Day-Ahead Regulation Service schedule is reduced for the purposes of calculating the Day-Ahead Margin Assurance Payment in interval i
- $REDres_{iup}$ = The amount in MW that Supplier u 's Day-Ahead Operating Reserve schedule for Operating Reserves product p is reduced for the purposes of calculating the Day-Ahead Margin Assurance Payment in interval i
- $POTREDen_{iu}$ = The potential amount in MW that Supplier u 's Day-Ahead Energy schedule could be reduced for the purposes of calculating the Day-Ahead Margin Assurance Payment for Supplier u in interval i
- $POTREDreg_{iu}$ = The potential amount in MW that Supplier u 's Day-Ahead Regulation Service schedule could be reduced for the purposes of calculating the Day-Ahead Margin Assurance Payment for Supplier u in interval i
- $POTREDres_{iup}$ = The potential amount in MW that Supplier u 's Day-Ahead Operating Reserve Schedule for Operating Reserve product p could be reduced for the purposes of calculating the Day-Ahead Margin Assurance Payment for Supplier u in interval i

All other variables are as defined above.

25.6 Import Curtailment Guarantee Payments

25.6.1 Eligibility for an Import Curtailment Guarantee Payment for an Import Curtailed by the ISO

In the event that the Energy injections for an Import scheduled by RTC or RTD at a Proxy Generator Bus, other than a CTS Enabled Proxy Generator Bus, are Curtailed at the request of the ISO, and (i) the real-time Energy Profile MW is equal to or greater than the Day-Ahead Energy Schedule for that interval, and (ii) the real-time Decremental Bid is less than or equal to the default real-time Decremental Bid amount as established by ISO procedures, then the Supplier or Transmission Customer that is subjected to the Curtailment, in addition to the charge for Energy Imbalance, shall be eligible for an Import Curtailment Guarantee Payment as determined in Section 25.6.2 of this Attachment J. Suppliers scheduling Imports at CTS Enabled Proxy Generator Buses shall not be eligible for Import Curtailment Guarantee payments for those Transactions.

25.6.2 Formula for an Import Curtailment Guarantee Payment for a Supplier Whose Import Was Curtailed by the ISO

A Supplier eligible under Section 25.6.1 of this Attachment J shall receive an Import Curtailment Guarantee Payment for its curtailed Energy injections that is equal to the daily sum of the hourly payments which, for each hour of Import t, is calculated as the greater of the interval payments determined for the hour or zero as seen in the formula below.

Import Curtailment Guarantee Payment to Supplier u in association with Import t =

$$\sum_{h=1}^N \max \left(\sum_{i=1}^H (RTLBM P_{ti} - \max(DADecBid_{ti}, 0)) * (DAen_{ti} - RTDen_{ti}) * \frac{S_i}{3600}, 0 \right)$$

Where

N = the number of hours in the Dispatch Day

- H = the number of intervals in hour h
- i = the relevant interval in hour h ;
- S_i = number of seconds in interval i ;
- $RTLBM P_{t,i}$ = the real-time LBMP, in \$/MWh, for interval i at the Proxy Generator Bus which is the source of the Import t .
- $DA Dec Bid_{t,i}$ = the Day Ahead Decremental Bid price associated with the Day-Ahead energy schedule, in \$/MWh, for Import t in hour h containing interval i ;
- $DA en_{t,i}$ = the Day Ahead scheduled Energy injections, in MWh, for Import t in hour h containing interval i as determined by Security Constrained Unit Commitment (SCUC); and
- $RT Den_{t,i}$ = the scheduled Energy injections, in MWh, for Import t in interval i as determined by Real-Time Dispatch (RTD).